

Broward County

License Number: 1653029

DUDE...PANCAKES!

License Type: Mobile Food Dispensing Vehicle

9837 W SAMPLE RD, CORAL SPRINGS 33065

Inspection Date: 06/19/2020

Inspection Number: 1216576

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator reheats chicken on flat top grill.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336257		NISELS CUISINE	
License Type: Permanent Food Service		27455 S DIXIE HWY, HOMESTEAD 33032	
Inspection Date: 06/17/2020	Inspection Number: 2982554	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed silver extinguisher gauge in red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326911		CHEESECAKE FACTORY (THE)	
License Type: Permanent Food Service		7535 DADELAND MALL SP2000, MIAMI 33156	
Inspection Date: 06/15/2020	Inspection Number: 2982348	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Inside linen room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2359146		PIZZA ITALIA MIAMI	
License Type: Mobile Food Dispensing Vehicle		4244 SW 164TH CT, MIAMI 33185	
Inspection Date: 06/17/2020	Inspection Number: 1221846	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: URIBE, GUISELLA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2608509		ALLSTARRZ RESTAURANT & LOUNGE	
License Type: Permanent Food Service		1111 CESERY BLVD, JACKSONVILLE 32211	
Inspection Date: 06/18/2020	Inspection Number: 2932792	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two 20lb propane tanks stored in liquor closet. Operator removed tanks from the building. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2651812		HICKORY'S HEAVEN	
License Type: Mobile Food Dispensing Vehicle		2394 ADAMS LAKE BLVD, JACKSONVILLE 32221	
Inspection Date: 06/12/2020	Inspection Number: 1216681	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PACE, PATRICK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2613184		A LITTLE BIT OF SAIGON	
License Type: Permanent Food Service		3503 KERNAN SOUTH BLVD STE 6, JACKSONVILLE 32224	
Inspection Date: 06/18/2020	Inspection Number: 2973328	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Kitchen exit door pathway blocked with a meat slicer.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Hillsborough County

License Number: 3915865

JAI HO RESTAURANT

License Type: Permanent Food Service

2311 E FOWLER AVE, TAMPA 33612

Inspection Date: 06/18/2020

Inspection Number: 2974995

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

49-03-4

Flammables stored/debris present in storage room by back door. America's propane tanks. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Lee County

License Number: 4604218		MCDONALDS #14767	
License Type: Permanent Food Service		1530 COLONIAL BLVD, FORT MYERS 33907	
Inspection Date: 06/17/2020	Inspection Number: 2982772	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MULROY, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed wet vac at bottom of stairs blocking emergency exit. Operator moved wet vac **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 4605297		LION KING CHINESE RESTAURANT	
License Type: Permanent Food Service		1751 NE PINE ISLAND ROAD #C, CAPE CORAL 33909	
Inspection Date: 06/18/2020	Inspection Number: 2982871	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EHMER, ANNETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Front counter.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4606006		EL TARASCO MEXICAN RESTAURANT	
License Type: Permanent Food Service		728 PINE ISLAND RD SW STE 8-9, CAPE CORAL 33991	
Inspection Date: 06/18/2020	Inspection Number: 2982107	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: EHMER, ANNETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door. **Repeat Violation** - From follow-up inspection 2020-06-12: **Time Extended** - From follow-up inspection 2020-06-18: **Time	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Manatee County

License Number: 5150372

MONTY JONES

License Type: Mobile Food Dispensing Vehicle

4460 TALLEVAST RD, SARASOTA 34243

Inspection Date: 06/19/2020

Inspection Number: 1214351

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813727

CARIBBEAN FINGERS TASTE

License Type: Permanent Food Service

4981 W COLONIAL DR, ORLANDO 32808

Inspection Date: 06/15/2020

Inspection Number: 2980390

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Call Back -
Complied

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

46-04-4

- From initial inspection : Exit door locked. For reporting purposes only.
 Back door is blocked from outside with a brick wall. - From follow-up inspection
 2020-06-15: **Time Extended**

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5811575

PIZZERIA VALDIANO

License Type: Permanent Food Service

421 N ALFAYA TRL, ORLANDO 32828

Inspection Date: 06/16/2020

Inspection Number: 2976848

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked, empty boxes , by back door. For reporting purposes only.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Palm Beach County

License Number: 6006378

O' CONNOR PUB

License Type: Permanent Food Service

9900 SW 14 ST, BOCA RATON 33428-6647

Inspection Date: 03/10/2020

Inspection Number: 2981541

Inspection Type: Routine - Food

Inspection Disposition: Informal
Conference - To Be Retired

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

45-04-4

Observed: Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - exhaust hood has ample FSS equipment that covers three deep fryers but not additional added

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6052227

THATS AMORE

License Type: Mobile Food Dispensing Vehicle

308 N FEDERAL HWY, BOYNTON BEACH 33435

Inspection Date: 06/19/2020

Inspection Number: 1223620

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216540 BRITTS PIZZA
 License Type: Permanent Food Service 10709 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 06/16/2020 Inspection Number: 2973074 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No hood system over new fryers in newly added salad prep area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6217242 CEDARS GRILL
 License Type: Permanent Food Service 6549 54 AVE N, ST.PETERSBURG 33709

Inspection Date: 06/17/2020 Inspection Number: 2978990 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: HOBBS, ANDREW

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. In storage closet. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2020-06-17: Using propa	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216189 EL CARRIEL
 License Type: Permanent Food Service 1215 N MARTIN LUTHER KING, CLEARWATER 33755

Inspection Date: 06/19/2020 Inspection Number: 2967730 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215545 LITTLE GREEK FRESH GRILL
 License Type: Permanent Food Service 320 E LAKE RD, PALM HARBOR 34685

Inspection Date: 06/18/2020 Inspection Number: 2974204 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Twelve cases of pitas in front of it	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pinellas County

License Number: 6215937

COASTAL CANTINA AND GRILL

License Type: Permanent Food Service

519 2ND ST S, SAFETY HARBOR 34695

Inspection Date: 06/19/2020

Inspection Number: 2966244

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

45-02-4 Red Portable fire extinguisher gauge in red zone. For reporting purposes only. In prep kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801550

SUNNYSIDE CAFE

License Type: Permanent Food Service

4900 N TAMIAMI TRL, SARASOTA 34234

Inspection Date: 06/16/2020

Inspection Number: 2960675

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed near men's room. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407307

TOMOKA BREWING COMPANY

License Type: Permanent Food Service

4647 CLYDE MORRIS BLVD UNIT 504, PORT ORANGE 32129

Inspection Date: 06/16/2020

Inspection Number: 2973773

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LARSON, SARAH

Violation Code

Observation

Violation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.