

**Alachua County**

License Number: 1103413

SOHAO STREET FARE CAFE

License Type: Permanent Food Service

3045 SW 34 ST STE 16, GAINESVILLE 32608

Inspection Date: 07/02/2020

Inspection Number: 3024918

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
 Observed the hallway to the back Marked Exit, is cluttered with boxes on both sides of the 47 inch hallway. At 2 points currently, there is less than 12 inches to pass through. \*\*Repeat Violation\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2329732

PAPA PASTA LLC

License Type: Catering

860 NE 79 ST STE B, MIAMI 33138

Inspection Date: 06/30/2020

Inspection Number: 1115243

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 lb gallon propane tank inside kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326601

BURGER KING

License Type: Permanent Food Service

15170 SW 72 ST, MIAMI 33193

Inspection Date: 07/02/2020

Inspection Number: 3033698

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2020-07-03: Portable fire extinguisher gauge in red zone \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2607689

CREOLE'S CAFE

License Type: Permanent Food Service

7825 BAYMEADOWS WAY STE 109, JACKSONVILLE 32256

Inspection Date: 07/02/2020

Inspection Number: 3033246

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. No hood suppression system over flat top and fryer area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3700027

LITTLE LADY CAFE

License Type: Permanent Food Service

13 S BROOKSVILLE AVE, BROOKSVILLE 34601

Inspection Date: 07/02/2020

Inspection Number: 2984564

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Electric skillet with oil, frying chicken and fries not under a hood system. Operator states the issue is temporary and the fryer needs to be fixed.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4101168

DUNKINS DONUTS/BASKIN ROBBINS

License Type: Permanent Food Service

2138 MIRACLE MILE, VERO BCH 32960

Inspection Date: 06/29/2020

Inspection Number: 2984197

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Martin County**

License Number: 5301453

TWO BROTHERS PIZZA LLC

License Type: Permanent Food Service

8423 SE CHURCH ST, HOBE SOUND 33455

Inspection Date: 07/01/2020

Inspection Number: 3007746

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HORTON, TIMOTHY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryers behind pizza oven. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5402704

KENTUCKY FRIED CHICKEN/TACO BELL

License Type: Permanent Food Service

6501 OVERSEAS HWY, MARATHON 33050

Inspection Date: 07/01/2020

Inspection Number: 3011682

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Back door Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5813330

ALOFT ORLANDO DOWNTOWN 2ND FLOOR KITCHEN

License Type: Permanent Food Service

500 S ORANGE AVE, ORLANDO 32801

Inspection Date: 07/02/2020

Inspection Number: 2988882

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: QUINONES, ANTONIO

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector's boiler report is required annually  
for power boilers and high pressure/high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.

License Number: 5809052

EMBASSY SUITES HOTEL

License Type: Permanent Food Service

5835 T. G. LEE BLVD, ORLANDO 32822

Inspection Date: 07/02/2020

Inspection Number: 3003223

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes  
only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector boiler report is required annually for  
power boilers and high pressure or high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.



**Palm Beach County**

License Number: 6022311

RESIDENCE INN BY MARRIOTT PALM BEACH GARDENS

License Type: Permanent Food Service

4250 DESIGN CENTER DR, PALM BEACH GARDENS 33410

Inspection Date: 06/29/2020

Inspection Number: 2983958

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HORTON, TIMOTHY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pinellas County**

License Number: 6217330

WHISKEY WINGS

License Type: Permanent Food Service

40737 US 19 N, TARPON SPRINGS 34689

Inspection Date: 07/02/2020

Inspection Number: 2995071

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Removed from building \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Walton County**

License Number: 7650102

LOVE AND TACOS

License Type: Mobile Food Dispensing Vehicle

55 E ORANGE BLOSSOM AVE, DEFUNIAK SPRINGS 32433

Inspection Date: 06/30/2020

Inspection Number: 1223890

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.  
- electrical outlet under electrical box broken in half.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.