

Brevard County

License Number: 1505681 HOLIDAY INN TITUSVILLE
 License Type: Hotel 4715 HELEN HAUSER BLVD, TITUSVILLE 32780

Inspection Date: 07/03/2019 Inspection Number: 1150032 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Last inspection 6-7-17	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500414 GREEN FORTUNE LLC
 License Type: Apartment 1708 ELM ST, ROCKLEDGE 32955

Inspection Date: 07/02/2019 Inspection Number: 1461060 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FRANZ, LINDA Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Between stairwell (wood) and balcony surround, property manager removed LP tank and relocated. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1617779 JACK BESNER TRUST HILDA BESNER TRUSTEE
 License Type: Apartment 17 SW 5 AVE, DANIA 33004

Inspection Date: 07/02/2019 Inspection Number: 1460658 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Wood covering window East side preventing egress from wood covered windows.For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600158 1639 MADISON LLC
 License Type: Apartment 1639 MADISON ST, HOLLYWOOD 33020

Inspection Date: 07/03/2019 Inspection Number: 1486799 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. bars covering some apartment windows preventing egress from metal covered windows. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1605113 JOHNSON STREET APARTMENTS
 License Type: Apartment 1724 JOHNSON ST, HOLLYWOOD 33020

Inspection Date: 07/03/2019 Inspection Number: 1476760 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. Metal mesh covering window facing alley preventing egress from metal covered window.For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604522 2449-2501 NE 11 ST APTS
 License Type: Apartment 2449 NE 11 ST, FORT LAUDERDALE 33304-4548

Inspection Date: 07/01/2019 Inspection Number: 1439705 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. 2459 building - between units 15 & 16 on 3rd floor. - From follow-up inspection 2019-07-01: Unable to verify at call back inspection. Building being tents for termites. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601092

DEEJAY BEACH RESORT APARTMENTS

License Type: Apartment

4617 EL MAR DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 07/03/2019

Inspection Number: 1475038

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Second floor by unit 10W.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310929 CHATEAUBLEAU INN
 License Type: Hotel 1211 E PONCE DE LEON BLVD, CORAL GABLES 33134-3316

Inspection Date: 07/02/2019 Inspection Number: 1151404 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed outlet hanging out of wall in room 508.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301429 THE BETTY
 License Type: Apartment 2271 SW 9 ST, MIAMI 33135

Inspection Date: 07/05/2019 Inspection Number: 1487360 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher by unit number 1, 7 and 11 missing breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302021 DEL RIO APARTMENTS #125
 License Type: Apartment 125 SW 18 CT, MIAMI 33135

Inspection Date: 07/03/2019 Inspection Number: 1450286 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-07-03: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330321 PARKVIEW APARTMENTS
 License Type: Apartment 1310 NW 8 CRT, MIAMI 33136

Inspection Date: 07/03/2019 Inspection Number: 1460389 Inspection Type: Lodging-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305534 RICHMOND HOTEL
 License Type: Hotel 1757 COLLINS AVE, MIAMI BEACH 331392003

Inspection Date: 07/02/2019 Inspection Number: 1149592 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302086 2401 CORAL WAY LLC
 License Type: Apartment 2401 SW 22 ST, MIAMI 33145

Inspection Date: 07/01/2019 Inspection Number: 1461048 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ALEJANDRO Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. First floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307942 MIAMI INT'L AIRPORT HOTEL
 License Type: Hotel MIAMI INT'L AIRPORT, MIAMI 33159

Inspection Date: 07/01/2019 Inspection Number: 1146127 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-07-01: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328246 OCEAN POINT RESORT & CLUB
 License Type: Hotel 17375 COLLINS AVE, GOLDEN BEACH 33160

Inspection Date: 07/05/2019 Inspection Number: 1149381 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329338 HILTON GARDEN INN MIAMI DOLPHIN MALL
 License Type: Hotel 1695 NW 111 AVE, SWEETWATER 33172

Inspection Date: 07/03/2019 Inspection Number: 1151158 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNOLD, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913627

WESTIN TAMPA BAY

License Type: Hotel

7627 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 07/01/2019

Inspection Number: 1148840

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Warning Issued

Inspector Name: BEACHAM, MICHELLE

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Last inspected 2017

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913862

GRADY SQUARE

License Type: Apartment

2615 N GRADY AVE, TAMPA 33607

Inspection Date: 07/02/2019

Inspection Number: 1460948

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FEDERORVITCH, CASEY

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. Trouble light on - Node 01. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900493

COURTYARDS ON THE RIVER LLC

License Type: Apartment

8412 RIO BRAVO CT, TAMPA 33617

Inspection Date: 07/01/2019

Inspection Number: 1457616

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -

Inspector Name: BEAULIEU, STEPHANIE

Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	<p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 12 by units 1-4, pin missing Building 18-5, 22-5, 20-5</p> <p>- From follow-up inspection 2019-04-24: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 12 by units 1-4, pin missing Building 18-5, 22-5, 20-5</p> <p>**Time Extended** - From follow-up inspection 2019-05-30: **Time Extended** - From follow-up inspection 2019-07-01: **Admin Complaint**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-03-4	<p>- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 12- between units 5-8 Building 11- between units 5-8</p> <p>Building 33-8, 21-1, 21-5, 30-1, 29-5 - From follow-up inspection 2019-04-24: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 12- between units 5-8 Building 11- between units 5-8</p> <p>Building 33-8, 21-1, 21-5, 30-1, 29-5 **Time Extended** - From follow-up inspection 2019-05-30: **Time Extended** - From follow-up inspection 2019-07-01: **Admin Complaint**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Indian River County

License Number: 4100032

BOAT DOCK LLC

License Type: Apartment

51 ROYAL PALLM POINTE, VERO BEACH 32960

Inspection Date: 07/03/2019

Inspection Number: 1475856

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
By unit B blocked by furniture and folding chairs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700679 1944 DAWSEY ST
 License Type: Apartment 1944 DAWSEY ST, TALLAHASSEE 32303

Inspection Date: 07/02/2019 Inspection Number: 1461047 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAKEH, NADEGE Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: by unit 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4700199 OAKS APARTMENTS
 License Type: Apartment 1619 LAKE AVE, TALLAHASSEE 32310

Inspection Date: 07/01/2019 Inspection Number: 1484730 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: TAKEH, NADEGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: by units 4, 11, 18, building D.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811137 ALLURE RESORT
 License Type: Hotel 8368 JAMAICAN COURT, ORLANDO 32819-9329

Inspection Date: 07/03/2019 Inspection Number: 1150950 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809051 EMBASSY SUITES HOTELS
 License Type: Hotel 5835 T G LEE BLVD, ORLANDO 32822

Inspection Date: 07/02/2019 Inspection Number: 1149638 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811335 QUEST VILLAGE
 License Type: Apartment 12799 ROBIN CHERNEY WAY, ORLANDO 32828

Inspection Date: 07/05/2019 Inspection Number: 1487370 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILSON, LANETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808937		HOME TOWNE STUDIOS ORLANDO SOUTH	
License Type: Hotel		9435 DELEGATES DR, ORLANDO 32837	
Inspection Date: 07/03/2019	Inspection Number: 1148901	Inspection Type: Complaint Partial	Inspection Disposition: Call Back - Complied
Inspector Name: YOUNG, COLIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-07-03: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5801630		THE CADEN	
License Type: Apartment		1989 AMERICANA BLVD, ORLANDO 32839	
Inspection Date: 07/03/2019	Inspection Number: 1487339	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Top of building 140.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 5807257		RIDGE CLUB APARTMENTS	
License Type: Apartment		5839 RIDGE CLUB LOOP, ORLANDO 32839	
Inspection Date: 06/28/2019	Inspection Number: 1480566	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Room 7-205. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5902028

BAYMONT BY WYNDHAM CELEBRATION

License Type: Motel

7601 BLACK LAKE RD, CELEBRATION 34747

Inspection Date: 07/02/2019

Inspection Number: 1208205

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ observed trouble in main fire panel	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./ 6/6/19	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003850

JUPITER BEACH RESORT

License Type: Motel

5 N A1A, JUPITER 33477

Inspection Date: 07/01/2019

Inspection Number: 1208203

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

08-01-4

Observed: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.099577, 099578, 098371 all exp
6/20/2019 **Repeat Violation**
Priority: Reporting

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215820

BERKELEY BEACH CLUB LLC

License Type: Hotel

109 8 AVE, ST PETE BEACH 33706

Inspection Date: 07/01/2019

Inspection Number: 1151326

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light in alarm panel near elevator on 1st floor. Yellow flashing trouble light in control panel in fire room in rear .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Wakulla County

License Number: 7500235

PANACEA RAT LLC

License Type: Motel

1160 COASTAL HWY, PANACEA 32346

Inspection Date: 07/05/2019

Inspection Number: 1204867

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: TAKEH, NADEGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	<p>- From initial inspection : No smoke detector provided in guest room/unit. unit 105, per operator guess removed smoke detector.</p> <p>- From follow-up inspection 2019-07-05: No smoke detector provided in guest room/unit. For reporting purposes only: unit 105, per operator guess removed smoke detector. **Time Extended**</p>	<p>509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>