

Alachua County

License Number: 1100137 PRAIRIE VIEW APARTMENTS
 License Type: Apartment 6315 SW 13 ST, GAINESVILLE 32608

Inspection Date: 07/11/2019 Inspection Number: 1487430 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed lack of a smoke detector in unit 24.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1501023

EXECUTIVE GARDEN TITUSVILLE HOTEL

License Type: Motel

3480 GARDEN ST, TITUSVILLE 32796

Inspection Date: 07/08/2019

Inspection Number: 1207514

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601295 D E LEE LLC
 License Type: Apartment 1012 NW 9 AVE, HALLANDALE 33009

Inspection Date: 07/10/2019 Inspection Number: 1485795 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. metal coverings over some apartment windows preventing egress from metal covered windows.For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1601795 POMPANO BEACH RESORT APT
 License Type: Apartment 501 N OCEAN BLVD, POMPANO BEACH 33062-4606

Inspection Date: 07/11/2019 Inspection Number: 1472919 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Mounted on wall next to apt #6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612790 LA QUINTA INN #942
 License Type: Motel 999 W CYPRESS CREEK RD, FORT LAUDERDALE 33309

Inspection Date: 07/08/2019 Inspection Number: 1208207 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEWELL, SANGAY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
03-04-4	Fire sprinkler head obstructed/covered. For reporting purposes only. Sprinkler head covered with dust in laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Calhoun County

License Number: 1700094

BENCHMARK APARTMENTS

License Type: Apartment

247 E FANNIN AVE, BLOUNTSTOWN 32424

Inspection Date: 07/12/2019

Inspection Number: 1468173

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARSHALL, MICHAEL D

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330323		CSR APARTMENTS	
License Type: Apartment		14100-14140 NW 24 CRT, MIAMI 33054	
Inspection Date: 07/11/2019	Inspection Number: 1487420	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No breaking device in building 14100 by unit 202, 302	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300968		FATHER & SON	
License Type: Apartment		1135 SW 6 ST, MIAMI 331303170	
Inspection Date: 07/09/2019	Inspection Number: 1487393	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2324858		CHANTAL APARTMENTS	
License Type: Apartment		739 SW 9 ST, MIAMI 331303321	
Inspection Date: 07/09/2019	Inspection Number: 1442166	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located between units #4 and #5. - From follow-up inspection 2019-07-09: Portable fire extinguisher	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301886		GRAND FLAMINGO NORTH TOWER	
License Type: Apartment		1508 BAY RD #1, MIAMI BEACH 33139	
Inspection Date: 07/12/2019	Inspection Number: 1487435	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329373

HAMPTON INN MIAMI AIRPORT EAST

License Type: Hotel

3449 NW 42 AVE, MIAMI 33142

Inspection Date: 07/09/2019

Inspection Number: 1151023

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-07-09: Observed trouble light illuminated at fire panel at the time of inspection **T

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613266

MARBLE WATERS HOTEL & SUITES

License Type: Hotel

45 KERNAN BLVD N, JACKSONVILLE 32256

Inspection Date: 07/10/2019

Inspection Number: 1150194

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705822 SANDSTONES
 License Type: Apartment 190 N OLD CORRY FIELD RD, PENSACOLA 32507

Inspection Date: 07/08/2019 Inspection Number: 1487383 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUSSELL, SARAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Missing smoke detector on rooms on apartment 2402.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2700898 GARDEN INN & SUITES
 License Type: Motel 8500 PINE FOREST RD, PENSACOLA 32534

Inspection Date: 07/10/2019 Inspection Number: 1208261 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RUSSELL, SARAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler expires 6/23/17. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913625

A1 MOTEL

License Type: Motel

12003 N NEBRASKA AVE, TAMPA 33612

Inspection Date: 07/09/2019

Inspection Number: 1208221

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 11

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4503014

ROCK SPRINGS RUN TRAIL RIDES

License Type: Bed and Breakfast

30218 WEKIVA RIVER RD, SORRENTO 32776

Inspection Date: 07/09/2019

Inspection Number: 1093390

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Stored inside bedroom closet.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605591

HYATT PLACE FORT MYERS

License Type: Hotel

2600 CHAMPION RING RD, FORT MYERS 33905

Inspection Date: 07/11/2019

Inspection Number: 1151425

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: MOREHEAD, PHILIP

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700264

SUNSET MOTEL

License Type: Motel

9556 APALACHEE PKWY, TALLAHASSEE 32311

Inspection Date: 07/11/2019

Inspection Number: 1204967

Inspection Type: Complaint Partial

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: CHARLES, BRENDA

Violation Code

Observation

Violation Citation

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Wiring tied into one outlet running on outside of wall to supply AC Request not complied unit. Room 9. - From follow-up inspection 2019-07-1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202214

LA QUINTA INN & SUITES #988

License Type: Hotel

3530 SW 36 AVE, OCALA 34474

Inspection Date: 07/12/2019

Inspection Number: 1149742

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
02/03/19, per management, inspection was performed on April

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301449

COURTYARD BY MARRIOTT - STUART

License Type: Hotel

7615 SW LOST RIVER RD, STUART 34997

Inspection Date: 07/12/2019

Inspection Number: 1149935

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 122899 exp 3/24/2019 and 122890 exp 3/24/2019

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403186

NYAH KEY WEST

License Type: Hotel

823 FLEMING ST, KEY WEST 33040

Inspection Date: 07/12/2019

Inspection Number: 1150238

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.Room 121. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801023

WYNDHAM RESORT ORLANDO I-DRIVE

License Type: Motel

8001 INTERNATIONAL DRIVE, ORLANDO 32819

Inspection Date: 07/11/2019

Inspection Number: 1208276

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811102

THE FLATS II

License Type: Apartment

12001 AVALON LAKE DR, ORLANDO 32828

Inspection Date: 07/08/2019

Inspection Number: 1475952

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5901189

CHAMPIONS WORLD RESORT

License Type: Motel

8660 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 07/11/2019

Inspection Number: 1207795

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ system trouble .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6207416

RED ROOF INN

License Type: Motel

4999 34 ST N, ST. PETERSBURG 33714

Inspection Date: 07/12/2019

Inspection Number: 1207579

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Yellow 'system trouble' light illuminated
Sensor located , laundry area

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214076

EXTENDED STAY HOTELS

License Type: Motel

2311 ULMERTON RD, CLEARWATER 33762

Inspection Date: 07/12/2019

Inspection Number: 1204530

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both expired 1/20/18 - From follow-up inspection 2019-07-12: Both expired 1/20/18 **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215669

BAYSIDE INN

License Type: Hotel

9359 US HWY 19 N, PINELLAS PARK 33782

Inspection Date: 07/08/2019

Inspection Number: 1151423

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near room 409 in recharge zone, unit 312 missing fire extinguisher. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. *Fire extinguisher near room 112 in recharge zone. *Fire extinguisher near room 409 in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing near unit 312. - From follow-up inspection 2019-06-24:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-02-4	- From initial inspection : Frayed electrical wire(s). For reporting purposes only. *Frayed wire near unit 118 in hallway on column poolside. * wires exposed in light fixture of bathroom in unit 119. - From follow-up inspection 2019-06-24: **Time	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-02-4	Frayed electrical wire(s). For reporting purposes only. Frayed wire near unit 118. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6902382

CASCADE HEIGHTS

License Type: Apartment

160 ISLANDER CT, LONGWOOD 32750

Inspection Date: 07/11/2019

Inspection Number: 1461053

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Per operator boilers inspected March 2019.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401678

HERITAGE INN

License Type: Motel

1100 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 07/09/2019

Inspection Number: 1207953

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.
Smoke detector not attached to ceiling in room 11. Do not rent room 11 until a fully
functioning smoke detector is installed.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403461

ANATOLE APARTMENTS

License Type: Apartment

1690 DUNN AVE, DAYTONA BEACH 32114

Inspection Date: 07/10/2019

Inspection Number: 1480394

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting
purposes only.
Office - trouble light.
Building 3 system trouble beeping .
Building 9-system trouble,power trouble.
Building 6- trouble light
Building 10- beeping

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406075

CHARLES RICHEY

License Type: Apartment

733 739 & 745 BELLEVUE AVE, DAYTONA BEACH 32114

Inspection Date: 07/11/2019

Inspection Number: 1487411

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present
indicating designated location). For reporting purposes only. Building 745 by
apartment 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403718

HOLIDAY INN EXPRESS AND SUITES

License Type: Motel

3301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 07/11/2019

Inspection Number: 1206988

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting
purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.