

Alachua County

License Number: 1100022

MICANOPY INN

License Type: Motel

17110 SE CR 234, MICANOPY 32667

Inspection Date: 07/22/2019

Inspection Number: 1205012

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Breaker bar is missing from the fire extinguisher box near room 217.
- From follow-up inspection 2019-06-21: No change **Time Extended**
- From follow-up inspection 2019-07-22: Three missing breaker bars on the east side upstairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1501023

EXECUTIVE GARDEN TITUSVILLE HOTEL

License Type: Motel

3480 GARDEN ST, TITUSVILLE 32796

Inspection Date: 07/23/2019

Inspection Number: 1207514

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-07-23: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621490

NAJIBE GARDENS

License Type: Apartment

2575 SW 64 AVE, MIRAMAR 33023

Inspection Date: 07/22/2019

Inspection Number: 1458960

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Call Back -
Complied

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing on each floor. - From follow-up inspection 2019-07-22: Owner stated extinguishers will be put in next week. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1901163

MARINA DEL RAY APARTMENTS

License Type: Apartment

265 FATHOM LOOP, BEVERLY HILLS 34465

Inspection Date: 07/26/2019

Inspection Number: 1474877

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DODGE, DAVID

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Chamber building (145-150) & (245-250).

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328266

EXTENDED STAY AMERICA #1600

License Type: Hotel

8655 NW 21 TERRACE, MIAMI 33122

Inspection Date: 07/24/2019

Inspection Number: 1148645

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

- From follow-up inspection 2019-07-24: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317827

HILTON MIAMI AIRPORT

License Type: Hotel

5101 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 07/24/2019

Inspection Number: 1150653

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 04/05/19

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329238

HOTEL ARIA

License Type: Hotel

2889 MCFARLANE RD, COCONUT GROVE 33133

Inspection Date: 07/26/2019

Inspection Number: 1151261

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329417

MR C

License Type: Hotel

2988 MCFARLANE RD, MIAMI 33133

Inspection Date: 07/22/2019

Inspection Number: 1151275

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.
For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 2325923

HAMPTON INN HOTEL

License Type: Hotel

2800 SW 28 TERR, MIAMI 33133713

Inspection Date: 07/25/2019

Inspection Number: 1149480

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For
reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 2327202

GABLES GRAND PLAZA

License Type: Apartment

353 ARAGON AVE, CORAL GABLES 33134

Inspection Date: 07/22/2019

Inspection Number: 1485328

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GANDOLFF, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For
reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Dade County

License Number: 2301886

GRAND FLAMINGO NORTH TOWER

License Type: Apartment

1508 BAY RD #1, MIAMI BEACH 33139

Inspection Date: 07/26/2019

Inspection Number: 1460989

Inspection Type: Complaint Partial

Inspection Disposition: Call Back -
Complied

Inspector Name: DE LA CRUZ, ADONIS

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. On the north building
 - From follow-up inspection 2019-06-26: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. On the north building **Time Extended**
 - From follow-up inspection 2019-07-26: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. On the north building
 - From follow-up inspection 2019-06-26: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. On the north building **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325175

HOTEL OCEAN

License Type: Hotel

1236 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 07/23/2019

Inspection Number: 1149795

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328417

JAMES ROYAL PALM (THE)

License Type: Hotel

1545 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 07/26/2019

Inspection Number: 1150070

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328452

COURTYARD BY MARRIOTT

License Type: Hotel

1530 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 07/25/2019

Inspection Number: 1149382

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329247

GALE SOUTH BEACH/ REGENT HOTEL

License Type: Hotel

1690 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 07/22/2019

Inspection Number: 1150216

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329307

AC HOTEL MIAMI BEACH

License Type: Hotel

2912 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 07/22/2019

Inspection Number: 1150459

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329047

THE MIMOSA

License Type: Hotel

6525 COLLINS AVENUE, MIAMI BEACH 33141

Inspection Date: 07/24/2019

Inspection Number: 1149700

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JOSEPH, VANRIE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603661

TRAVELODGE INN & SUITES

License Type: Motel

1153 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 07/24/2019

Inspection Number: 1208395

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher near room 304

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705820

SUBURBAN EXTENDED STAY HOTEL

License Type: Hotel

3984 BARRANCAS AVE, PENSACOLA 32507

Inspection Date: 07/23/2019

Inspection Number: 1151581

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: RUSSELL, SARAH

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3904020

LA QUINTA INN #597

License Type: Motel

4730 SPRUCE ST, TAMPA 33607

Inspection Date: 07/24/2019

Inspection Number: 1206694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. No specifics observed on panel, trouble light on. Operator stated panel was serviced a week ago. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700095

ROLLING HILLS APARTMENTS

License Type: Apartment

280 JOHN KNOX RD, TALLAHASSEE 32303

Inspection Date: 07/23/2019

Inspection Number: 1487488

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only: by unit 128. - From follow-up inspection 2019-07-23: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only: by unit 128. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400573

AMARA CAY RESORT

License Type: Hotel

80001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 07/23/2019

Inspection Number: 1150341

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-06-4

Smoke detector in lint room emitting an audible alarm , covered in dust. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403065

FAIRFIELD INN & SUITES

License Type: Motel

3852 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 07/24/2019

Inspection Number: 1207712

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603600

EMERALD GRANDE

License Type: Hotel

10 HARBOR BLVD, DESTIN 32541

Inspection Date: 07/25/2019

Inspection Number: 1151599

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Three boilers in place / no certificates posted	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801025 MARVIN GARDENS APTS
 License Type: Apartment 3106 FAIRWAY LN, ORLANDO 328043755

Inspection Date: 07/22/2019 Inspection Number: 1472105 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: QUINONES, ANTONIO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
12-04-4	High Priority - Balcony collapsing due to rotten support structure beam at rear side of the building. **Warning**	61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

License Number: 5801461 I-DRIVE GRAND RESORT & SUITES
 License Type: Motel 7050 S KIRKMAN RD, ORLANDO 32819

Inspection Date: 07/23/2019 Inspection Number: 1208392 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, COLIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Inspector Ken Noble was out, 352a□□369-2872	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809335 PORTO FINO BAY HOTEL
 License Type: Hotel 5601 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 07/22/2019 Inspection Number: 1151542 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: YOUNG, COLIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810332 FAIRFIELD INN & SUITES ORLANDO
 License Type: Hotel 5614 VINELAND RD, ORLANDO 32819

Inspection Date: 07/22/2019 Inspection Number: 1150598 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available/expired. Broiler ID FL134712, expired on 06/14/19. Boiler ID FL120649-No certificate available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810427

COMFORT SUITES

License Type: Hotel

5617 MAJOR BLVD, ORLANDO 32819

Inspection Date: 07/23/2019

Inspection Number: 1149619

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

08-06-4

Combustibles stored in gas water heater room. For reporting purposes only.

Observed old equipment stored in gas water heater room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811108

RESIDENCE INN ORLANDO AIRPORT

License Type: Hotel

7024 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 07/25/2019

Inspection Number: 1149881

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Room 600. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801555

SCOT ARMS APARTMENT

License Type: Apartment

11600 MENDEL DR, ORLANDO 32826

Inspection Date: 03/15/2019

Inspection Number: 1487581

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

01-02-4

Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At the laundry room
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913656

LAKE CECILE RESORT INN & SUITES

License Type: Motel

4900 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 07/24/2019

Inspection Number: 1202583

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-07-24: Boiler were inspected operator is waiting for the certificate **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900204

RAMADA PLAZA HOTEL & INN GATEWAY

License Type: Motel

7470 HWY 192 W, KISSIMMEE 34747

Inspection Date: 07/23/2019

Inspection Number: 1208380

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ trouble silence .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5901202

QUALITY INN MAINGATE

License Type: Motel

2945 ENTRY POINT BLVD, KISSIMMEE 34747

Inspection Date: 07/26/2019

Inspection Number: 1207489

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ system trouble at main fire panel

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204014

BILMAR BEACH RESORT

License Type: Motel

10650 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 07/23/2019

Inspection Number: 1207657

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired boiler certificates hung in boiler room. Boilers inspected 7/2/2019 new certificates to be mailed.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211956

KENWOOD INN

License Type: Motel

451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 07/24/2019

Inspection Number: 1208348

Inspection Type: Complaint Full

Inspection Disposition: Call Back -

Inspector Name: RANVILLE, AMANDA

Admin. complaint recommended

Violation CodeObservationViolation Citation

04-02-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Room 204, 234 - From follow-up inspection 2019-07-24: **Time Extended**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 204, 234	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. Hanging from previous smoke detector location	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	- From initial inspection : Damaged electrical wire(s). For reporting purposes only. Hanging from previous smoke detector location - From follow-up inspection 2019-07-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-03-4	- From initial inspection : Scorch marks around an electrical outlet. For reporting purposes only. Room 204, complainant states it caught fire. - From follow-up inspection 2019-07-24: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-03-4	Scorch marks around an electrical outlet. For reporting purposes only. Room 204, complainant states it caught fire.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205501

PARADISE TOWERS

License Type: Apartment

11000 62 AVE N, SEMINOLE 33772

Inspection Date: 07/22/2019

Inspection Number: 1460149

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: LANTIGUA, ROBERTO

Violation Code

Observation

Violation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. In 2nd story laundry rooms Building A & B, missing tool to break panel.

Building A, by unit 202 has duct tape to hold up pull here panel for fire extinguisher. - From follow-up inspection 2019-07-22: Portable fire extinguisher in 2nd story laundry room of Building B missing breaker bar. ****Admin Complaint****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406605

COCONUT PALMS APARTMENTS

License Type: Apartment

716 N HALIFAX AVE, DAYTONA BEACH 32118

Inspection Date: 07/23/2019

Inspection Number: 1484689

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

02-08-4

Motorcycle parked under balcony /south east corner of building .
stored under a stairwell. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For
reporting purposes only.
3 lights on red, yellow and green flashing.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401324

HOLIDAY INN SUITES

License Type: Motel

930 N ATLANTIC AVE, DAYTONA BCH 321183718

Inspection Date: 07/26/2019

Inspection Number: 1205918

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For
reporting purposes only. Engineer states tech will be here today

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.