

Bay County

License Number: 1300032

PLAZA MOTEL

License Type: Motel

12830 W FRONT BEACH RD, PANAMA CITY BCH 324073312

Inspection Date: 08/05/2019

Inspection Number: 1206319

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YANDELL, TIMOTHY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620896

HOTEL MORRISON

License Type: Hotel

28 S FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 08/05/2019

Inspection Number: 1150980

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

02-07-4

Flammable chemicals stored near a source of ignition. Gas can removed from boiler room. For reporting purposes only. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1607221

FORT LAUDERDALE GRAND HOTEL

License Type: Hotel

4900 POWERLINE ROAD, OAKLAND PARK 33309

Inspection Date: 08/08/2019

Inspection Number: 1151716

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERSAUD, SHAWN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1901178

THE COURTYARD APARTMENTS

License Type: Apartment

773 NE 9 ST, CRYSTAL RIVER 34428

Inspection Date: 08/02/2019

Inspection Number: 1483492

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Blocked by plant by unit F **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1900654

KNOLLWOOD TOWNHOUSES

License Type: Apartment

1719 DRUID RD, INVERNESS 34452

Inspection Date: 08/03/2019

Inspection Number: 1468038

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher by laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329362

THE JEFFERSON HOTEL

License Type: Hotel

528 SW 9 AVE, MIAMI 33130

Inspection Date: 08/05/2019

Inspection Number: 1151170

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only. Boiler room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307353

GABLES COVE

License Type: Motel

4700 SW 8 ST, CORAL GABLES 33134

Inspection Date: 08/05/2019

Inspection Number: 1208147

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305469		SHELBORNE SOUTH BEACH	
License Type: Hotel		1801 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 08/06/2019	Inspection Number: 1150379	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler - Fired Pressured Vessel Report from State Fire Marshall issued on 5/3/2019 for the new Boiler Certificates. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2325734		FDR LOUNGE/ DELANO	
License Type: Hotel		1685 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 08/09/2019	Inspection Number: 1150143	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Inspection done, waiting for the certificates. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329280		THE MERCURY HOTEL	
License Type: Hotel		100 COLLINS AVENUE, MIAMI BEACH 33139	
Inspection Date: 07/30/2019	Inspection Number: 1146360	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-07-30: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2300796

SEACOAST SUITE

License Type: Apartment

5101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/05/2019

Inspection Number: 1487644

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328318

BEST WESTERN

License Type: Hotel

4101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/05/2019

Inspection Number: 1151713

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Technician working on alarm system at time of inspection.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329221

SOHO HOUSE

License Type: Hotel

4385 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/08/2019

Inspection Number: 1150053

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306103

SEA VIEW HOTEL (THE)

License Type: Hotel

9909 COLLINS AVE, MIAMI BEACH 331541808

Inspection Date: 08/06/2019

Inspection Number: 1149476

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JOSEPH, VANRIE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312612

CARIB VILLAS APARTMENTS

License Type: Apartment

11101 SW 200 ST, MIAMI 33157

Inspection Date: 08/08/2019

Inspection Number: 1487677

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to unit 4106.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed next to unit 4112.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613257

HILTON GARDEN INN JACKSONVILLE DOWNTOWN SOUTHBANK

License Type: Hotel

1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 08/07/2019

Inspection Number: 1151061

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702162

RED ROOF INN #10083

License Type: Motel

7340 PLANTATION RD, PENSACOLA 32504

Inspection Date: 08/08/2019

Inspection Number: 1207607

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HALL, DAVID

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired 6/22/19 **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
On both boilers
Expired 6/22/19 - From follow-up inspection 2019-08-08: Boiler inspection expired
Inspector scheduled to come

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900914

LA SALLE PALMS

License Type: Apartment

1515 LA SALLE ST, TAMPA 33607

Inspection Date: 08/02/2019

Inspection Number: 1477569

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. Every fire extinguisher on property observed "EMPTY" at time of inspection. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

Damaged and exposed electrical wire(s). Exterior light fixture near back entrance of unit 1515 1/2. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701568

LA CASA INN & SUITES

License Type: Motel

2801 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 08/06/2019

Inspection Number: 1208328

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: side of 128, by 138, - From follow-up inspection 2019-08-06: Portable fire extinguisher pressure gau

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500014 PINE FOREST MOTEL
 License Type: Motel 850928 US HWY 17 N, YULEE 32097

Inspection Date: 08/06/2019 Inspection Number: 1208521 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 3	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500079 NASSAU HOLIDAY MOTEL
 License Type: Motel 850857 HWY 17, YULEE 32097

Inspection Date: 08/05/2019 Inspection Number: 1208518 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ESPINOSA-BECKERT, ILIANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. In gas water heater room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 125, mgr brought one to put in **Corrective Action Taken**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603333

BAYMONT INN & SUITES - CRESTVIEW

License Type: Motel

4040 S FERDON BLVD, CRESTVIEW 32536

Inspection Date: 08/05/2019

Inspection Number: 1206154

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

- light missing from fitness center bathroom showing exposed wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811195

UNIVERSITY HOUSE CENTRAL FLORIDA, L.L.C.

License Type: Apartment

3200 N ALAFAYA TRL, ORLANDO 32826

Inspection Date: 08/06/2019

Inspection Number: 1479023

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher at stair 1 level 2 garage in a box. At level 3 bldg 1 garage in a box, level 4 bldg 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit is at the front door of the office panel reads 0001 tamper active
Tamper 3&4 fire pump
Rm garage

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810870

THE RITZ-CARLTON ORLANDO GRANDE LAKES

License Type: Hotel

4012 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 08/07/2019

Inspection Number: 1151730

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913656

LAKE CECILE RESORT INN & SUITES

License Type: Motel

4900 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/06/2019

Inspection Number: 1208016

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5913653

COZY COVE INN

License Type: Motel

5790 ALLIGATOR LAKESHORE W, ST. CLOUD 34771

Inspection Date: 08/05/2019

Inspection Number: 1208520

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. All outlets missing electrical outlet covers-room #5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012655

FAIRFIELD INN & SUITES JUPITER

License Type: Hotel

6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 08/05/2019

Inspection Number: 1150480

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021, 121022, 095111 all exp on 03/15/2019.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014058

WYNDHAM GRAND JUPITER AT HARBOURSIDE PLACE

License Type: Hotel

122 SOUNDINGS AVE, JUPITER 33477

Inspection Date: 08/09/2019

Inspection Number: 1151233

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Chief engineer office/main panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201933

MIDSHIP APARTMENTS

License Type: Apartment

5255 62 ST N, KENNETH CITY 33709

Inspection Date: 08/09/2019

Inspection Number: 1484697

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
- bldg 5255, hallway outside unit 215

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211956

KENWOOD INN

License Type: Motel

451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 08/06/2019

Inspection Number: 1208348

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: RANVILLE, AMANDA

Violation CodeObservationViolation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Room 204, 234 - From follow-up inspection 2019-07-24: **Time Extended** - From follow-up inspection 2019-08-06: No smoke detector in room 24

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

- From initial inspection : Damaged electrical wire(s). For reporting purposes only. Hanging from previous smoke detector location - From follow-up inspection 2019-07-24: **Time Extended** - From follow-up inspection 2019-08-06: **Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-03-4

- From initial inspection : Scorch marks around an electrical outlet. For reporting purposes only. Room 204, complainant states it caught fire. - From follow-up inspection 2019-07-24: **Time Extended** - From follow-up inspection 2019-08-06: Roo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211508

BELCHER PARK APTS

License Type: Apartment

7800 BELCHER RD, PINELLAS PARK 337811964

Inspection Date: 08/09/2019

Inspection Number: 1472654

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. In first floor of bldg A, missing a breaker bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400243

RK PALMETTO LLC

License Type: Apartment

623 S PALMETTO AVE, DAYTONA BEACH 32114

Inspection Date: 08/08/2019

Inspection Number: 1487670

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.
For reporting purposes only.
1st and 2nd floor heard smoke detectors chirping(possible low battery). Unable to
determine which rooms.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Hallway
partially blocked dresser by room 3.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 7401445

SUN PLAZA MOTEL

License Type: Motel

1011 S RIDGEWOOD AVE, DAYTONA BCH 321146107

Inspection Date: 08/08/2019

Inspection Number: 1206474

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting
purposes only.
Smoke detector flashing. Sound is very faint.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 7406504

HILTON GARDEN INN DAYTONA BEACH OCEANFRONT

License Type: Hotel

2560 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/05/2019

Inspection Number: 1150802

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

06-05-4

Door marked as an exit locked with a lock that would require special
knowledge/tool to unlock. For reporting purposes only.
Exit door stairway on the 5th floor south stairway handle does not open the door
currently from inside of the stairway.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Volusia County

License Number: 7400051

DAYS INN SPEEDWAY

License Type: Motel

2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 08/05/2019

Inspection Number: 1208519

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 131934. Manager states boiler inspector was out and stated that the boiler has not being properly disconnected.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Wakulla County

License Number: 7500234

PANACEA MOTEL

License Type: Motel

1545 COASTAL HWY, PANACEA 32346

Inspection Date: 08/08/2019

Inspection Number: 1207268

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.