

Alachua County

License Number: 1100086

TOWERS (THE)

License Type: Apartment

207 NW 17 ST, GAINESVILLE 326031856

Inspection Date: 08/20/2019

Inspection Number: 1440546

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Box in laundry room and box on second floor missing breaker bar. - From follow-up inspection 2019-08-20: Fire extinguisher box in laundry missing breaker bar. Fire extinguisher box on second floor by elevator missing breaker bar.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620697

HILTON GARDEN INN FT LAUDERDALE

License Type: Hotel

180 SW 18 AVE, DANIA 33004

Inspection Date: 08/19/2019

Inspection Number: 1151837

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620867

CAMBRIA SUITES FT LAUDERDALE

License Type: Hotel

141 SW 19 CT, DANIA 33004

Inspection Date: 08/21/2019

Inspection Number: 1150014

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620242

THE DIPLOMAT RESORT & SPA

License Type: Hotel

3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 08/22/2019

Inspection Number: 1151896

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. in hotel office. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. Boiler certificates expiring today. Engineer has new inspection reports. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620887

MARGARITAVILLE BEACH RESORT

License Type: Hotel

1111 N OCEAN DR, HOLLYWOOD 33019

Inspection Date: 08/20/2019

Inspection Number: 1151099

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102299

BEST WESTERN HOTEL & SUITES

License Type: Motel

6400 DUDLEY DR, NAPLES 34105

Inspection Date: 08/20/2019

Inspection Number: 1206004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARIANI, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired on 6/2/19

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301202 BEACHFRONT HOLDINGS GROUP INC
 License Type: Apartment 120 NW 7 AVE, MIAMI 33130

Inspection Date: 08/21/2019 Inspection Number: 1487768 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. By Garbage and AC unit hallway next to apartment. 6 **Warning**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-01-4	- From initial inspection : Path to door marked as an exit is blocked. For reporting purposes only. By Garbage and AC unit hallway next to apartment. 6 **Warning** - From follow-up inspection 2019-08-22: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2327907 STARLITE MOTEL
 License Type: Motel 135 SW 8 ST, MIAMI 33130

Inspection Date: 08/20/2019 Inspection Number: 1207402 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Red light	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328937 THE RITZ CARLTON HOTEL COCONUT GROVE
 License Type: Hotel 3300 SW 27TH AVE, COCONUT GROVE 33133

Inspection Date: 08/21/2019 Inspection Number: 1151069 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 094551 expires 0515/19	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318723 MAYFAIR HOTEL & SPA
 License Type: Hotel 3000 FLORIDA AVE, MIAMI 33133

Inspection Date: 08/22/2019 Inspection Number: 1151322 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 016684 EXPIRE 08/15/19	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305321 THE BETSY SOUTH BEACH
 License Type: Hotel 1440 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 08/22/2019 Inspection Number: 1149725 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boilers in boiler room.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328890 OCEAN SPRAY HOTEL
 License Type: Hotel 4130 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 08/21/2019 Inspection Number: 1150514 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329275

HOTEL PIERRE

License Type: Hotel

216 43 STREET, MIAMI BEACH 33140

Inspection Date: 08/19/2019

Inspection Number: 1150304

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329309

FOUR POINT BY SHERATON

License Type: Hotel

3861 BIRD RD, MIAMI 33146

Inspection Date: 08/20/2019

Inspection Number: 1150793

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702162

RED ROOF INN #10083

License Type: Motel

7340 PLANTATION RD, PENSACOLA 32504

Inspection Date: 08/22/2019

Inspection Number: 1208662

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HALL, DAVID

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler repairs have been made waiting on inspection from fire marshal.
Corrective Action Taken **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905879

WESTIN HARBOUR ISLAND

License Type: Hotel

725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 08/21/2019

Inspection Number: 1150586

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3902852

GODFREY HOTELS & CABANAS

License Type: Hotel

7700 COURTNEY CAMPBELL CSWY, TAMPA 33607

Inspection Date: 08/21/2019

Inspection Number: 1150753

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. 745,000 BTU/Hour observed on data plate. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701568

LA CASA INN & SUITES

License Type: Motel

2801 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 08/22/2019

Inspection Number: 1208328

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: side of 128, by 138, - From follow-up inspection 2019-08-06: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: side of 128, by 138, **Time Extended** - From follow-up inspection 2019-08-22: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: side of 128, by 138. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5102347

QUALITY INN

License Type: Motel

6727 14 ST W, BRADENTON 34207

Inspection Date: 08/19/2019

Inspection Number: 1208480

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KNOX, KHALENA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804950		TRAVELODGE	
License Type: Motel		1850 W LANDSTREET RD, ORLANDO 32809	
Inspection Date: 08/23/2019	Inspection Number: 1208703	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GUTTERMAN, KENNETH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. In handicapped room # 305	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809646		EXTENDED STAY AMERICA #1632	
License Type: Hotel		1776 PEMBROOK DR, ORLANDO 32810	
Inspection Date: 08/21/2019	Inspection Number: 1150932	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only./room 217.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5801023		WYNDHAM RESORT ORLANDO I-DRIVE	
License Type: Motel		8001 INTERNATIONAL DRIVE, ORLANDO 32819	
Inspection Date: 08/20/2019	Inspection Number: 1208655	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Orange County

License Number: 5801461

I-DRIVE GRAND RESORT & SUITES

License Type: Motel

7050 S KIRKMAN RD, ORLANDO 32819

Inspection Date: 08/21/2019

Inspection Number: 1208548

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

07-03-4

- From initial inspection : Electrical cover is missing at room 106.Lampshade area.For reporting purposes only. - From follow-up inspection 2019-08-16:
Time Extended - From follow-up inspection 2019-08-21: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2019-08-16:
Time Extended - From follow-up inspection 2019-08-21: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803815

EMBASSY SUITES ORLANDO INTERNATIONAL DRIVE/JAMAICAN COURT

License Type: Hotel

8250 JAMAICAN CT, ORLANDO 32819

Inspection Date: 08/19/2019

Inspection Number: 1150462

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803843

METROPOLITAN RESORT

License Type: Hotel

8444 INTERNATIONAL DR, ORLANDO 32819-9329

Inspection Date: 08/22/2019

Inspection Number: 1151048

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.FI 134289 5/30/19.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5803620

HOLIDAY INN ORLANDO AIRPORT

License Type: Hotel

5750 T G LEE BLVD, ORLANDO 32822

Inspection Date: 08/22/2019

Inspection Number: 1150745

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel, 5 troubles . For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. All three Boilers were expired 11-29-18. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913656

LAKE CECILE RESORT INN & SUITES

License Type: Motel

4900 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/21/2019

Inspection Number: 1208016

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2019-08-21: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900606

KNIGHTS INN MAINGATE

License Type: Motel

7475 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 08/22/2019

Inspection Number: 1206416

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only./ unplugged room 308 ****Corrected On-Site****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204365

PAGE TERRACE

License Type: Motel

10500 GULF BLVD, TREASURE ISLAND 337064817

Inspection Date: 08/20/2019

Inspection Number: 1208664

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6202516

BAY POINTE TOWER APARTMENTS

License Type: Apartment

880 OLEANDER WAY S, SOUTH PASADENA 33707

Inspection Date: 08/19/2019

Inspection Number: 1487733

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired boiler certificate 5/9/2019

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired boiler certificate 5/9/2019 - From follow-up inspection 2019-08-20: Employee contacted Boiler inspector **Time Extended** **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211956

KENWOOD INN

License Type: Motel

451 34 ST N, ST. PETERSBURG 33713

Inspection Date: 08/20/2019

Inspection Number: 1208348

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: RANVILLE, AMANDA

Violation CodeObservationViolation Citation

07-03-4

- From initial inspection : Scorch marks around an electrical outlet. For reporting purposes only. Room 204, complainant states it caught fire. - From follow-up inspection 2019-07-24: **Time Extended** - From follow-up inspection 2019-08-06: Room 214 scorch mark on electrical outlet **Time Extended** - From follow-up inspection 2019-08-20: Scorch mark at outlet. 204. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215769

BLUE WAVE MOTEL

License Type: Motel

440 E SHORE DR, CLEARWATER 33767

Inspection Date: 08/23/2019

Inspection Number: 1206703

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm states phone line.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300459

PARAMOUNT LAKESIDE INN & SUITES

License Type: Motel

910 E MEMORIAL BLVD, LAKELAND 33801

Inspection Date: 08/19/2019

Inspection Number: 1208648

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GARCIA, GUADALUPE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by unit 2324. Employee replaced fire extinguisher. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed 3 doors down from maintenance. Employee replaced fire extinguisher. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903811

LEGENDS WINTER SPRINGS

License Type: Apartment

440 COURTNEY SPRINGS CIR, WINTER SPRINGS 32708

Inspection Date: 08/23/2019

Inspection Number: 1475642

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unit reads trouble, alarm bldg 9

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6900381

EXTENDED STAY OF ALTAMONTE SPRINGS

License Type: Motel

230 W SR 436, ALTAMONTE SPRINGS 32714

Inspection Date: 08/22/2019

Inspection Number: 1208165

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600732

COURTYARD MARRIOTT

License Type: Hotel

10978 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 08/19/2019

Inspection Number: 1150861

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401645		PALM COVE APARTMENTS	
License Type: Apartment		886 S NOVA RD, DAYTONA BEACH 32114	
Inspection Date: 08/23/2019	Inspection Number: 1487790	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored on landing by apartment b6. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400194		SAHARA MOTEL	
License Type: Motel		1215 N ATLANTIC AVE, DAYTONA BCH 321183630	
Inspection Date: 08/22/2019	Inspection Number: 1206434	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	2 Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Smoke detector made sound but did not flash.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400051		DAYS INN SPEEDWAY	
License Type: Motel		2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124	
Inspection Date: 08/19/2019	Inspection Number: 1208519	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-08-19:	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 131934. Manager states boiler inspector was out and stated that the boiler has not been properly disconnected. - From follow-up inspection 2019-08-19: Boiler appears to be capped. Viewed letter stating boiler has been disconnected but does not say which boiler.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	