

Brevard County

License Number: 1501583

DAYS INN TITUSVILLE KENNEDY SPACE CENTER

License Type: Motel

3755 CHENEY HWY, TITUSVILLE 32780

Inspection Date: 09/06/2019

Inspection Number: 1207405

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1610916 MOTEL 6 #376
 License Type: Motel 825 E DANIA BEACH BLVD, DANIA BEACH 33004

Inspection Date: 09/04/2019 Inspection Number: 1207223 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 08-03-4 | No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-04-4 | Boiler certificate not posted in the boiler room. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 1620865 HYATT PLACE FT LAUDERDALE AIRPORT & CRUISE PORT
 License Type: Hotel 91 SW 18 AVE, DANIA BEACH 33004

Inspection Date: 09/04/2019 Inspection Number: 1151253 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 08-03-4 | No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-04-4 | Boiler certificate not posted in the boiler room. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Broward County

| | | | |
|------------------------------------|---|---|--|
| License Number: 1604595 | | LUCKY BOY MOTEL | |
| License Type: Motel | | 610 S FEDERAL HWY, HOLLYWOOD 33020-5422 | |
| Inspection Date: 09/06/2019 | Inspection Number: 1207208 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: CHAPDELAINE, MARIE | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 06-05-4 | Door marked as an exit locked with a lock that would require special knowledge/tool to unlock. For reporting purposes only. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 1612520 | | SHERATON SUITES FORT LAUDERDALE AT CYPRESS CREEK | |
| License Type: Hotel | | 555 NW 62 ST, FORT LAUDERDALE 33309 | |
| Inspection Date: 09/05/2019 | Inspection Number: 1151324 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: GRAY, ANTHONY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 08-01-4 | Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - Observed informations on Boiler certificate not correctly justified. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 1612832 | | LA QUINTA INN & SUITES | |
| License Type: Hotel | | 5070 N SR 7, TAMARAC 33319 | |
| Inspection Date: 09/04/2019 | Inspection Number: 1149802 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: SEWELL, SANGAY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 01-01-4 | Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next room 400 | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 1620275 | | COURTYARD BY MARRIOTT WESTON | |
| License Type: Hotel | | 2000 N COMMERCE PKWY, WESTON 33326 | |
| Inspection Date: 09/05/2019 | Inspection Number: 1149831 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PERSAUD, SHAWN | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 02-07-4 | Flammable chemicals stored near a source of ignition. For reporting purposes only. Chemicals removed from being stored in mechanical room. **Corrected On-Site** **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Broward County

License Number: 1620897

WOODSPRING SUITES DEERFIELD BEACH LLC

License Type: Hotel

1400 SW 11 WAY, DEERFIELD BEACH 33441

Inspection Date: 09/06/2019

Inspection Number: 1150847

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PINEROS, MICHELE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to Room 431. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2321514 HOLIDAY INN EXPRESS & SUITES - MIAMI/HIALEAH
 License Type: Hotel 6650 W 20 AVE, HIALEAH 33016

Inspection Date: 09/03/2019 Inspection Number: 1150611 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 01-02-4 | Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In hall way on the way to boiler room. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed alarm supervisory and alarm silenced lights on. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-01-4 | Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boilers FL093792, FL088026 both expire on 08-11-19. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2329247 GALE SOUTH BEACH/ REGENT HOTEL
 License Type: Hotel 1690 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/03/2019 Inspection Number: 1150216 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: PRIETO, VICENTE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 08-03-4 | - From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2019-09-03: **Time Extended** | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2329297 MIAMI BEACH EDITION HOTEL
 License Type: Hotel 2901 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 09/03/2019 Inspection Number: 1150321 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SUAREZ, LEOPOLDO

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Dade County

License Number: 2319933 EMBASSY SUITES HOTEL MIAMI AIRPORT
 License Type: Hotel 3974 NW SOUTH RIVER DR, MIAMI 33142

Inspection Date: 09/05/2019 Inspection Number: 1150412 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located on first floor located behind front desk. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2315280 JW MARRIOTT MIAMI TURNBERRY RESORT & SPA
 License Type: Hotel 19999 W COUNTRY CLUB DR, AVENTURA 33180

Inspection Date: 09/05/2019 Inspection Number: 1150085 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2307837 CENTER COURT
 License Type: Apartment 14795 NE 18 AVE, NORTH MIAMI 33181

Inspection Date: 09/05/2019 Inspection Number: 1487824 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 01-06-4 | Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device on fire extinguisher located on 1 and 2nd floors building 1 and most of them throughout the property. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Duval County

License Number: 2612227

LA QUINTA INN #969

License Type: Hotel

4686 LENOIR AVE S, JACKSONVILLE 32216

Inspection Date: 09/05/2019

Inspection Number: 1149741

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
 Person in charge placed boiler certificate inside boiler room. **Corrected On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700051

RIDGE MANOR MOTEL

License Type: Motel

5205 TRELMAN BLVD, RIDGE MANOR 33523

Inspection Date: 09/04/2019

Inspection Number: 1207137

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GALICIA, ARIEL

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913611

TAMPA STADIUM HOTEL

License Type: Hotel

4750 N DALE MABRY HWY, TAMPA 33614

Inspection Date: 09/04/2019

Inspection Number: 1151946

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: AIELLO, ROCCI

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire unit says, Check 974 Dialer 1 - From follow-up inspection 2019-09-04: Not done yet **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401721

HYATT KEY WEST

License Type: Hotel

601 FRONT ST, KEY WEST 330406676

Inspection Date: 09/04/2019

Inspection Number: 1149604

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MECK, PAMELA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5802176

ARROW MOTEL

License Type: Motel

5425 S ORANGE BLOSSOM TRL, ORLANDO 328392797

Inspection Date: 09/06/2019

Inspection Number: 1208847

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: DIOP, DONALD

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Windows are nailed in in room 141.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014067 HYATT PLACE BOCA RATON
 License Type: Hotel 100 E PALMETTO PARK RD, BOCA RATON 33432

Inspection Date: 09/05/2019 Inspection Number: 1150706 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TORRES, LARRY

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 01-02-4 | Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near emergency stair #3 on 10th floor. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 06-01-4 | Path to door marked as an exit is blocked. For reporting purposes only. Chaiand high chairs obstructing path on emergency stair #4 on 1st floor | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6012655 FAIRFIELD INN & SUITES JUPITER
 License Type: Hotel 6748 INDIANTOWN RD, JUPITER 33458

Inspection Date: 09/05/2019 Inspection Number: 1150480 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: ROTONDI, VICTOR

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 08-01-4 | - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.121021, 121022, 095111 all exp on 03/15/2019. - From follow-up inspection 2019-09-05: **Time Extended** | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6008599 LAQUINTA INN
 License Type: Motel 34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 09/05/2019 Inspection Number: 1206465 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ROTONDI, VICTOR

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 04-03-4 | Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.room 314 and 228 | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 07-04-4 | Electrical outlet damaged to indicate a malfunction. For reporting purposes only.by room #304/hallway | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Pinellas County

| | | | |
|----------------------------------|---|---|--|
| License Number: 6202672 | | MOLLOY GULF MOTEL | |
| License Type: Motel | | 10164 GULF BLVD, TREASURE ISLAND 337064809 | |
| Inspection Date: 09/03/2019 | Inspection Number: 1206185 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: DAY-WALKER, LISA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 01-02-4 | Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in recharge zone near unit 17A | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 6204365 | | PAGE TERRACE | |
| License Type: Motel | | 10500 GULF BLVD, TREASURE ISLAND 337064817 | |
| Inspection Date: 09/03/2019 | Inspection Number: 1208664 | Inspection Type: Complaint Full | Inspection Disposition: Call Back - Complied |
| Inspector Name: DAY-WALKER, LISA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 04-01-4 | - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel. - From follow-up inspection 2019-09-03: **Time Extended** | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 6211956 | | KENWOOD INN | |
| License Type: Motel | | 451 34 ST N, ST. PETERSBURG 33713 | |
| Inspection Date: 09/04/2019 | Inspection Number: 1208348 | Inspection Type: Complaint Full | Inspection Disposition: Call Back - Admin. complaint recommended |
| Inspector Name: RANVILLE, AMANDA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 07-03-4 | - From initial inspection : Scorch marks around an electrical outlet. For reporting purposes only. Room 204, complainant states it caught fire. - From follow-up inspection 2019-07-24: **Time Extended** - From follow-up inspection 2019-08-06: Roo | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 6207732 | | RODEWAY INN | |
| License Type: Motel | | 28596 US 19 N, CLEARWATER 33761 | |
| Inspection Date: 09/03/2019 | Inspection Number: 1208809 | Inspection Type: Complaint Full | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PEARCE, LAURA | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 04-02-4 | Smoke detector provided in guest room/unit with flashing light - manager replaced battery - room 212 For reporting purposes only. **Corrected On-Site** | 509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Pinellas County

| | | | |
|-------------------------------|---|---|--|
| License Number: 6201176 | | MAGNUSON HOTEL | |
| License Type: Motel | | 21252 US HWY 19 N, CLEARWATER 33765 | |
| Inspection Date: 09/04/2019 | Inspection Number: 1206937 | Inspection Type: Routine - Lodging | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: DAHL, MICHELE | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 08-03-4 | No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

| | | | |
|----------------------------------|--|---|--|
| License Number: 6203452 | | SHEPHARDS BEACH RESORT | |
| License Type: Motel | | 619 S GULFVIEW BLVD, CLEARWATER BCH 33767 | |
| Inspection Date: 09/04/2019 | Inspection Number: 1208836 | Inspection Type: Complaint Full | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: KOUSTIS, TIMOTHY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Gulf Tower. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

| | | | |
|----------------------------------|--|---|--|
| License Number: 6215570 | | HOLIDAY INN HOTEL & SUITES CLEARWATER BEACH | |
| License Type: Hotel | | 521 S GULFVIEW BLVD, CLEARWATER BEACH 33767 | |
| Inspection Date: 09/04/2019 | Inspection Number: 1149647 | Inspection Type: Routine - Lodging | Inspection Disposition: Warning Issued |
| Inspector Name: KOUSTIS, TIMOTHY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 08-04-4 | Boiler certificate not posted in the boiler room. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Polk County

License Number: 6300876 AMERICAS BEST INN & SUITES
 License Type: Motel 508 E MEMORIAL BLVD, LAKELAND 33801

Inspection Date: 09/05/2019 Inspection Number: 1208826 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BEAULIEU, STEPHANIE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 04-02-4 | No smoke detector provided in guest room/unit. For reporting purposes only. Smoke detector missing room 102 | 509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 6306196 SERENA INN
 License Type: Motel 9400 HWY 192, CLERMONT 34714

Inspection Date: 09/04/2019 Inspection Number: 1208775 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JACKSON, SHARON

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 04-01-4 | Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Putnam County

License Number: 6400001

SLEEP INN & SUITES OF PALATKA

License Type: Hotel

3805 REID ST, PALATKA 32177

Inspection Date: 09/05/2019

Inspection Number: 1151961

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. No smoke detector in room 204. Manager had employee replace smoke detector during inspection. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903650

EXTENDED STAY AMERICA #9634

License Type: Hotel

302 NORTHLAKE BLVD, ALTAMONTE SPRINGS 32701

Inspection Date: 09/06/2019

Inspection Number: 1150893

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

