

**Broward County**

License Number: 1620713

SUPER 8 MOTEL

License Type: Motel

333 S FEDERAL HWY, DANIA 33004

Inspection Date: 09/11/2019

Inspection Number: 1206546

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.  
Hanging by wires room202. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620870

HYATT HOUSE FT LAUDERDALE AIRPORT &amp; CRUISE PORT

License Type: Hotel

90 SW 18 AVE, DANIA BEACH 33004

Inspection Date: 09/11/2019

Inspection Number: 1150747

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620242

THE DIPLOMAT RESORT &amp; SPA

License Type: Hotel

3555 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 09/09/2019

Inspection Number: 1151896

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. in hotel office.For reporting purposes only. - From follow-up inspection 2019-09-09: Not repaired as of today. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. Boiler certificates expiring today. Engineer has new inspection reports. For reporting purposes only. - From follow-up inspection 2019-09-09: Engineer has

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620893

HAMPTON INN FORT LAUDERDALE/POMPANO BEACH

License Type: Hotel

900 S FEDERAL HWY, POMPANO BEACH 33062

Inspection Date: 09/11/2019

Inspection Number: 1150542

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BURGGRAVE, BROCK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At front desk panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620850

THE WORTHINGTON GUEST HOUSE

License Type: Motel

543 N BIRCH RD, FORT LAUDERDALE 33304

Inspection Date: 09/13/2019

Inspection Number: 1206754

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 130. Emailed Fire Marshal - Jeff Lucas - JLucas@fortlauderdale.gov  
\*\*Corrective Action Taken\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621031

FLORIDA FAIR HOUSING CORP

License Type: Apartment

1045 N ANDREWS AVE, FORT LAUDERDALE 33311

Inspection Date: 09/09/2019

Inspection Number: 1478387

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Apartment 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Citrus County**

License Number: 1900285

SIESTA APTS

License Type: Apartment

440 NE 9 ST APT 5, CRYSTAL RIVER 344283646

Inspection Date: 09/07/2019

Inspection Number: 1470797

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Middle building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2320362 2225 BUILDING  
 License Type: Apartment 2225 W 60 ST, HIALEAH 330164476

Inspection Date: 09/13/2019 Inspection Number: 1470898 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed a fire extinguisher in need of recharge next to the elevator on the second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no braking device to access fire extinguishers throughout the property <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300968 FATHER & SON  
 License Type: Apartment 1135 SW 6 ST, MIAMI 331303170

Inspection Date: 09/12/2019 Inspection Number: 1487393 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - From follow-up inspection 2019-09-12: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320476 HOTEL COLONNADE CORAL GABLES  
 License Type: Hotel 180 ARAGON AVE, CORAL GABLES 33134

Inspection Date: 09/11/2019 Inspection Number: 1150359 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed across room number 221 next to ice machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308571		JAMAICA MOTEL	
License Type: Motel		4601 SW 8 ST, MIAMI 331342571	
Inspection Date: 09/10/2019	Inspection Number: 1206298	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2319413		THE BILTMORE HOTEL	
License Type: Hotel		1200 ANASTASIA AVE, CORAL GABLES 331346340	
Inspection Date: 09/09/2019	Inspection Number: 1149386	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330336		THE OASIS	
License Type: Apartment		481 NE 37 ST, MIAMI 33137	
Inspection Date: 09/11/2019	Inspection Number: 1487899	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Wall of building 481 between apartments 3 & 4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329200		OCEAN REEF HOTEL	
License Type: Hotel		1130 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 09/12/2019	Inspection Number: 1149936	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2603661

TRAVELODGE INN & SUITES

License Type: Motel

1153 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 09/09/2019

Inspection Number: 1208395

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Fire extinguisher near room 304 - From follow-up inspection 2019-08-23: No change \*\*Time Extended\*\* - F

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913649

THE WEST WING BOUTIQUE HOTEL

License Type: Hotel

2501 E FOWLER AVE, TAMPA 33612

Inspection Date: 09/09/2019

Inspection Number: 1150805

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. Observed  
750,000 BTU/hr input. For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is  
required annually for power boilers and high  
pressure/high temperature boilers and biannually for low  
pressure steam or vapor heating boilers. 509.032(2)(d)  
The division, or its agent, shall notify the local firesafety  
authority or the State Fire Marshal of any readily  
observable violation of a rule adopted under chapter 633  
which relates to public lodging establishments or public  
food establishments, and the identification of such  
violation does not require any firesafety inspection  
certification. For reporting purposes only.

License Number: 3911500

EXTENDED STAY AMERICA #789

License Type: Hotel

12242 MORRIS BRIDGE RD, TEMPLE TERRACE 33637

Inspection Date: 09/12/2019

Inspection Number: 1150694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MAIO, BRENNNA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting  
purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is  
required annually for power boilers and high  
pressure/high temperature boilers and biannually for low  
pressure steam or vapor heating boilers. 509.032(2)(d)  
The division, or its agent, shall notify the local firesafety  
authority or the State Fire Marshal of any readily  
observable violation of a rule adopted under chapter 633  
which relates to public lodging establishments or public  
food establishments, and the identification of such  
violation does not require any firesafety inspection  
certification. For reporting purposes only.



**Marion County**

License Number: 5202473

HOMEWOOD SUITES AT HEATHBROOK

License Type: Hotel

4610 SW 49 RD, OCALA 34474

Inspection Date: 09/11/2019

Inspection Number: 1149855

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 310.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Okaloosa County**

License Number: 5603335

FAIRFIELD INN &amp; SUITES DESTIN

License Type: Hotel

19001 EMERALD COAST PKWY, DESTIN 32541

Inspection Date: 09/13/2019

Inspection Number: 1151860

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
# 130406 5/10/1961C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5601368

EMERALD COAST INN &amp; SUITES

License Type: Motel

1214 E HWY 98, FT WALTON BCH 32548

Inspection Date: 09/10/2019

Inspection Number: 1206338

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MCGEE, MONACO

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable.  
For reporting purposes only.  
The alarm needs new battery room 604, and room 405 the alarm is off the wall.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811120

HILTON ORLANDO

License Type: Hotel

6001 DESTINATION PWKY, ORLANDO 32819

Inspection Date: 09/09/2019

Inspection Number: 1149969

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809885

FAIRFIELD INN ORLANDO LK BUENA VISTA

License Type: Hotel

8615 VINELAND AVE, ORLANDO 32821

Inspection Date: 09/10/2019

Inspection Number: 1152049

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ TROUBLE \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803594

ORLANDO AIRPORT MARRIOTT LAKESIDE

License Type: Hotel

7499 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 09/13/2019

Inspection Number: 1150558

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809051

EMBASSY SUITES HOTELS

License Type: Hotel

5835 T G LEE BLVD, ORLANDO 32822

Inspection Date: 09/12/2019

Inspection Number: 1152130

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. 7 th floor beam.For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. 7 th floor beam.For reporting purposes only. - From follow-up inspection 2019-09-13: Alarm system was showing no alarms present, but still was showing troub

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811272

LONDONHOUSE

License Type: Apartment

7010 LAKE NONA BLVD, ORLANDO 32827

Inspection Date: 09/12/2019

Inspection Number: 1455778

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel , trouble relay.. For reporting purposes only. - From follow-up inspection 2019-08-28: \*\*Time Extended\*\* - From follow-up inspection 2019-09-12: \*\*Time

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804423

DAYS INN ORLANDO AIRPORT FLORIDA MALL

License Type: Motel

9301 ORANGE BLOSSOM TRAIL, ORLANDO 32837

Inspection Date: 09/11/2019

Inspection Number: 1208761

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Next to laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5810870		THE RITZ-CARLTON ORLANDO GRANDE LAKES	
License Type: Hotel		4012 CENTRAL FLORIDA PKWY, ORLANDO 32837	
Inspection Date: 09/13/2019	Inspection Number: 1151730	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-09-13: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811167		RESIDENCE INN & SPRINGHILL SUITES ORLANDO AT MILLENIA	
License Type: Hotel		5403 MILLENIA LAKES BLVD, ORLANDO 32839	
Inspection Date: 09/09/2019	Inspection Number: 1150846	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5801679		WOODHOLLOW APTS	
License Type: Apartment		5739 KINGSGATE DR, ORLANDO 328393681	
Inspection Date: 09/12/2019	Inspection Number: 1472345	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Laundry facilities. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5801794		WOODHOLLOW APTS	
License Type: Apartment		5739 KINGSGATE DR, ORLANDO 328393681	
Inspection Date: 09/12/2019	Inspection Number: 1472362	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Laundry facility. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Osceola County**

License Number: 5913656

LAKE CECILE RESORT INN & SUITES

License Type: Motel

4900 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 09/11/2019

Inspection Number: 1208016

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: BELTRAN, SANDRA

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2019-08-21: **\*\*Time Extended\*\*** - From follow-up inspection 2019-09-11: \*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6007675

HILTON SUITE HOTEL

License Type: Hotel

7920 GLADES RD, BOCA RATON 33434

Inspection Date: 09/06/2019

Inspection Number: 1152063

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
  
- Panel Indicates 7th Floor Speaker Trouble.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007452

MARRIOTT BOCA RATON AT BOCA CENTER

License Type: Hotel

5150 TOWN CENTER CIRCLE, BOCA RATON 33486

Inspection Date: 09/13/2019

Inspection Number: 1150487

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, LARRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Pinellas County**

License Number: 6205675

419 93 AVE N

License Type: Apartment

419 93 AVE N, ST. PETERSBURG 33702

Inspection Date: 09/07/2019

Inspection Number: 1481805

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Upstairs extinguisher next to unit 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215690

BAYWEST APARTMENTS LLC

License Type: Apartment

500 - 520 89 AVE N, ST. PETERSBURG 33702

Inspection Date: 09/07/2019

Inspection Number: 1481644

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
3 extinguishers area in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
3 extinguisher missing from designated boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203181

DELUX INN

License Type: Motel

1735 GULF TO BAY, CLEARWATER 33755

Inspection Date: 09/09/2019

Inspection Number: 1207735

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 116 and by 109

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6306539 BEST WESTERN MULBERRY HOTEL  
 License Type: Motel 2525 SR 60 E, MULBERRY 33860

Inspection Date: 09/13/2019 Inspection Number: 1207333 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BEAULIEU, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602284

MAINSTAY SUITES OF PORT ST LUCIE

License Type: Hotel

8501 CHAMPION WAY, PORT ST LUCIE 34986

Inspection Date: 09/13/2019

Inspection Number: 1150863

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. There are two portables located in the laundry room that are gauged red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602525

SLEEP INN OF PORT ST LUCIE

License Type: Hotel

8501 CHAMPIONS WAY, PORT ST LUCIE 34986

Inspection Date: 09/13/2019

Inspection Number: 1150814

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 2 portables in laundry area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400062 LEGACY DAYTONA SUITES LLC  
 License Type: Hotel 209 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 07/16/2019 Inspection Number: 1152084 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Second and third floor hallway mattresses and other items stored partially blocking path to fire escape.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401228 COVE MOTEL  
 License Type: Motel 1306 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 09/10/2019 Inspection Number: 1207881 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Viewed Fire Marshall report code violations for 131951. Dated 7/3/19. Maintenance states has estimate for new boiler	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403718 HOLIDAY INN EXPRESS AND SUITES  
 License Type: Motel 3301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 09/09/2019 Inspection Number: 1206988 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-09-09: Supervisory light on tech on site doing 6 month test	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.