

Brevard County

License Number: 1505681

SEA GRASS LANDINGS

License Type: Apartment

110- 132 SEA GRASS LANE, COCOA 32927

Inspection Date: 09/25/2019

Inspection Number: 1468028

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. 2 bbq grill units stored on covered porch units 120 and 130,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601857		DELUXE INN	
License Type: Motel		1150 S FEDERAL HWY, DANIA 33004-4343	
Inspection Date: 09/26/2019	Inspection Number: 1205748	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. some room windows have metal bars covering them and or wood covering them preventing egress from covered windows. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1601208		HALLANDALE BEACH RESORT	
License Type: Motel		703 NE 7 ST, HALLANDALE BEACH 33009	
Inspection Date: 09/23/2019	Inspection Number: 1207811	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Lights not flashing.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1600355		316 MINNESOTA STREET APARTMENTS	
License Type: Apartment		316 MINNESOTA ST, HOLLYWOOD 33019	
Inspection Date: 09/25/2019	Inspection Number: 1480704	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. some windows have metal coverings over them preventing egress from metal covered windows. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1606634		SUNSHINE APARTMENTS	
License Type: Apartment		6840 PEMBROKE RD, PEMBROKE PINES 33023	
Inspection Date: 09/24/2019	Inspection Number: 1487965	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Under stairway next to room #201	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1612733 ISLAND CLUB APARTMENTS
 License Type: Apartment 3505 W ATLANTIC BLVD, POMPANO BEACH 33069

Inspection Date: 09/24/2019 Inspection Number: 1487966 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. At building 9/3535 in meter room.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1610580 BONAVENTURE RESORT & SPA
 License Type: Hotel 250 RACQUET CLUB RD, WESTON 33326

Inspection Date: 09/26/2019 Inspection Number: 1150121 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERSAUD, SHAWN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 096910 8/14/2019, 096011 8/14/2019, 003925 8/25/2019 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312775 1020 APARTMENTS LLC
 License Type: Apartment 1020 NW 45 AVE, MIAMI 33126

Inspection Date: 09/26/2019 Inspection Number: 1478727 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319228 PULLMAN MIAMI AIRPORT
 License Type: Hotel 5800 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 09/25/2019 Inspection Number: 1151225 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 057720 exp. 5/19, FI 057721 exp. 5/19, FL 057719 exp. 5/19, FL 057718 exp. 5/19, FI 057717 exp. 5/19	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301227 VVV BEAUCHAMP 1 LLC
 License Type: Apartment 902 SALZEDO ST, CORAL GABLES 33134

Inspection Date: 09/25/2019 Inspection Number: 1481156 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at downstairs fire extinguisher by u it 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303571 33-37 SALAMANCA AVE APARTMENTS
 License Type: Apartment 33 SALAMANCA AVE, CORAL GABLES 33134

Inspection Date: 09/26/2019 Inspection Number: 1480479 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	AC/DC Light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307262

SANTINA APARTMENTS

License Type: Apartment

216 CALABRIA AVE, CORAL GABLES 33134

Inspection Date: 09/27/2019

Inspection Number: 1486311

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher missing breaking device by unit number 8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310220

REM RE MB LLC

License Type: Apartment

710 7 ST, MIAMI BEACH 33139

Inspection Date: 09/23/2019

Inspection Number: 1487943

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328823

GENEVA HOTEL

License Type: Hotel

1520 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 09/26/2019

Inspection Number: 1149637

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329303 1 HOTEL SOUTH BEACH
 License Type: Hotel 2341 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/27/2019 Inspection Number: 1151331 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed inspection tickets issued on 07/30/19. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302009 ALEXANDER HOTEL MIAMI BEACH LLC
 License Type: Hotel 5225 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 09/26/2019 Inspection Number: 1150845 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328890 OCEAN SPRAY HOTEL
 License Type: Hotel 4130 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 09/25/2019 Inspection Number: 1150514 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2019-09-25: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329399 DESIGN SUITES MIAMI BEACH
 License Type: Hotel 5445 COLLINS AVE STE CU14, MIAMI BEACH 33140

Inspection Date: 09/25/2019 Inspection Number: 1151260 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310973 RENAISSANCE HOMES
 License Type: Apartment 1895 NW 35 STREET, MIAMI 33142

Inspection Date: 09/26/2019 Inspection Number: 1479877 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located on the first and second floor of apartment complex, near and above unit number 2. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near unit number 2. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326042 ROLIE APARTMENTS
 License Type: Apartment 1833 NW 35 ST, MIAMI 331425488

Inspection Date: 09/25/2019 Inspection Number: 1471679 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device or means of access for fire extinguisher located next to unit number 2 on the first floor. **Repeat Viol	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310977 PALM PLAZA MOTEL
 License Type: Motel 7331 N MIAMI AVE, MIAMI 331503507

Inspection Date: 09/23/2019 Inspection Number: 1206300 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed inside exposed wires from smoke detector/alarm inside room number 9.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329967 DOMINIQUE DUMONT
 License Type: Apartment 765 NE 121 STREET, NORTH MIAMI 33161

Inspection Date: 09/26/2019 Inspection Number: 1487984 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device for extinguisher located between units 2 and 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329367 AC HOTEL MIAMI AVENTURA
 License Type: Hotel 20805 BISCAYNE BLVD, AVENTURA 33180

Inspection Date: 09/23/2019 Inspection Number: 1151011 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603661

TRAVELODGE INN & SUITES

License Type: Motel

1153 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 09/24/2019

Inspection Number: 1209031

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Overcharged extinguisher Near room 146

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3801005

BEACH FRONT APARTMENTS

License Type: Apartment

213 GARRETT RD, AVON PARK 33825

Inspection Date: 09/24/2019

Inspection Number: 1438488

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed multiple fire extinguishers throughout the property in the red zone. Priority: Repor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902852

GODFREY HOTELS & CABANAS

License Type: Hotel

7700 COURTNEY CAMPBELL CSWY, TAMPA 33607

Inspection Date: 09/24/2019

Inspection Number: 1150753

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. 745,000 BTU/Hour observed on data plate. For reporting purposes only.
- From follow-up inspection 2019-09-24: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. 745,000 BTU/hr. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. 745,000 BTU/hr. For reporting purposes only. - From follow-up inspection 2019-09-26: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906241

DOUBLETREE SUITES BY HILTON TAMPA BAY

License Type: Hotel

3050 N ROCKY POINT DR, TAMPA 33607

Inspection Date: 09/24/2019

Inspection Number: 1150907

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. 2 out of 3 boilers replaced. No boiler certificates observed for 2 new boilers. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602914

DAYS INN SPRINGS RESORT

License Type: Motel

18051 SOUTH TAMIAMI TRAIL, FORT MYERS 33908

Inspection Date: 09/23/2019

Inspection Number: 1207701

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near facility laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4702720

MADELINE SHEPARD APTS

License Type: Apartment

534 E COLLEGE AVE, TALLAHASSEE 32301

Inspection Date: 09/25/2019

Inspection Number: 1469249

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only: throughout property.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403194

HERON HOUSE

License Type: Hotel

512 SIMONTON ST, KEY WEST 33040

Inspection Date: 09/25/2019

Inspection Number: 1150563

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Outlet cover missing in room 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400696

HAWKS CAY RESORT

License Type: Hotel

61 HAWKS CAY BLVD, DUCK KEY 33050

Inspection Date: 09/27/2019

Inspection Number: 1150643

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500867

THE SURF RESTAURANT AND BAR

License Type: Motel

3199 S FLETCHER AVE, FERNANDINA BEACH 32034

Inspection Date: 09/24/2019

Inspection Number: 1207856

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 3

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603292

SHELL APARTMENTS

License Type: Apartment

367 ALABAMA ST, CRESTVIEW 32536

Inspection Date: 09/25/2019

Inspection Number: 1476777

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
 - left washer in laundry room has the electrical wiring exposed and in the drum area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808887

RAMADA SUITES ORLANDO INTERNATIONAL AIRPORT

License Type: Hotel

7500 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 09/27/2019

Inspection Number: 1150054

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel Tb smoke in room
127 z006 invalid reply. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 5806918

HYATT REGENCY ORL INTL AIRPORT

License Type: Hotel

9300 AIRPORT BLVD, ORLANDO 328274385

Inspection Date: 09/25/2019

Inspection Number: 1149616

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel, 1st floor tamper
active north se stair. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 5802176

ARROW MOTEL

License Type: Motel

5425 S ORANGE BLOSSOM TRL, ORLANDO 328392797

Inspection Date: 09/23/2019

Inspection Number: 1208847

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

06-03-4

- From initial inspection : Marked exit is inaccessible. For reporting purposes only.
Windows are nailed in in room 141. - From follow-up inspection 2019-09-23: 141
Time Extended509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State Fire
Marshal of any readily observable violation of a rule
adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Osceola County

License Number: 5900534

SUN INN & SUITES

License Type: Motel

5020 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 09/27/2019

Inspection Number: 1209105

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. In room 208

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005579 BOCA BEACH CLUB
 License Type: Hotel 900 S OCEAN BLVD, BOCA RATON 33432

Inspection Date: 09/24/2019 Inspection Number: 1151407 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TORRES, LARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014128 DOVELAND
 License Type: Apartment 8733 DOVELAND DR, PAHOKEE 33476

Inspection Date: 09/26/2019 Inspection Number: 1483219 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MENOR, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. For reporting purposes only. Many of the units have boards on the windows. Windows are used for emergency exits	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215769

COURTYARD BY MARRIOTT ST PETERSBURG DOWNTOWN

License Type: Hotel

300 4 ST N, ST. PETERSBURG 33701

Inspection Date: 09/27/2019

Inspection Number: 1150439

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: VALENCIA, ASHLEY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Rooftop relay for stairwell fan

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201054

BROOKSIDE SQUARE APARTMENTS

License Type: Apartment

200 72 AVE N, ST. PETERSBURG 33702

Inspection Date: 09/21/2019

Inspection Number: 1483262

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 129 building 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Glass partially broken and no means break glass further next to unit 156 building 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6206004

RIO VISTA VILLAGE

License Type: Apartment

200 78 AVE N, ST. PETERSBURG 33702

Inspection Date: 09/21/2019

Inspection Number: 1485739

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 148 building 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 198 building 14.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209282		CRESCENT LANE APARTMENTS	
License Type: Apartment		2000 GANDY BLVD N, ST. PETERSBURG 33702	
Inspection Date: 09/21/2019	Inspection Number: 1484013	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building J, next to unit 143	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6214934		LG-88 LLC	
License Type: Apartment		528 88 AVE N, ST. PETERSBURG 33702	
Inspection Date: 09/21/2019	Inspection Number: 1480087	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Fire extinguisher in recharge zone next to unit 3 building 628	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216079		JEFFERSON MANOR APARTMENTS	
License Type: Apartment		209 NW JEFFERSON CIR N, ST. PETERSBURG 33702	
Inspection Date: 09/21/2019	Inspection Number: 1486436	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Glass is broken next to apartment #3, no means to break remaining glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6202980		BAYVIEW PLAZA RESORT	
License Type: Motel		4321 GULF BLVD, ST PETE BCH 337063830	
Inspection Date: 09/26/2019	Inspection Number: 1205869	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near unit 722 is in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6203940

SUNRISE RESORT

License Type: Motel

229 CORONADO DR, CLEARWATER BEACH 33767

Inspection Date: 09/23/2019

Inspection Number: 1206729

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Between rooms 12 and 14. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6303259

MOTEL 6 #0677

License Type: Motel

3120 US HWY 98 N, LAKELAND 33805

Inspection Date: 09/23/2019

Inspection Number: 1207216

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed by unit 302.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKELAND 33813

Inspection Date: 09/25/2019

Inspection Number: 1151910

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: BEAULIEU, STEPHANIE

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
NAC 3 open - From follow-up inspection 2019-09-25: Alarm still on **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-09-25: Boiler report still expired **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406510

VILLAGES AT HALIFAX

License Type: Apartment

121 NORMA DR, DAYTONA BEACH 32114

Inspection Date: 09/25/2019

Inspection Number: 1476815

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Trouble on light office states building 2.
 Beeping from FACP in building 2. Power light on but nothing on screen. Trouble light on FACP Building.
 Maintenance st

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401657

THE SHORES RESORT & SPA

License Type: Motel

2637 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 09/25/2019

Inspection Number: 1207694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.