

Alachua County

License Number: 1100734 POINT 12 APARTMENTS
 License Type: Apartment 409 NE 11 ST, GAINESVILLE 32601

Inspection Date: 10/28/2019 Inspection Number: 1486445 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WEATHERS, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Outlet for light outside laundry has exposed wire, no fixture for bulb.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102962 AC HOTEL BY MARRIOTT GAINESVILLE
 License Type: Hotel 151 NW 14 ST, GAINESVILLE 32603

Inspection Date: 10/30/2019 Inspection Number: 1150973 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WEATHERS, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Two boilers on roof/floor 10. 600000 BTU. Spoke with Ken Nobel state deputy boiler inspector. He is aware of situation, but has not yet provided boiler inspections. **Corrective Action Taken** **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1500613

RIVER PALM HOTEL

License Type: Motel

420 S HARBOR CITY BLVD, MELBOURNE 32901

Inspection Date: 10/30/2019

Inspection Number: 1209641

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FRANZ, LISA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.by room 145

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600109 WHITE WAY ROOM HOUSE
 License Type: Apartment 602 NW 1 ST, DANIA 33004

Inspection Date: 10/30/2019 Inspection Number: 1475820 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-03-4	Marked exit is inaccessible. Metal shutters covering some doors preventing egress from covered doors. Metal post and or bars covering some apt windows preventing egress from bar covered windows. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618968 SPRINGHILL SUITES
 License Type: Hotel 151 SW 18 CT, DANIA 33004

Inspection Date: 10/28/2019 Inspection Number: 1149774 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620697 HILTON GARDEN INN FT LAUDERDALE
 License Type: Hotel 180 SW 18 AVE, DANIA 33004

Inspection Date: 10/30/2019 Inspection Number: 1149656 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. See comment section.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601126		PALMS INN	
License Type: Motel		1290 S FEDERAL HWY, DANIA 33004-4345	
Inspection Date: 10/31/2019	Inspection Number: 1208790	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	Marked exit is inaccessible. bars on some room windows preventing egress from bar covered windows. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621032		KAMOO MOHAMED	
License Type: Apartment		6015 WILEY ST, HOLLYWOOD 33023	
Inspection Date: 10/29/2019	Inspection Number: 1478357	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-04-4	Electrical box opened with wires exposed behind units 4 and 10.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620966		POMPANO GARDENS INC	
License Type: Apartment		329 SW 2 ST, POMPANO BEACH 33060	
Inspection Date: 10/31/2019	Inspection Number: 1479178	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRABE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apt 2, building 329.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1602168		BALI HAI MOTEL	
License Type: Motel		1601 N FEDERAL HWY, FORT LAUDERDALE 33305	
Inspection Date: 10/30/2019	Inspection Number: 1207860	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MATTIELLO-ATASSI, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke detector disconnected in room 114. Operator called for service. **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1619289

EXTENDED STAY AMERICA #1563

License Type: Hotel

6001 NW 6 WAY, FORT LAUDERDALE 33309

Inspection Date: 10/28/2019

Inspection Number: 1151029

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code

Observation

Violation Citation

04-05-4

No potable smoke detector provided . For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200160

BAYMONT INN & SUITE

License Type: Motel

3598 W US HWY 90, LAKE CITY 32055

Inspection Date: 10/30/2019

Inspection Number: 1209626

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Fire extinguisher missing from station in front of room 134.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329187 HILTON GARDEN INN MIAMI AIRPORT WEST
 License Type: Hotel 3550 NW 74 AVE, MIAMI 33122

Inspection Date: 11/01/2019 Inspection Number: 1150494 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307926 SABUGO APARTMENTS
 License Type: Apartment 949 NW 1 STREET, MIAMI 33128

Inspection Date: 10/28/2019 Inspection Number: 1474466 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316974 HYATT REGENCY MIAMI HOTEL
 License Type: Hotel 400 SE 2 AVE, MIAMI 331312197

Inspection Date: 10/29/2019 Inspection Number: 1149468 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316091 HOLIDAY INN DOWNTOWN PORT OF MIAMI
 License Type: Hotel 340 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 10/31/2019 Inspection Number: 1150695 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 5/10/19	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330061 BISCAYNE COVE
 License Type: Apartment 665 NE 83 TER, MIAMI 33138

Inspection Date: 10/28/2019 Inspection Number: 1487926 Inspection Type: Complaint Full Inspection Disposition: Call Back -
 Inspector Name: SEYBA, JAMES Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed no fire extinguisher between apartments 504 & 506, also observed no fire extinguisher next to elevator on 3rd floor. - From follow-up inspection 2019-10-28: Observed no fire extinguisher between apartments 504 & 506, also observed no fire extinguisher next to elevator on 3rd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no means to access fire extinguisher in locked boxes on floors 4,5, &6 **Repeat Violation** - From follow-up inspection 2019-10-28: Observed no means to access fire extinguisher in locked boxes on floors 4,5, &6	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329306 HYATT CENTRIC SOUTH BEACH
 License Type: Hotel 1600 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 10/29/2019 Inspection Number: 1152789 Inspection Type: Complaint Full Inspection Disposition: Warning
 Inspector Name: SUAREZ, LEOPOLDO Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329354 940 8TH STREET APARTMENTS
 License Type: Apartment 940 8 ST, MIAMI BEACH 33139

Inspection Date: 11/01/2019 Inspection Number: 1477425 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: WILLIAMS, ALFREDA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306151 ROSA APARTMENTS
 License Type: Apartment 7635 BYRON AVE, MIAMI BEACH 33141

Inspection Date: 10/29/2019 Inspection Number: 1468498 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located between apartments 1 and 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309237 GIL APTS
 License Type: Apartment 330 SW 57 AVE, MIAMI 33144

Inspection Date: 10/29/2019 Inspection Number: 1481429 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JA DE DIOS, YANLEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between unit 1 and 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308942 HUNTER LAND TRUST
 License Type: Apartment 1601 NW 62 ST, MIAMI 33147

Inspection Date: 11/01/2019 Inspection Number: 1488157 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only. But alarm panels.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310254 RANDO BAY HARBOR INC
 License Type: Apartment 9490 E BAY HARBOR DR, BAY HARBOR ISLANDS 33154

Inspection Date: 10/29/2019 Inspection Number: 1488267 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: UNZAGA, MILADYS Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire alarm flashing light system on trouble. By apt 110.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320005 MIAMI MARRIOTT DADELAND
 License Type: Hotel 9090 S DADELAND BLVD, MIAMI 331567825

Inspection Date: 10/31/2019 Inspection Number: 1149387 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: MASKASEM, SUPPACHAI Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329188 TRUMP INTL BEACH RESORT
 License Type: Hotel 18001 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 10/31/2019 Inspection Number: 1149924 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: PRIETO, VICENTE Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326270

HAINLIN MILLS PRESERVATION LP

License Type: Apartment

10400 SW 216 ST, CUTLER BAY 33190

Inspection Date: 11/01/2019

Inspection Number: 1478516

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in building 10360 between apartments 103 and 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613249 TOWNEPLACE SUITES
 License Type: Hotel 4801 LENOIR AVE, JACKSONVILLE 32216

Inspection Date: 10/28/2019 Inspection Number: 1150585 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ARMSTRONG, RICO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Certificates expired on 10/23/19 099965 099966	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2603527 USA INN
 License Type: Motel 1057 BROWARD RD, JACKSONVILLE 32218

Inspection Date: 10/31/2019 Inspection Number: 1209693 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. No smoke detectors in room 110, maintenance installed smoke detector during inspection **Corrected On-Site**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. Wire hanging on side of office building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613222 HOMEWOOD SUITES
 License Type: Hotel 10434 MIDTOWN PKWY, JACKSONVILLE 32246

Inspection Date: 10/29/2019 Inspection Number: 1149904 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FEAGANS, ASHLEY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 132876, 132877 expired on 10/18/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911502 EXTENDED STAY AMERICA #9643
 License Type: Motel 330 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 10/31/2019 Inspection Number: 1207256 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913532 LA QUINTA INN # 965
 License Type: Hotel 310 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 11/01/2019 Inspection Number: 1149736 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CANNELLA, MARK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. COS , manager posted boiler certificates in boiler room at time of inspection **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913659 HYATT PLACE WESLEY CHAPEL
 License Type: Hotel 26000 SIERRA CENTER BLVD, LUTZ 33559

Inspection Date: 10/30/2019 Inspection Number: 1151100 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HIRST, DAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700124 MAISON DEVILLE
 License Type: Apartment 504 BEVERLY ST, TALLAHASSEE 32301

Inspection Date: 11/01/2019 Inspection Number: 1469230 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: TAKEH, NADEGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only: by unit 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4701582 HOTEL DUVAL
 License Type: Hotel 415 NORTH MONROE STREET, TALLAHASSEE 32301

Inspection Date: 10/28/2019 Inspection Number: 1150496 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: TAKEH, NADEGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403073 LIMETREE BAY RESORT
 License Type: Motel 68250 OVERSEAS HWY, LAYTON 33001

Inspection Date: 10/30/2019 Inspection Number: 1209621 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: WHITEHURST, SCOTT Inspection Completed - No Further Action

Violation Code Observation

03-01-4 No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.

Violation Citation

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403033 DOVE CREEK LODGE
 License Type: Hotel 147 SEASIDE AVE, KEY LARGO 33037

Inspection Date: 10/30/2019 Inspection Number: 1150760 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: GONZALEZ, RICARDO Inspection Completed - No Further Action

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402361 THE STUDIOS OF KEYWEST
 License Type: Apartment 529 EATON ST, KEY WEST 33040

Inspection Date: 11/01/2019 Inspection Number: 1460548 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: MECK, PAMELA Inspection Completed - No Further Action

Violation Code Observation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only. Room 1.

Violation Citation

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403197 ROSE LANE VILLAS
 License Type: Hotel 522 ROSE LN, KEY WEST 33040

Inspection Date: 11/01/2019 Inspection Number: 1150740 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MECK, PAMELA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402207 OLD CUSTOM HOUSE INN
 License Type: Apartment 124 DUVAL ST, KEY WEST 330406562

Inspection Date: 10/29/2019 Inspection Number: 1471835 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MECK, PAMELA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Upstairs fire extinguisher expired 3/2018.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500303

DIXIE MOTEL

License Type: Motel

551664 US HWY 1, HILLIARD 32046

Inspection Date: 10/29/2019

Inspection Number: 1207450

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. In laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808503 BOWEN APARTMENTS
 License Type: Apartment 2048 BOWEN DR, ORLANDO 32822

Inspection Date: 10/29/2019 Inspection Number: 1477703 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between 2060 and 2062 and between 2052 and 2054.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801336 RESERVE AT LAKE BUCHANAN
 License Type: Apartment 1717 W HOLDEN AVE, ORLANDO 32839

Inspection Date: 10/30/2019 Inspection Number: 1484122 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Laundry facility.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Hammer missing for fire extinguisher near 4618A.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012005 J & D RENTALS INC
 License Type: Apartment 505 SW 9 ST, BELLE GLADE 33430

Inspection Date: 10/30/2019 Inspection Number: 1472188 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MENOR, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. All 4 boxes are empty	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6003812 HOLIDAY INN EXPRESS BOCA RATON -WEST
 License Type: Motel 8144 GLADES RD, BOCA RATON 33434

Inspection Date: 10/30/2019 Inspection Number: 1207965 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - Trouble Light #1 indicator is ON. General Manager Stated it has been on since being reviewed by Fire Marshall.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215769 COURTYARD BY MARRIOTT ST PETERSBURG DOWNTOWN
 License Type: Hotel 300 4 ST N, ST. PETERSBURG 33701

Inspection Date: 10/29/2019 Inspection Number: 1150439 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: PORTER, LINDSAY Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Rooftop relay for stairwell fan - From follow-up inspection 2019-10-29: Trouble lights still illuminated	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204220 SAND DUNE APARTMENTS LLC
 License Type: Apartment 8012 BLIND PASS RD, ST.PETE BEACH 33706

Inspection Date: 10/27/2019 Inspection Number: 1483875 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: DAY-WALKER, LISA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Outlet in front of unit 1 has damaged outlet.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215777 SUNCOAST BEACH VILLAS
 License Type: Motel 10232 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 10/28/2019 Inspection Number: 1206999 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: DAY-WALKER, LISA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. 1 Gentex Heating impaired smoke detector not flashing light during inspection.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6202405 SPENCER RECOVERY CENTER
 License Type: Apartment 601 71 AVE, ST PETERSBURG BCH 337063609

Inspection Date: 11/01/2019 Inspection Number: 1469682 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: DAY-WALKER, LISA Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher in recharge zone upstairs near door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205339 ALPINE OAKS
 License Type: Apartment 2069 ALPINE RD, CLEARWATER 33755

Inspection Date: 10/26/2019 Inspection Number: 1480621 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAHL, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. No extinguisher in box near unit 1	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204235 CENTRAL PARK APTS A
 License Type: Apartment 90 JASPER ST, LARGO 337705403

Inspection Date: 10/31/2019 Inspection Number: 1473909 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Sitting on ground between unit 10 and 11. Holder is broken .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205597 CORNERSTONE POINTE APARTMENTS
 License Type: Apartment 301 SEACREST DR, LARGO 33771

Inspection Date: 11/01/2019 Inspection Number: 1478107 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to unit 204.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6206026 OASIS AT BAYSIDE
 License Type: Apartment 305 GLADES CIR, LARGO 33771

Inspection Date: 11/01/2019 Inspection Number: 1486937 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to unit 207, 201,289, 105,99, 119, 131. All scheduled to be replaced.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6206527 MYSTIC BAY
 License Type: Apartment 600 STARKEY RD, LARGO 33771

Inspection Date: 10/31/2019 Inspection Number: 1487492 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 1103	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Unit next to 703, 1311,	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6800877

LAUREL VILLA MOTEL

License Type: Motel

1409 N TAMIAMI TRL, NOKOMIS 342751570

Inspection Date: 10/29/2019

Inspection Number: 1206463

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed exterior of Unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903020

EASTBROOK APARTMENTS

License Type: Apartment

2610 EASTBROOK BLVD, WINTER PARK 32792

Inspection Date: 10/29/2019

Inspection Number: 1483550

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403685 MAPLE STREET APARTMENTS
 License Type: Apartment 304 MAPLE ST, DAYTONA BEACH 32114

Inspection Date: 10/31/2019 Inspection Number: 1481122 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. North west stairway.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401131 BELLAIR PALMS
 License Type: Apartment 2417 N. OLEANDER DRIVE, DAYTONA BEACH 32118

Inspection Date: 10/29/2019 Inspection Number: 1474646 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Lp tank stored next stairway by apartment 19. Remove. Motorcycle stored under landing by apartment 17.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406522 TRAVELODGE DELTONA
 License Type: Motel 481 DELTONA BLVD, DELTONA 32725

Inspection Date: 10/29/2019 Inspection Number: 1208094 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ANGEL, TERRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 04/07/2019.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.