

Alachua County

License Number: 1102395

ROYAL INN

License Type: Motel

16305 NW 162ND LANE, ALACHUA 32615

Inspection Date: 11/19/2019

Inspection Number: 1207358

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between rooms 185 & 183

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1500643

GARDEN PARK APARTMENTS

License Type: Apartment

1600 GARDEN ST, ATTN: OFFICE, TITUSVILLE 32796

Inspection Date: 11/21/2019

Inspection Number: 1479441

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Behind office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620904

WYNDHAM GARDEN FT LAUDERDALE AIRPORT AND CRUISE PORT

License Type: Hotel

129 N FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 11/21/2019

Inspection Number: 1151978

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation Code Observation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.see comment section.

Violation Citation61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. See comment section.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620854

HOLLYWOOD BEACH HOTELS- FLAMINGO

License Type: Motel

324 MCKINLEY ST, HOLLYWOOD 33019

Inspection Date: 11/20/2019

Inspection Number: 1206897

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation Code Observation

06-03-4 Marked exit is inaccessible. metal coverings over windows preventing egress from metal covered windows. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618593

EXTENDED STAY AMERICA 9808

License Type: Hotel

1401 SW 15 ST, POMPANO BEACH 33060

Inspection Date: 11/21/2019

Inspection Number: 1149748

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BURGGRABE, BROCK

Violation Code Observation02-04-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. In electrical room. Removed to outside.
Corrected On-SiteViolation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618826 SON COR VILLA
 License Type: Apartment 350 NW 10 ST, POMPANO BEACH 33060

Inspection Date: 11/21/2019 Inspection Number: 1472708 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRABE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next to apt N and between A and B.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604798 PICTURE APARTMENTS
 License Type: Apartment 2037 SE 3 ST, DEERFIELD BEACH 33441-5149

Inspection Date: 11/20/2019 Inspection Number: 1473007 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PINEROS, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By Apartment #6 on first floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 11/18/2019

Inspection Number: 1209905

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Establishment does not have a boiler certificate. Plate states unit is a boiler. 676,500 BTUs.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311162 WEST PALM APARTMENTS LLC
 License Type: Apartment 10 W 38 ST, HIALEAH 33012

Inspection Date: 11/20/2019 Inspection Number: 1477377 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apartment #11.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328280 1665 W 41 ST APARTMENTS
 License Type: Apartment 1665 W 41 ST, HIALEAH 33012

Inspection Date: 11/21/2019 Inspection Number: 1471160 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apartment #1667.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322664 2116 LLC
 License Type: Apartment 21 E 40 ST, HIALEAH 33013

Inspection Date: 11/22/2019 Inspection Number: 1481782 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located next to apartment #23 door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322648 HIA APARTMENTS
 License Type: Apartment 6130 W 22 CT, HIALEAH 330163948

Inspection Date: 11/21/2019 Inspection Number: 1473162 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no glass breaking device next to unit #105	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2322266 HILTON ESTATES
 License Type: Apartment 6385 W 24 AVE, HIALEAH 330166960

Inspection Date: 11/15/2019 Inspection Number: 1468926 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325549 JJR APARTMENTS LLC
 License Type: Apartment 151 SE 8 ST, HOMESTEAD 33030

Inspection Date: 11/22/2019 Inspection Number: 1482999 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ALEJANDRO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328266 EXTENDED STAY AMERICA #1600
 License Type: Hotel 8655 NW 21 TERRACE, MIAMI 33122

Inspection Date: 11/22/2019 Inspection Number: 1151017 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 97595 expired on 10/16/17, FL 97596 expired 12/28/18. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304307 APARTAMENTOS DIEGO LLC
 License Type: Apartment 1870 NW 22 AVENUE, MIAMI 33125

Inspection Date: 11/21/2019 Inspection Number: 1480456 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 9. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302881 4440 APARTMENTS
 License Type: Apartment 4440 NW 9 ST, MIAMI 331262462

Inspection Date: 11/20/2019 Inspection Number: 1470576 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JA DE DIOS, YANLEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 46.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303739 1054 MONICA LLC
 License Type: Apartment 1054 NW 5 ST, MIAMI 33128

Inspection Date: 11/20/2019 Inspection Number: 1477474 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Glass breaking device missing from fire extinguisher station. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329361 1042 ADRIANA LLC
 License Type: Apartment 1042 NW 5 ST, MIAMI 33128

Inspection Date: 11/20/2019 Inspection Number: 1477475 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed glass breaking device missing from fire extinguisher station. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330365 CAOBA MIAMI WORLDCENTER
 License Type: Apartment 698 NE 1 AVE, MIAMI 33132

Inspection Date: 11/20/2019 Inspection Number: 1488367 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329207		SPRINGHILL SUITES BY MARRIOTT	
License Type: Hotel		1311 NW 10TH AVE, MIAMI 33136	
Inspection Date: 11/21/2019	Inspection Number: 1152555	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328156		CONTRERAS APTS	
License Type: Apartment		142 NE 26 ST, MIAMI 33137	
Inspection Date: 11/19/2019	Inspection Number: 1471082	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of unit #3. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305469		SHELBORNE SOUTH BEACH	
License Type: Hotel		1801 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 11/22/2019	Inspection Number: 1152668	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-11-22: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305485		NATIONAL HOTEL (THE)	
License Type: Hotel		1677 COLLINS AVENUE, MIAMI BEACH 33139	
Inspection Date: 11/19/2019	Inspection Number: 1151556	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329419		LENNOX MIAMI	
License Type: Hotel		1900 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 11/18/2019	Inspection Number: 1151241	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boiler in boilers room.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322623		CASA DEL MAR	
License Type: Apartment		1409 EUCLID AVE, MIAMI BEACH 331393911	
Inspection Date: 11/15/2019	Inspection Number: 1468947	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-06-4	Door marked as an exit locked with a lock that requires a key. For reporting purposes only. Back gate with chains and lock that requires a key.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301114		LA FLORA HOTEL	
License Type: Hotel		1238 COLLINS AVE, MIAMI BEACH 331394607	
Inspection Date: 11/20/2019	Inspection Number: 1149370	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-11-20: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327192		RED SOUTH BEACH HOTEL	
License Type: Hotel		3010 COLLINS AVE, MIAMI BEACH 33140	
Inspection Date: 11/21/2019	Inspection Number: 1151503	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329307 AC HOTEL MIAMI BEACH
 License Type: Hotel 2912 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 11/20/2019 Inspection Number: 1151573 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308001 NORTH BEACH VILLAS LLC
 License Type: Apartment 7625 ABBOTT AVE, MIAMI BEACH 33141

Inspection Date: 11/18/2019 Inspection Number: 1476442 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308899 MONACO BAY APTS
 License Type: Apartment 2025 CALAIS DR, MIAMI BEACH 33141

Inspection Date: 11/21/2019 Inspection Number: 1477315 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on extinguisher located on the side of apt. 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310212 CRYSTAL BAY APTS
 License Type: Apartment 2101 CALAIS DR, MIAMI BEACH 33141

Inspection Date: 11/21/2019 Inspection Number: 1476783 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on none of the extinguishers located on the building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329315 HYATT PLACE
 License Type: Hotel 3549 LEJEUNE RD, MIAMI 33142

Inspection Date: 11/18/2019 Inspection Number: 1150569 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on fire panel located at maintenance office. **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329968 PARAIISO AT FOUNTAIN SQUARE
 License Type: Apartment 9931 W FLAGER ST, MIAMI 33174

Inspection Date: 11/15/2019 Inspection Number: 1484215 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2315092 HONEY SUCKLE APARTMENTS
 License Type: Apartment 10720 SW 2 ST, SWEET WATER 33174

Inspection Date: 11/21/2019 Inspection Number: 1476138 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed inside meter room area. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323032 ROSE APTS
 License Type: Apartment 10860 SW 3 ST, SWEETWATER 331744421

Inspection Date: 11/22/2019 Inspection Number: 1471001 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher located between units 6 and 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705362

EXTENDED STAY AMERICA #302

License Type: Motel

809 BLOODWORTH LN, PENSACOLA 32504

Inspection Date: 11/21/2019

Inspection Number: 1207837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901693 EL RANCHO MOTEL
 License Type: Motel 7100 NEBRASKA AVE, TAMPA 336044992

Inspection Date: 11/18/2019 Inspection Number: 1206349 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARQUETTI, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to unit 108, 117 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913577 EXTENDED STAY AMERICA #1805
 License Type: Hotel 4312 W SPRUCE ST, TAMPA 33607

Inspection Date: 11/22/2019 Inspection Number: 1153092 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. New boilers installed 10/18/19. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913637 SPRINGHILL SUITES- TAMPA NORTH
 License Type: Hotel 5396 PRIMROSE LAKE CIRCLE, TAMPA 33647

Inspection Date: 11/21/2019 Inspection Number: 1150025 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MAIO, BRENNNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100359

ST FRANCIS MANOR OF VB INC

License Type: Apartment

1750 20 AVE, VERO BCH 329603639

Inspection Date: 11/22/2019

Inspection Number: 1469192

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.
Observed when walking through the premises that there are a lot of items in the breezeway that can block exit egress in an emergency

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300132

BLUE HERON

License Type: Apartment

4780 NE INDIAN RIVER DR, JENSEN BEACH 34957-4037

Inspection Date: 11/20/2019

Inspection Number: 1473841

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301450

MACKNIGHT RENTAL

License Type: Apartment

524 SW CAMDEN AVE, STUART 34994

Inspection Date: 11/20/2019

Inspection Number: 1482306

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher observed on the premises. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804177 THE FLORIDA HOTEL & CONFERENCE CENTER
 License Type: Hotel 1500 SANDLAKE RD, ORLANDO 32809

Inspection Date: 11/15/2019 Inspection Number: 1149667 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GUTTERMAN, KENNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator provided updated certification **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805056 RED ROOF PLUS
 License Type: Hotel 8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 11/20/2019 Inspection Number: 1150713 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Completed
 Inspector Name: CHIU, CECILIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Room 115. - From follow-up inspection 2019-11-20: Room 115, is occupied at time of inspection. Advised operator to ensure hearing	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2019-11-20: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810905 HILTON GARDEN INN ORLANDO I-DRIVE NORTH
 License Type: Hotel 5877 AMERICAN WAY, ORLANDO 32819

Inspection Date: 11/19/2019 Inspection Number: 1149657 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2019-11-21: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2019-11-21: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800691 HIDDEN COVE APTS
 License Type: Apartment 4900 S RIO GRANDE AVE, ORLANDO 32839

Inspection Date: 11/19/2019 Inspection Number: 1472089 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DIOP, DONALD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In room 28A. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804293

THE LANDING AT EAST MIL

License Type: Apartment

4937 WATERWAY CT, ORLANDO 32839

Inspection Date: 11/20/2019

Inspection Number: 1486013

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Room 512. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808609

POINTE VISTA APARTMENTS

License Type: Apartment

5455 POINTE VISTA CIR, ORLANDO 32839

Inspection Date: 11/21/2019

Inspection Number: 1486263

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Laundry facility.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913656

LAKE CECILE RESORT INN & SUITES

License Type: Motel

4900 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 11/20/2019

Inspection Number: 1210013

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014007

TRADITION OF THE PALM BEACHES

License Type: Apartment

4920 LORING DR, WEST PALM BEACH 33417

Inspection Date: 11/21/2019

Inspection Number: 1475094

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SINGH, GAJENDRA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214016

PALM GROVE INN

License Type: Hotel

711 3 AVE S OFFICE, ST. PETERSBURG 33701

Inspection Date: 11/22/2019

Inspection Number: 1151004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code Observation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 108.

Violation Citation

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6207251

JEFFERSON APARTMENTS

License Type: Apartment

121 N JEFFERSON AVE, CLEARWATER 33755

Inspection Date: 11/23/2019

Inspection Number: 1483213

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code Observation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit four

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215906

FAITH APARTMENTS

License Type: Apartment

7095 110 ST, SEMINOLE 33772

Inspection Date: 11/20/2019

Inspection Number: 1478887

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code Observation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 1 next to unit 2.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602518

HILTON GARDEN INN AT PGA VILLAGE

License Type: Hotel

8540 COMMERCE CENTRE DR, PORT ST LUCIE 34986

Inspection Date: 11/20/2019

Inspection Number: 1151757

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406415

HAMPTON INN DAYTONA SPEEDWAY AIRPORT

License Type: Hotel

1715 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 11/20/2019

Inspection Number: 1150390

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.