

Brevard County

License Number: 1500078

SIESTA MOTOR INN

License Type: Motel

2006 S WASHINGTON AVE, TITUSVILLE 32780-4739

Inspection Date: 12/19/2019

Inspection Number: 1207434

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620604		SLEEP INN AND SUITE	
License Type: Hotel		1500 SE 5 AVE, DANIA 33004	
Inspection Date: 12/18/2019	Inspection Number: 1152249	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1610896		GOLDEN SEA APTS	
License Type: Apartment		345 MCKINLEY ST, HOLLYWOOD 33019-3438	
Inspection Date: 12/18/2019	Inspection Number: 1472928	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-03-4	- From initial inspection : Marked exit is inaccessible. some apartment windows have metal coverings over them preventing egress from metal covered windows. For reporting purposes only. - From follow-up inspection 2019-12-18: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621451		CLUB AT CRYSTAL LAKE	
License Type: Apartment		3800 CRYSTAL LAKE DR, POMPANO BEACH 33064	
Inspection Date: 12/20/2019	Inspection Number: 1488572	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PINEROS, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Building 3800 by apartment # 502.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1605018		925 OCEAN RESORT	
License Type: Motel		925 SE 20 AVE, DEERFIELD BEACH 33441	
Inspection Date: 12/20/2019	Inspection Number: 1208943	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PINEROS, MICHELE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near vending machines 1st floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Clay County

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 12/19/2019

Inspection Number: 1210435

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Box across from room 410.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305910 WESTLAND 49 APARTMENTS
 License Type: Apartment 1337 W 49 PLACE, HIALEAH 33012

Inspection Date: 12/20/2019 Inspection Number: 1487409 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309713 TWINS HIALEAH TRACK LLC
 License Type: Apartment 456 E 29 ST, HIALEAH 33013

Inspection Date: 12/20/2019 Inspection Number: 1482364 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310999 3800 INVESTMENTS LLC
 License Type: Apartment 3800 E 4 AVE, HIALEAH 33013

Inspection Date: 12/16/2019 Inspection Number: 1480578 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on the 2nd floor by the unit #1. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318942		EASTLAND MANOR LLC	
License Type: Apartment		450 E 30 ST, HIALEAH 33013	
Inspection Date: 12/20/2019	Inspection Number: 1482212	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near to apartment #10. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2326144		WG APARTMENTS LLC	
License Type: Apartment		2364-2380 W 56 SREET, HIALEAH 33016	
Inspection Date: 12/17/2019	Inspection Number: 1481434	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to unit 102 on building 2380.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2315596		ESTORIL APARTMENTS	
License Type: Apartment		555 NW 72 AVE, MIAMI 33126	
Inspection Date: 12/16/2019	Inspection Number: 1488579	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Extension given, pending
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed hummer taped to the extinguisher by unit 307. - From follow-up inspection 2019-12-16: Observed hummer taped to the extinguisher by unit 307. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329271		CAMBRIA SUITES MIAMI AIRPORT- BLUE LAGOON	
License Type: Hotel		6750 NW 7 ST, MIAMI 33126	
Inspection Date: 12/16/2019	Inspection Number: 1152404	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2316439		CASA BONITA APTS	
License Type: Apartment		345 NW 57 AVE, MIAMI 331264862	
Inspection Date: 12/20/2019	Inspection Number: 1468311	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By units 102, 106, 108, 112, 210, second floor laundry room, and 202 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2310075		FLAGLER PARK II	
License Type: Apartment		437 NW 57 AVE, MIAMI 331264863	
Inspection Date: 12/20/2019	Inspection Number: 1471254	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	Fire alarm control panel has no power. For reporting purposes only. Observed on the south side of the building by 13S. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2300996		38 OVIEDO AVE LLC	
License Type: Apartment		38 OVIEDO AVE, CORAL GABLES 33134	
Inspection Date: 12/20/2019	Inspection Number: 1483344	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed in the fire extinguisher in the second floor next to unit 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2307262		SANTINA APARTMENTS	
License Type: Apartment		216 CALABRIA AVE, CORAL GABLES 33134	
Inspection Date: 12/19/2019	Inspection Number: 1486311	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher missing breaking device by unit number 8. - From follow-up inspection 2019-12-19: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher missing breaking device by unit number 8. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2309344		VALENCIA 520-524 LLC	
License Type: Apartment		220 ANTILLA AVE, CORAL GABLES 33134	
Inspection Date: 12/19/2019	Inspection Number: 1479089	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher missing breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307879		325 MAJORCA AVE APTS	
License Type: Apartment		325 MAJORCA AVE, CORAL GABLES 331344275	
Inspection Date: 12/20/2019	Inspection Number: 1468492	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed next to unit five.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307898		LINDA COURT	
License Type: Apartment		441 SANTANDER AVE, CORAL GABLES 331346518	
Inspection Date: 12/13/2019	Inspection Number: 1471336	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No visible portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301260		APARTMENT BUILDING	
License Type: Apartment		227 SW 13 AVE, MIAMI 331352430	
Inspection Date: 12/20/2019	Inspection Number: 1470819	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2309245 410 NE 62 ST
 License Type: Apartment 410 NE 62 ST, MIAMI 33138

Inspection Date: 12/20/2019 Inspection Number: 1481939 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartment #4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304994 THE BLUE MOON HOTEL
 License Type: Hotel 944 & 926 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 12/17/2019 Inspection Number: 1150244 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329186 MONDRIAN SOUTH BEACH
 License Type: Hotel 1100 WEST AVE, MIAMI BEACH 33139

Inspection Date: 12/16/2019 Inspection Number: 1150726 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329249 THE WASHINGTON PARK HOTEL
 License Type: Hotel 1020 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 12/17/2019 Inspection Number: 1150146 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329295		BOULAN HOTEL	
License Type: Hotel		220 21 ST, MIAMI BEACH 33139	
Inspection Date: 12/20/2019	Inspection Number: 1151371	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: SUAREZ, LEOPOLDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329437		THE PALM HOUSE	
License Type: Apartment		1010 PENNSYLVANIA AVE, MIAMI BEACH 33139	
Inspection Date: 12/16/2019	Inspection Number: 1479411	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329894		1005 PENN LLC	
License Type: Apartment		1005 PENNSYLVANIA AVE, MIAMI BEACH 33139	
Inspection Date: 12/16/2019	Inspection Number: 1483886	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WILLIAMS, ALFREDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2326476 RIU PLAZA MIAMI BEACH
 License Type: Hotel 3101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 12/17/2019 Inspection Number: 1151534 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed confirmation for boilers inspection for Bureau Veritas USA. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329296 THE CONFIDANTE
 License Type: Hotel 4041 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 12/20/2019 Inspection Number: 1151803 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305870 BOSCH FL LLC
 License Type: Apartment 6940 BAY DR, MIAMI BEACH 33141

Inspection Date: 12/20/2019 Inspection Number: 1479549 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located in between units 7 and 8.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310214		VITTEL LLC	
License Type: Apartment		1935 NORMANDY DR, MIAMI BEACH 33141	
Inspection Date: 12/20/2019	Inspection Number: 1478762	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher 2 floor. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304428		PARK SURF APARTMENTS	
License Type: Apartment		341 73 ST, MIAMI BEACH 331412784	
Inspection Date: 12/17/2019	Inspection Number: 1470622	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed beside apt. 16. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2307989		HAMLET APT	
License Type: Apartment		1020 NE 127 ST, NORTH MIAMI 331614261	
Inspection Date: 12/16/2019	Inspection Number: 1471403	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located between Apt 2 and Apt 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2303109		ROLAND APARTMENTS	
License Type: Apartment		729 NE 127 ST, NORTH MIAMI 331614802	
Inspection Date: 12/16/2019	Inspection Number: 1470624	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Extinguishers located next to apt 2 and in hallway of 2nd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2307295		1940 NE 167 ST APTS	
License Type: Apartment		1940 NE 167 ST, NORTH MIAMI BEACH 33162	
Inspection Date: 12/18/2019	Inspection Number: 1474805	Inspection Type: Routine - Lodging	Inspection Disposition: Administrative complaint recommended
Inspector Name: CHOW, ZULEIMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Building 1940, by unit 3A. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330275		5250 PARK	
License Type: Apartment		5250 NW 84 AVE, DORAL 33166	
Inspection Date: 12/18/2019	Inspection Number: 1486430	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329236		COMFORT SUITES MIAMI INTERNATIONAL AIRPORT	
License Type: Hotel		657 MINOLA DR, MIAMI SPRINGS 33166	
Inspection Date: 12/17/2019	Inspection Number: 1150055	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At fire extinguisher across from 518.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at fire extinguisher across from room number 418.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hernando County

License Number: 3700071

QUALITY INN & SUITES

License Type: Motel

30307 CORTEZ BLVD, BROOKSVILLE 34602

Inspection Date: 12/20/2019

Inspection Number: 1207963

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 8/15/19

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800078

LAKESIDE RESORT

License Type: Apartment

176 BERTON DR, LAKE PLACID 33852

Inspection Date: 12/18/2019

Inspection Number: 1474869

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: JACKS, ALBERT

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Units 1 and three.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3800987

LAKESIDE COTTAGES

License Type: Motel

740 S LAKEVIEW RD, LAKE PLACID 33857

Inspection Date: 12/18/2019

Inspection Number: 1206513

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only :unit one.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3904663

MARRIOTT TAMPA WESTSHORE

License Type: Hotel

1001 N WESTSHORE BLVD, TAMPA 33607

Inspection Date: 12/19/2019

Inspection Number: 1149697

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificates or insurance inspector's boiler reports
expired. For reporting purposes only. ****Repeat Violation****61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

License Number: 3907679

BAYMONT INN & SUITES TAMPA

License Type: Hotel

3001 UNIVERSITY CENTER DR, TAMPA 33612

Inspection Date: 12/20/2019

Inspection Number: 1150363

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report
expired. For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is
required annually for power boilers and high
pressure/high temperature boilers and biannually for low
pressure steam or vapor heating boilers. 509.032(2)(d)
The division, or its agent, shall notify the local firesafety
authority or the State Fire Marshal of any readily
observable violation of a rule adopted under chapter 633
which relates to public lodging establishments or public
food establishments, and the identification of such
violation does not require any firesafety inspection
certification. For reporting purposes only.

Leon County

License Number: 4700474		WYNDHAM GARDEN TALLAHASSEE CAPITOL	
License Type: Hotel		1355 APALACHEE PKWY, TALLAHASSEE 32301	
Inspection Date: 12/18/2019	Inspection Number: 1153360	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAKEH, NADEGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4701568		LA CASA INN & SUITES	
License Type: Motel		2801 N MONROE ST, TALLAHASSEE 32303	
Inspection Date: 12/16/2019	Inspection Number: 1210138	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TRUESDALE, CHRIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-01-4	Path to door marked as an exit is blocked in side door to lobby. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4700264		SUNSET MOTEL	
License Type: Motel		9556 APALACHEE PKWY, TALLAHASSEE 32311	
Inspection Date: 12/16/2019	Inspection Number: 1210383	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: TAKEH, NADEGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only: room 8.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Manatee County

License Number: 5103874

QUALITY INN

License Type: Motel

580 E 66 ST COURT, BRADENTON 342086013

Inspection Date: 12/19/2019

Inspection Number: 1206118

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300126

WEST END APARTMENTS

License Type: Apartment

3101 W END BLVD, JENSEN BEACH 34957

Inspection Date: 12/18/2019

Inspection Number: 1482856

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the
extinguisher is in need of recharge. For reporting purposes
only. By unit 4.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 5301461

THE HAMMOCK AT STUART VILLA RENTALS

License Type: Apartment

701 SE MARTIN LUTHER KING JR BLVD, STUART 34994

Inspection Date: 12/18/2019

Inspection Number: 1480051

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher observed on the premises. For
reporting purposes only.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Orange County

License Number: 5801661 LA QUINTA INN
 License Type: Motel 5825 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 12/18/2019 Inspection Number: 1206625 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.Boiler 1.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801774 DOUBLETREE BY HILTON ORLANDO UNIVERSAL
 License Type: Hotel 5780 MAJOR BLVD, ORLANDO 32819

Inspection Date: 12/17/2019 Inspection Number: 1153291 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 16th main line lobby smoke 3rd service elevator smoke Trouble light for convention center - From follow-up inspection 2019-12-17: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013679

THE SOPHIA AT ABACOA

License Type: Apartment

863 UNIVERSITY BLVD, JUPITER 33458

Inspection Date: 12/16/2019

Inspection Number: 1488626

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. by bldg #859/by alarm bell/hallway

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007819

MOTEL 6 #0688

License Type: Motel

310 W LANTANA RD, LANTANA 33462

Inspection Date: 12/16/2019

Inspection Number: 1207242

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Trouble light blinking

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009310

BELL BOCA TOWN CENTER

License Type: Apartment

5881 TOWN BAY DR, BOCA RATON 33486

Inspection Date: 12/19/2019

Inspection Number: 1482355

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TORRES, LARRY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By apt 10-17 in building 5880.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212783	THE POINT PROPERTIES, LLC		
License Type: Apartment	10814 NAVAJO DR, ST. PETERSBURG 33708		
Inspection Date: 12/20/2019	Inspection Number: 1488491	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 17.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215671	RESIDENCE INN ST PETERSBURG CLEARWATER		
License Type: Hotel	5050 ULMERTON RD, CLEARWATER 33760		
Inspection Date: 12/17/2019	Inspection Number: 1150901	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: AUSTIN, MARK			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2019-12-16: Trouble light still on on the fire alarm system **Time Extended** - From follow-up inspection 2019-12-17: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2019-12-16: Trouble light still on on the fire alarm system **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - room 922 - From follow-up inspection 2019-12-16: Hearing-impaired smoke detector still not functioning **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - room 922 - From follow-up inspection 2019-12-16: Hearing-impaired smoke detector still not functioning **Time Extended** - From follow-up inspection 2019-12-17: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215772		INTOWN SUITES	
License Type: Hotel		2833 ROOSEVELT BLVD, CLEARWATER 33760	
Inspection Date: 12/20/2019	Inspection Number: 1149939	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AUSTIN, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215782		PELICAN POINTE RESORT & HOTEL	
License Type: Hotel		445 GULFVIEW BLVD, CLEARWATER 33767	
Inspection Date: 12/17/2019	Inspection Number: 1149966	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 225.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing hammer next to 325. Hammer broken next to 314. Hammer missing next to 4th floor elevator. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215768		ROYAL NORTH BEACH HOTEL	
License Type: Motel		657 MANDALAY AVE, CLEARWATER BEACH 33767	
Inspection Date: 12/16/2019	Inspection Number: 1207675	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to 206	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Putnam County

License Number: 6400778

HOLLY RIDGE SENIOR APARTMENTS

License Type: Apartment

6401 ST JOHNS AVE, PALATKA 32177

Inspection Date: 12/17/2019

Inspection Number: 1474524

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near room 133 has needle in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904006

ALAFAYA TRAIL OWNER LLC

License Type: Apartment

2590 GREENHILL WAY, OVIEDO 32765

Inspection Date: 12/17/2019

Inspection Number: 1485029

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel reads Summer kitchen ansul z036. The summer kitchen is under remodel per operator

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904050

LOFTS AT EDEN

License Type: Apartment

1840 RINEHART RD, SANFORD 32771

Inspection Date: 12/19/2019

Inspection Number: 1486166

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Sanford Fire Inspector, Mark James, 407-562-2786. Left Voice Message.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406514		THE DAYTONA AUTOGRAPH COLLECTION	
License Type: Hotel		1870 VICTORY CIR, DAYTONA BEACH 32114	
Inspection Date: 12/16/2019	Inspection Number: 1151294	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-01-4	- From initial inspection : Path to door marked as an exit is blocked. For reporting purposes only. Path to exit partial blocked by boxes near boiler room. - From follow-up inspection 2019-12-16:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7406367		CAROLINA CLUB APTS	
License Type: Apartment		100 CAROLINA LAKE DR, DAYTONA BCH 321141148	
Inspection Date: 12/20/2019	Inspection Number: 1469947	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. FACP in office states alarm silenced ,120 alarm trouble,a1 fire alarms,duct detectors . Building 24trouble light and disable light flashing.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7401486		SUPER INN	
License Type: Motel		1515 S RIDGEWOOD AVE, DAYTONA BCH 321146133	
Inspection Date: 12/16/2019	Inspection Number: 1205920	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
07-01-4	Damaged electrical wire(s). For reporting purposes only. Light hanging from wires in storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7400796		LIGHTHOUSE INN	
License Type: Motel		1227 N ATLANTIC AVE, DAYTONA BEACH 32118	
Inspection Date: 12/17/2019	Inspection Number: 1207352	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: RUTLEDGE, REBECCA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 3.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Volusia County

License Number: 7400500

PERRY'S OCEAN EDGE RESORT

License Type: Motel

2209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 12/18/2019

Inspection Number: 1207121

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405162

RIVERSHORE COTTAGES

License Type: Motel

3150 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 12/18/2019

Inspection Number: 1208162

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Must be hard wired and is not, unable to test

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406516

SA 2011 LLC

License Type: Motel

3635 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 12/18/2019

Inspection Number: 1207732

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

06-01-4

Side patio door does not open, north villa., For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406522

TRAVELODGE DELTONA

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 12/19/2019

Inspection Number: 1210410

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Notified Lisa Nadeau, Deltona Fire Inspector, 386-878-8656.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.