

Broward County

License Number: 1604617 GARSAM TERRACE APARTMENTS
 License Type: Apartment 701 NE 10 ST, HALLANDALE 33009-2540

Inspection Date: 01/08/2020 Inspection Number: 1473511 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit #3	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620955 GOLDEN SQUARE APARTMENTS
 License Type: Apartment 1415 NW 18 DR, POMPANO BEACH 33069

Inspection Date: 01/06/2020 Inspection Number: 1477697 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Second floor landing next to #205. 102/1411 building. Also missing at 1st floor near meter room same building. Building 104/1391 ground floor extinguisher box empty.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621523 COUNTRYSIDE PROPERTY OWNER LLC
 License Type: Apartment 5621 SW 36 CT, DAVIE 33314

Inspection Date: 01/06/2020 Inspection Number: 1487710 Inspection Type: Lodging-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: CHAPDELAIN, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-02-4	exposed electrical wire(s). For reporting purposes only. Building 5661 se corner next to lamp, above the address.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-02-4	- From initial inspection : exposed electrical wire(s). For reporting purposes only. Building 5661 se corner next to lamp, above the address. - From follow-up inspection 2020-01-10: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329864 BY THE RIVER PROPERTIES LLC
 License Type: Apartment 840 NW 4TH ST, MIAMI 33128

Inspection Date: 01/09/2020 Inspection Number: 1486703 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing glass breaking device from cabinet. At the first floor of the building.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301611 MERDA DO MONE APTS
 License Type: Apartment 1552 SW 2 ST, MIAMI 33135

Inspection Date: 01/09/2020 Inspection Number: 1481788 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301124 ANNA MARIA APTS
 License Type: Apartment 180 NE 57 ST, MIAMI 331372489

Inspection Date: 01/09/2020 Inspection Number: 1470785 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 14. **Repeat Violation**

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309788 1031-41 NE 78TH ROAD, LLC
 License Type: Apartment 1020 NE 78TH ROAD, MIAMI 33138

Inspection Date: 01/07/2020 Inspection Number: 1479596 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

Violation Code Observation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units 4 & 6 **Repeat Violation**

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302622 1322 LLC
 License Type: Apartment 1322 NE 105 ST, MIAMI SHORES 33138

Inspection Date: 01/08/2020 Inspection Number: 1487973 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: SEYBA, JAMES Inspection Completed - No Further Action

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between units 10 & 11, and between 20 & 21.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324795 RIVIERA PLAZA APARTMENTS
 License Type: Apartment 337 20 ST, MIAMI BEACH 33139

Inspection Date: 01/07/2020 Inspection Number: 1482457 Inspection Type: Routine - Lodging Inspection Disposition: Warning
 Inspector Name: SUAREZ, LEOPOLDO Issued

Violation Code Observation

06-06-4 Door marked as an exit locked with a lock that requires a key. For reporting purposes only. Gate on front right side of the building is locked with chain and lack that requires a key.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329240 RIVIERA LOFTS HOTEL
 License Type: Hotel 318 20 ST, MIAMI BEACH 33139

Inspection Date: 01/10/2020 Inspection Number: 1152140 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: SUAREZ, LEOPOLDO Completed - No Further Action

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329250 THE WASHINGTON PARK HOTEL
 License Type: Hotel 1036 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 01/09/2020 Inspection Number: 1150205 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: MASKASEM, SUPPACHAI Completed - No Further Action

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329370 BERKELEY SHORE HOTEL
 License Type: Hotel 1610 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 01/07/2020 Inspection Number: 1151975 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Advised manager she called technician and he corrected it. **Corrected On-Site**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302009 ALEXANDER HOTEL MIAMI BEACH LLC
 License Type: Hotel 5225 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/06/2020 Inspection Number: 1152337 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328890 OCEAN SPRAY HOTEL
 License Type: Hotel 4130 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/10/2020 Inspection Number: 1151901 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329277 HILTON CABANA MIAMI BEACH
 License Type: Hotel 6261 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/07/2020 Inspection Number: 1151828 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed new Certificate of Inspection 4/24/19. As per operator they haven't received Certificates. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2323650 THE PALMS SOUTH BEACH HOTEL
 License Type: Hotel 3025 COLLINS AVE, MIAMI BEACH 331404106

Inspection Date: 01/09/2020 Inspection Number: 1151524 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler Certificate missing for boiler 059039. Inspection done on 12/17/18, according Inspection Report from Division of State Fire Marshall.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305430 SOUTHWIND APTS
 License Type: Apartment 2 S SHORE DR, MIAMI BEACH 33141

Inspection Date: 01/10/2020 Inspection Number: 1479148 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire alarm located by the window of unit 8.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310483 THE CASA MIA GROUP
 License Type: Apartment 2271 NW 26 ST, MIAMI 33142

Inspection Date: 01/06/2020 Inspection Number: 1482714 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguishers on the 2nd floor near unit 8 and on the 1st of apartment complex missing breaking devices, no means of access.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308917		TAPIA BROTHERS	
License Type: Apartment		6791 NW 22 AVE, MIAMI 331477270	
Inspection Date: 10/15/2019	Inspection Number: 1471328	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: JOSEPH, VANRIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apt # 3-4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2302419		HALL'S APARTMENT	
License Type: Apartment		12416 NE 12 COURT, NORTH MIAMI 33161	
Inspection Date: 01/06/2020	Inspection Number: 1476109	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310172		MANOR APTS	
License Type: Apartment		544 NE 124 ST, NORTH MIAMI 33161	
Inspection Date: 01/08/2020	Inspection Number: 1474649	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 1 and apt 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330151		BIMINI PROPERTIES LLC	
License Type: Apartment		670 NW 134 ST, NORTH MIAMI 33168	
Inspection Date: 01/09/2020	Inspection Number: 1486700	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 11.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2301228

VICON APTS

License Type: Apartment

10860 SW 6 ST, SWEETWATER 331741559

Inspection Date: 01/09/2020

Inspection Number: 1468265

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed extinguisher with no braking device located by mail boxes And unit 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330211

THE LANDMARK SOUTH

License Type: Apartment

6055 NW 105 CT, DORAL 33178

Inspection Date: 01/06/2020

Inspection Number: 1486325

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed on alarm panels on both buildings.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2611874 GOLDEN SHORES JACKSONVILLE (KONA)
 License Type: Apartment 7623 KONA AVE, JACKSONVILLE 32211

Inspection Date: 01/08/2020 Inspection Number: 1484425 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Near units 458, 315, 7693 and 7717. - From follow-up inspection 2020-01-08: 315 fire extinguisher still missing. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609173 APT SUITES JAX AIRPORT
 License Type: Motel 812 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 01/08/2020 Inspection Number: 1210571 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near room 116	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700071

QUALITY INN & SUITES

License Type: Motel

30307 CORTEZ BLVD, BROOKSVILLE 34602

Inspection Date: 01/06/2020

Inspection Number: 1207963

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MEAKINS, ALLISON

Violation Code Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 8/15/19 - From follow-up inspection 2020-01-06: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800759

INN ON THE LAKES

License Type: Hotel

3100 GULFVIEW DR, SEBRING 338725002

Inspection Date: 01/08/2020

Inspection Number: 1149614

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code Observation

Violation Citation

02-07-4 Flammable chemicals stored near a source of ignition. For reporting purposes only. Pain stored on cart near boiler. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100080

VERO BEACH SPORTS VILLAGE

License Type: Motel

3901 26 ST, VERO BEACH 32960

Inspection Date: 01/09/2020

Inspection Number: 1207098

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Fire alarm silenced and in trouble mode-company working on repairing in laundry

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202214

LA QUINTA INN & SUITES #988

License Type: Hotel

3530 SW 36 AVE, OCALA 34474

Inspection Date: 01/09/2020

Inspection Number: 1151500

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. For boiler 058132.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. For boiler 058132

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400221

PELICAN COVE RESORT & MARINA

License Type: Motel

84457 OLD OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 01/08/2020

Inspection Number: 1209041

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code ObservationViolation Citation04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting
purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402993

BATES B & B

License Type: Bed and Breakfast

84791 OLD HWY, ISLAMORADA, VLG OF I 33036

Inspection Date: 01/09/2020

Inspection Number: 1093472

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code ObservationViolation Citation03-01-4 No fire sprinkler system installed in a transient lodging establishment three
stories or more in height, or over 75 feet in height. For reporting purposes only.

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5400696

HAWKS CAY RESORT

License Type: Hotel

61 HAWKS CAY BLVD, DUCK KEY 33050

Inspection Date: 01/07/2020

Inspection Number: 1152350

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code ObservationViolation Citation04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting
purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810954 HERITAGE HOTEL
 License Type: Motel 7900 S ORANGE BLOSSOM TRAIL, ORLANDO 32809

Inspection Date: 01/06/2020 Inspection Number: 1207004 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per Kevin establishment has two new boilers that were installed approximately two months ago.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811143 RUBEN SANCHEZ
 License Type: Apartment 805 SKYLAKE CIR APT D, ORLANDO 32809

Inspection Date: 01/06/2020 Inspection Number: 1476801 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 805 near unit A	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811239 SANDLAKE COURTYARD CONDOMINIUM
 License Type: Apartment 7900 S ORANGE BLOSSOM TRL, ORLANDO 32809

Inspection Date: 01/06/2020 Inspection Number: 1480594 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per Kevin establishment installed two new boilers that need to be inspected	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801461

I-DRIVE GRAND RESORT & SUITES

License Type: Motel

7050 S KIRKMAN RD, ORLANDO 32819

Inspection Date: 01/09/2020

Inspection Number: 1207641

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: YOUNG, COLIN

Violation Code ObservationViolation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808632

EXTENDED STAY AMERICA #174

License Type: Hotel

6451 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 01/08/2020

Inspection Number: 1149535

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FERTIL, SYLVERST

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809011 HOMETOWNE STUDIOS ORLANDO UCF AREA 3513
 License Type: Hotel 12350 E COLONIAL DR, ORLANDO 32826

Inspection Date: 01/09/2020 Inspection Number: 1150604 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-07-4	Flammable chemicals stored near a source of ignition. For reporting purposes only. Red gas can stored in the boiler room , operator removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System is in trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 092329 8/22/19, 133126 8/22/19 certificates expired	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810883 THE LOFT
 License Type: Apartment 1805 LOFTWAY, ORLANDO 32826

Inspection Date: 01/09/2020 Inspection Number: 1475156 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: THORNCROFT, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System reads ground fault	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810908 NORTHLAKE PARK APTS.
 License Type: Apartment 9300 NORTHLAKE PARKWAY, ORLANDO 32827

Inspection Date: 01/06/2020 Inspection Number: 1474738 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). maintenance shop. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804763

LAKE NONA CLUB

License Type: Hotel

9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 01/08/2020

Inspection Number: 1152068

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 10-24-19

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810870

THE RITZ-CARLTON ORLANDO GRANDE LAKES

License Type: Hotel

4012 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 01/03/2020

Inspection Number: 1151050

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804460

MILLENNIA WEST APARTMENTS

License Type: Apartment

5496 FITNESS CIR, ORLANDO 32839

Inspection Date: 01/06/2020

Inspection Number: 1485049

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 2 room 203.
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900700

BANYAN HOTEL & MICROSUITES

License Type: Motel

5565 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 01/09/2020

Inspection Number: 1207602

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation Code Observation

Violation Citation

08-01-4 One Boiler certificate or insurance inspector's boiler report expired. On 07/19/19 FL050723. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904001

GRANDEVILLE AT RIVERPLACE

License Type: Apartment

2980 GRANDEVILLE CIR, OVIEDO 32765

Inspection Date: 01/10/2020

Inspection Number: 1479126

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: THORNCROFT, ROBERT

Violation Code Observation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Panel at the front reads supervisor back flow blg 6-7 - From follow-up inspection 2020-01-10: Alarm #9 **Time Extended**

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600214 MAYFLOWER SIX APARTMENTS INC
 License Type: Apartment 1017 MAYFLOWER RD, FORT PIERCE 34950

Inspection Date: 01/09/2020 Inspection Number: 1475340 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAVIS, DIANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Top floor between apartments 4 and 5	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602522 HOLIDAY INN EXPRESS HOTEL & SUITES
 License Type: Hotel 1601 NW COURTYARD CIRCLE, PORT ST LUCIE 34986

Inspection Date: 01/10/2020 Inspection Number: 1149938 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SCHOENLY, BARBARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm company working on finding the problem	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405449 ROYAL INN OF RIDGEWOOD
 License Type: Motel 810 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 01/08/2020 Inspection Number: 1208233 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Motorcycle stored under a landing by room 135. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406564 ZAPPIS ITALIAN GARDEN
 License Type: Apartment 128 S BEACH ST, DAYTONA BEACH 32114

Inspection Date: 01/06/2020 Inspection Number: 1479555 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble ,system silence - From follow-up inspection 2020-01-06: Manager states tech has come out to look at panel and coming back to look at strobe horn.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405715 OCEAN BREEZE CLUB HOTEL
 License Type: Motel 640 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 01/07/2020 Inspection Number: 1210578 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble,silenced lights	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-03-4	Exit door to stairway hard to open by room 520. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.