

Broward County

License Number: 1602320

CORAL KEY APARTMENTS

License Type: Apartment

4608 N OCEAN DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 01/15/2020

Inspection Number: 1479317

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
By unit 2, South side of the building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000674

ZEN LIVING SUITES

License Type: Motel

150 PARK AVE, ORANGE PARK 32073

Inspection Date: 01/14/2020

Inspection Number: 1210625

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code Observation

Violation Citation

04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. In unit 401.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Operator states Fire Inspection occurring Thursday. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328199 FERCO APARTMENTS
 License Type: Apartment 78 W 24 ST, HIALEAH 33010

Inspection Date: 01/14/2020 Inspection Number: 1473175 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By unit #2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2321514 HOLIDAY INN EXPRESS & SUITES - MIAMI/HIALEAH
 License Type: Hotel 6650 W 20 AVE, HIALEAH 33016

Inspection Date: 01/17/2020 Inspection Number: 1152032 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed Boiler Jurisdiction and Expiration: FL093792, FL088026 both expire on 08-11-19 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329794 VILLA CAPRI III
 License Type: Apartment 14548 SW 284 ST, HOMESTEAD 33033

Inspection Date: 01/16/2020 Inspection Number: 1480367 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Breaking device missing by units 105 and 106 of building 14648 - From follow-up inspection 2020-01-16: Breaking device missing by units 105 and 106 of building 14648 **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308601 THE NEW YORKER
 License Type: Motel 6500 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 01/16/2020 Inspection Number: 1208335 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. In front of room 106.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326492 SIXTY SIXTY RESORT
 License Type: Hotel 6060 INDIAN CREEK DR, MIAMI BEACH 33140

Inspection Date: 01/16/2020 Inspection Number: 1152446 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328969 CADILLAC HOTEL & BEACH CLUB, AUTOGRAPH COLLECTION
 License Type: Hotel 3925 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/14/2020 Inspection Number: 1152429 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329321 L HOTEL
 License Type: Hotel 4121 INDIAN CREEK DR, MIAMI BEACH 33140

Inspection Date: 01/16/2020 Inspection Number: 1152449 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PRIETO, VICENTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308726 RONNA APARTMENTS
 License Type: Apartment 501 77 ST, MIAMI BEACH 33141

Inspection Date: 01/17/2020 Inspection Number: 1488801 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection
 Inspector Name: UNZAGA, MILADYS Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on extinguisher located next to unit 4 on the first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308061 JERRICO APARTMENTS
 License Type: Apartment 235 78 ST, MIAMI BEACH 331412189

Inspection Date: 01/16/2020 Inspection Number: 1473544 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: UNZAGA, MILADYS Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device on extinguishers on premises. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329351 FOUR SEASONS HOTEL THE SURF CLUB
 License Type: Hotel 9011 COLLINS AVE, SURFSIDE 33154

Inspection Date: 01/14/2020 Inspection Number: 1152025 Inspection Type: Routine - Lodging Inspection Disposition: Inspection
 Inspector Name: UNZAGA, MILADYS Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Date 02/24/2019.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330049 109 TOWER FL LLC
 License Type: Apartment 737 SW 109 AVE, MIAMI 33174

Inspection Date: 01/16/2020 Inspection Number: 1488799 Inspection Type: Complaint Full Inspection Disposition: Inspection
 Inspector Name: GONZALEZ, ERIK Inspection Completed - No Further Action

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher in recharge zone between rooms 1107 and 1109. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330218

801 NE 85 ST LLC

License Type: Apartment

801 NE 85 ST, NORTH MIAMI 33179

Inspection Date: 01/14/2020

Inspection Number: 1486519

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near to apartment number 1,3 and 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613266

MARBLE WATERS HOTEL & SUITES

License Type: Hotel

45 KERNAN BLVD N, JACKSONVILLE 32256

Inspection Date: 01/15/2020

Inspection Number: 1151485

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.
 Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901589

ORANGE MOTEL

License Type: Motel

7800 N NEBRASKA AVE, TAMPA 336044241

Inspection Date: 01/14/2020

Inspection Number: 1206348

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARQUETTI, JESSICA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Unit 2

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800225

APM INN & SUITES ORLANDO

License Type: Hotel

3155 S JOHN YOUNG PKWY, ORLANDO 32805

Inspection Date: 01/15/2020

Inspection Number: 1153483

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation Code Observation

Violation Citation

06-02-4 Door marked as an exit is blocked. For reporting purposes only. In bottom banquet area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801035

VILLAS DEL SOL

License Type: Apartment

229 W LANCASTER RD, ORLANDO 32809

Inspection Date: 01/15/2020

Inspection Number: 1483710

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MANTI, KATHRYN

Violation Code Observation

Violation Citation

01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Blocked by plant stand near Units 6 and 4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013898 VISTA LAGO APARTMENTS
 License Type: Apartment 3130 N JOG RD, WEST PALM BEACH 33411

Inspection Date: 01/17/2020 Inspection Number: 1474442 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 6 - trouble CNT 3. Technician notified. **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014059 HOLIDAY INN EXPRESS & SUITES
 License Type: Hotel 1251 HYPOLUXO RD, LANTANA 33462

Inspection Date: 01/17/2020 Inspection Number: 1152212 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6001587 ATLANTIC HIDEAWAY LLC
 License Type: Motel 297 NE 6 AVE, DELRAY BEACH 33483

Inspection Date: 01/14/2020 Inspection Number: 1209393 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: AHLE, ROBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to room 9. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6206187 BOBELIS APARTMENTS
 License Type: Apartment 16900 E 1 ST, N REDINGTON BCH 337081458

Inspection Date: 01/17/2020 Inspection Number: 1472637 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Between units 1010-102.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215782 PELICAN POINTE RESORT & HOTEL
 License Type: Hotel 445 GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 01/17/2020 Inspection Number: 1149966 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to 225. - From follow-up inspection 2020-01-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing hammer next to 325. Hammer broken next to 314. Hammer missing next to 4th floor elevator. **Repeat Violation** - From follow-up inspection 2020-01-17: Operator has a repair company completing necessary repairs. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6302826

WESTMONT INN

License Type: Motel

1817 E MEMORIAL BLVD, LAKELAND 33801

Inspection Date: 01/16/2020

Inspection Number: 1209076

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
Room 203 missing. Room 206, disconnected and not working. Room 209 detector is missing.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500188

SEABREEZE MOTEL

License Type: Motel

208 ANASTASIA BLVD, SAINT AUGUSTINE 32080

Inspection Date: 01/16/2020

Inspection Number: 1206866

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ANDERSON, EDWARD

Violation Code Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
 No smoke detector in unit 10. Corrected on site by installing new smoke
 detector. **Repeat Violation** **Corrected On-Site** **Repeat Violation**

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7404230

INDIGO PLANTATION APARTMENTS

License Type: Apartment

100 POWELL BLVD, DAYTONA BEACH 32114

Inspection Date: 01/15/2020

Inspection Number: 1482138

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

02-08-4

Char coal stored under a stairwell by apartment 1101. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.