

Bay County

License Number: 1305242

HOLIDAY INN EXPRESS & SUITES PANAMA CITY BEACH - BEACHFRONT

License Type: Hotel

12907 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 01/27/2020

Inspection Number: 1151116

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code

Observation

Violation Citation

05-03-4

High Priority - The front desk clerk/person responsible for registering guests is unaware of the location of the hearing-impaired smoke detector(s).

61C-1.004(8) FAC High Priority: Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in transient public lodging establishments without charge. Failure of the operator to inform any employee charged with registering guests of the location of such detector constitutes failure to make such detectors available.

Bradford County

License Number: 1400018

BUDGET INN OF LAWTEY

License Type: Motel

23670 US HWY 301 N, LAWTEY 32058

Inspection Date: 01/29/2020

Inspection Number: 1210694

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher by room 118.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601248 SEA COVE MOTEL
 License Type: Motel 213 S OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 01/27/2020 Inspection Number: 1208785 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Next to apt six. Pipe covering wire is rusted through and wire is exposed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600543 LEGRANDE PRIX APARTMENTS
 License Type: Apartment 2308 NE 9 ST, FORT LAUDERDALE 33304-3562

Inspection Date: 01/30/2020 Inspection Number: 1469127 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint, clothing and debris behind dryer in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 1602846 GREAT ESCAPE INN
 License Type: Motel 4620 N OCEAN DR, FORT LAUDERDALE 33308

Inspection Date: 01/31/2020 Inspection Number: 1207706 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-03-4	High Priority - The front desk clerk/person responsible for registering guests is unable of the location of the hearing-impaired smoke detector(s).	61C-1.004(8) FAC High Priority: Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in transient public lodging establishments without charge. Failure of the operator to inform any employee charged with registering guests of the location of such detector constitutes failure to make such detectors available.

License Number: 1601745 4605 N OCEAN DR LLC
 License Type: Motel 4605 N OCEAN DR, LAUDERDALE BY THE SE 33308

Inspection Date: 01/31/2020 Inspection Number: 1207981 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location, on North building by unit #16. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604194		TROPIC SEAS	
License Type: Motel		4616 EL MAR DR, LAUDERDALE-BY-THE-SE 33308-3618	
Inspection Date: 01/30/2020	Inspection Number: 1205983	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.	
License Number: 1614909		PR CENTRO SUNFOREST OWNER LLC	
License Type: Apartment		2750 SW 73RD WAY, DAVIE 33314	
Inspection Date: 01/29/2020	Inspection Number: 1484913	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher next to apartment 2609	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher at building 3 in front of apartment 313	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing fire extinguisher in front of apartments 1315, 1509, and 413	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621164		33 WEST	
License Type: Apartment		6300 SW 24 PL, DAVIE 33314	
Inspection Date: 01/30/2020	Inspection Number: 1459386	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher next to garage G-34	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 10 next to apartment 205 Extinguisher next to garage G-16 Building 2 next to apartment 311	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Charlotte County

License Number: 1801522

HOLIDAY INN EXPRESS

License Type: Hotel

24440 SANDHILL BLVD, PORT CHARLOTTE 33983

Inspection Date: 01/29/2020

Inspection Number: 1152092

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code

Observation

Violation Citation

02-01-4

High Priority - Build-up of lint in the laundry room. Housekeeper cleaned the excessive lint from behind the dryers. ****Corrected On-Site** **Repeat Violation****

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Collier County

License Number: 2102474

HAWTHORN SUITES

License Type: Hotel

3557 PINE RIDGE RD, NAPLES 34109

Inspection Date: 01/30/2020

Inspection Number: 1151569

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

02-01-4 High Priority - Build-up of lint in the laundry room. **Repeat Violation**

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Columbia County

License Number: 2200232

RODEWAY INN

License Type: Motel

205 SW COMMERCE DR., LAKE CITY 32025

Inspection Date: 01/30/2020

Inspection Number: 1209887

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
In front of room 120.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328172 SECURITY INVESTMENT LLC
 License Type: Apartment 55 W 26 STREET, HIALEAH 33010

Inspection Date: 01/27/2020 Inspection Number: 1478974 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by unit 6 portable fire extinguisher need of recharge.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304515 TURF 2 LLC
 License Type: Apartment 479 E 28 ST, HIALEAH 33013

Inspection Date: 01/29/2020 Inspection Number: 1483297 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apt#6	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2320673 BUDGET HOST INN
 License Type: Motel 815 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 01/28/2020 Inspection Number: 1210696 Inspection Type: Complaint Partial Inspection Disposition: Warning Issued
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2311385 CORDOBA COURTS
 License Type: Apartment 13875 NW 22 AVE, OPA LOCKA 33054-4151

Inspection Date: 01/28/2020 Inspection Number: 1488840 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-03-4	High Priority - Build-up of clothing/debris in the laundry room. Behind washers and dryers next to unit 190	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Dade County

License Number: 2328407 EXTENDED STAY AMERICA #1762
 License Type: Hotel 7750 NW 25 ST, MIAMI 33122

Inspection Date: 01/27/2020 Inspection Number: 1152977 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by the receptionist office fire alarm with some lights on. As per operator the mechanics are coming next Monday.

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311171 SOCARRAS APARTMENT
 License Type: Apartment 619 SW 10 ST, MIAMI 331303851

Inspection Date: 01/29/2020 Inspection Number: 1473140 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

02-01-4 High Priority - Build-up of lint in the laundry room.

Violation Citation

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2317880 RODEWAY INN & SUITES DOWNTOWN BRICKELL
 License Type: Hotel 100 SE 4 ST, MIAMI 33131

Inspection Date: 01/28/2020 Inspection Number: 1152594 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boilers in a room outside the building by the dumpsters.

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2316974 HYATT REGENCY MIAMI HOTEL
 License Type: Hotel 400 SE 2 AVE, MIAMI 331312197

Inspection Date: 01/27/2020 Inspection Number: 1152813 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Violation Citation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314753		HILTON MIAMI DOWNTOWN	
License Type: Hotel		1601 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 01/27/2020	Inspection Number: 1152873	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.	
License Number: 2316091		HOLIDAY INN DOWNTOWN PORT OF MIAMI	
License Type: Hotel		340 BISCAYNE BLVD, MIAMI 33132	
Inspection Date: 01/29/2020	Inspection Number: 1152864	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301669		VLEX 1450, LLC	
License Type: Apartment		1450 SW 3 ST, MIAMI 33135	
Inspection Date: 01/31/2020	Inspection Number: 1481504	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Stove hallway 1 st floor.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
07-01-4	Damaged electrical wire(s). For reporting purposes only. 1st and 2nd floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329381 HYDE SUITES MIDTOWN
 License Type: Hotel 3401 NE 1 AVE, MIAMI 33137

Inspection Date: 01/28/2020 Inspection Number: 1152352 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326984 CREST HOTEL SUITES
 License Type: Hotel 1666-1670 JAMES AVE, MIAMI BEACH 33139

Inspection Date: 01/29/2020 Inspection Number: 1152441 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2329435 KIMPTON HOTEL PALOMAR SOUTH BEACH
 License Type: Hotel 1750 ALTON RD, MIAMI BEACH 33139

Inspection Date: 01/29/2020 Inspection Number: 1152903 Inspection Type: Lodging-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	Observed: No boiler certificate or insurance inspector's boiler report available.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329050 CHATEAU, VERSAILLES, FONTAINEBLEAU FLORIDA TOWER II & III
 License Type: Hotel 4441 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 01/28/2020 Inspection Number: 1152621 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expiration date 9/25/19 for boilers jurisdiction 023063, 023064, 023068, 023045. Expiration date 1/15/16: 123334, 123333. Operator showed certificate	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307895 HARDING APARTMENTS
 License Type: Apartment 8250 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 01/31/2020 Inspection Number: 1471335 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light flashing. Fire alarm located by unit 12.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314382 RIVIERA TERR APARTMENTS
 License Type: Apartment 888 NE 132 STREET, MIAMI 33161

Inspection Date: 01/29/2020 Inspection Number: 1475047 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name:

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to apt 206, 303 and all extinguishers in parking garage.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326861 THE STAR BUILDING INC
 License Type: Apartment 12400 NE 12CT, NORTH MIAMI 33161

Inspection Date: 01/27/2020 Inspection Number: 1482251 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 3.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2319611 MIAMI SPRINGS INN
 License Type: Motel 4585 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 01/28/2020 Inspection Number: 1207044 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name:

Violation Code Observation

02-01-4 - From initial inspection : High Priority - Build-up of lint in the laundry room. Behind dryers of both laundry rooms. - From follow-up inspection 2020-01-28: Build-up of lint in the laundry room. Behind dryers of both laundry rooms. **Time Extended*

Violation Citation

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2326874 EXTENDED STAY AMERICA #9639
 License Type: Hotel 8720 NW 33RD ST, MIAMI 33172

Inspection Date: 01/27/2020 Inspection Number: 1152718 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

Violation Code Observation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed Extinguisher without braking device between units 164 and 166.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327849 CANDLEWOOD HOTEL
 License Type: Hotel 8855 NW 27 ST, MIAMI 33172

Inspection Date: 01/27/2020 Inspection Number: 1152609 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. Observed behind washers and dryers. **Repeat Violation**	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2327881 STAYBRIDGE SUITES MIAMI/DORAL
 License Type: Hotel 3265 NW 87 AVE, MIAMI 33172

Inspection Date: 01/28/2020 Inspection Number: 1153128 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. Observed behind dryers.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2311704 QUALITY INN SOUTH
 License Type: Motel 14501 S DIXIE HWY, MIAMI 331767988

Inspection Date: 01/30/2020 Inspection Number: 1208960 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. **Corrected On-Site** **Repeat Violation**	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2310422 BEST WESTERN WINDOR INN
 License Type: Motel 12210 BISCAYNE BLVD, NORTH MIAMI 33181

Inspection Date: 01/28/2020 Inspection Number: 1208781 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. Located in dryer. Maintenance cleaned. **Corrected On-Site**	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Dade County

License Number: 2309718

SANS SOUCI APTS

License Type: Apartment

1745 SAN SOUCI BLVD, NORTH MIAMI 331813258

Inspection Date: 01/31/2020

Inspection Number: 1468219

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located in front of apt 207, next to apt 107 and 101.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2601928 PARK PLACE
 License Type: Apartment 7514 HOGAN RD, JACKSONVILLE 32216

Inspection Date: 01/28/2020 Inspection Number: 1485284 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. Dryer lint traps #11,13,15,17 and 19. Person in charge cleaned dryer lint traps. **Corrected On-Site** **Repeat Violation**	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2612343 EXTENDED STAY AMERICA 1565
 License Type: Hotel 4699 LENOIR AVE S, JACKSONVILLE 32216

Inspection Date: 01/27/2020 Inspection Number: 1151737 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room. Person in charge cleaned dryer lint trap. **Corrected On-Site**	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 2608361 PARK SOUTH AT DEERWOOD
 License Type: Apartment 7932 SOUTHSIDE BLVD, JACKSONVILLE 32256

Inspection Date: 01/27/2020 Inspection Number: 1481700 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. No portable fire extinguisher present throughout complex.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613245 SHERATON JACKSONVILLE HOTEL
 License Type: Hotel 10605 DEERWOOD PARK BLVD, JACKSONVILLE 32256

Inspection Date: 01/27/2020 Inspection Number: 1151232 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate 09381 expired on 1-18-20.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700323

OSCEOLA RANCH MOTEL

License Type: Motel

4735 W MOBILE HWY, PENSACOLA 325063570

Inspection Date: 01/27/2020

Inspection Number: 1210676

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. In room 8 and 4. Fire Marshal notified.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. In room 8 electrical outlet by day door and under AC unit. Fire Marshal notified.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800991

RESIDENCE INN BY MARRIOTT SEBRING

License Type: Hotel

3221 TUBBS RD, SEBRING 33870

Inspection Date: 01/28/2020

Inspection Number: 1150750

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

05-04-4

High Priority - Insufficient number of hearing-impaired smoke detector(s) available. One hearing impaired smoke detector for each 50 guest rooms/units, or portion thereof, not provided (maximum of 5 hearing impaired smoke detectors required).

509.215(6) FS High Priority: Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in public lodging establishments at a rate of at least one such smoke detector per 50 dwelling units or portion thereof, not to exceed five such smoke detectors per public lodging facility.

Hillsborough County

License Number: 3902027

SHERATON TAMPA RIVERWALK

License Type: Hotel

200 N ASHLEY DR, TAMPA 33602

Inspection Date: 01/30/2020

Inspection Number: 1150404

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913645

ALOFT TAMPA DOWNTOWN

License Type: Hotel

100 W KENNEDY BLVD, TAMPA 33602

Inspection Date: 01/30/2020

Inspection Number: 1150309

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3905758

RODEWAY INN AND SUITES

License Type: Motel

2904 MELBOURNE BLVD, TAMPA 33605

Inspection Date: 01/31/2020

Inspection Number: 1210491

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

02-01-4 High Priority - Build-up of lint in the laundry room.

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 3910815

STARWOOD PROPERTY TRUST INC & SPT WAH WATERFORD LLC

License Type: Apartment

4733 W WATERS AVE, TAMPA 33614

Inspection Date: 01/30/2020

Inspection Number: 1481925

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

02-01-4 High Priority - Build-up of lint in the laundry room.

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Leon County

License Number: 4701568

LA CASA INN & SUITES

License Type: Motel

2801 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 01/27/2020

Inspection Number: 1208155

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

04-02-4 No smoke detector provided in guest room 105. Observed manager place smoke alarm in room. For reporting purposes only. **Corrected On-Site**

Violation Citation

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4702533

RESIDENCE INN TALLAHASSEE

License Type: Hotel

1880 RAYMOND DIEHL RD, TALLAHASSEE 32308

Inspection Date: 01/30/2020

Inspection Number: 1153652

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name:

Violation Code Observation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105023

ZOTA BEACH RESORT

License Type: Hotel

4711 GULF OF MEXICO DR, LONGBOAT KEY 34228

Inspection Date: 01/27/2020

Inspection Number: 1152888

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Showing system fault smoke alarm 5th floor room 535 north hotel. Operator was aware of system fault status

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603625

AMERICAN HOUSE BLUEWATER BAY

License Type: Apartment

4595 HWY 20 E, NICEVILLE 32578

Inspection Date: 01/27/2020

Inspection Number: 1484261

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
6/29/16 #130209 / 6/29/16 #130210

Violation Citation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801038

ECONOLOGDE

License Type: Motel

8700 S ORANGE BLOSSOM TRL, ORLANDO 32809

Inspection Date: 01/29/2020

Inspection Number: 1207101

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name:

Violation Code ObservationViolation Citation

05-01-4 High Priority - No hearing-impaired smoke detector(s) available. Operator unable to locate **Warning**

509.215(6) FS and 61C-1.004(8) FAC High Priority: 509.215(6) Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in public lodging establishments at a rate of at least one such smoke detector per 50 dwelling units or portion thereof, not to exceed five such smoke detectors per public lodging facility. 61C-1.004(8) Failure of the operator to inform any employee charged with registering guests of the location of such detector constitutes failure to make such detectors available.

License Number: 5811141

BAYMONT INN & SUITES

License Type: Hotel

8820 S ORANGE BLOSSOM TRL, ORLANDO 32809

Inspection Date: 01/29/2020

Inspection Number: 1151815

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805987

COLLEGIATE VILLAGE INN

License Type: Apartment

11850 UNIVERSITY BLVD, ORLANDO 328172146

Inspection Date: 01/29/2020

Inspection Number: 1472129

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808945 EXTENDED STAY AMERICA #9636
 License Type: Hotel 4101 EQUITY ROW, ORLANDO 32819

Inspection Date: 01/27/2020 Inspection Number: 1150841 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811106 SPRINGHILL SUITES ORLANDO AIRPORT
 License Type: Hotel 5828 HAZELTINE NATIONAL DR, ORLANDO 32822

Inspection Date: 01/30/2020 Inspection Number: 1151665 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Pinellas County

License Number: 6203665

ST PETE BEACH SUITES LLC

License Type: Apartment

6801 SUNSET WAY, ST.PETE BEACH 33706

Inspection Date: 01/27/2020

Inspection Number: 1481941

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

02-01-4 High Priority - Build-up of lint in the laundry room. Buildup of lint behind the dryer in guest laundry room.

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 6204087

ST PETE BEACH SUITES LLC

License Type: Apartment

610 69 AVE, ST.PETE BEACH 33706

Inspection Date: 01/27/2020

Inspection Number: 1481942

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

02-01-4 High Priority - Build-up of lint in the laundry room. Build up of lint behind facility dryer.

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 6205791

SUNRISE MOTEL

License Type: Motel

9630 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 01/30/2020

Inspection Number: 1208831

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code ObservationViolation Citation

02-01-4 High Priority - Build-up of lint in the laundry room. Buildup of lint in guest laundry room around dryer. **Repeat Violation**

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

02-08-4 Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. 3 tanks stored under rear stairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203632 SKYLARK MOTEL
 License Type: Motel 10149 GULF BLVD, TREASURE ISLAND 337064808

Inspection Date: 01/30/2020 Inspection Number: 1209151 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-02-4	Frayed electrical wire(s). For reporting purposes only. Fraying wire in light near unit 8.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215767 HILTON HOTEL ST PETE-CARILLON PARK
 License Type: Hotel 950 LAKE CARILLON DR, ST PETERSBURG 33716

Inspection Date: 01/27/2020 Inspection Number: 1149784 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - observed yellow 'trouble' light on panel illuminated Mapping disabled	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215830 FRANK R CHIVAS
 License Type: Apartment 309 S VENUS AVE, CLEARWATER 33755

Inspection Date: 01/29/2020 Inspection Number: 1477530 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside unit 4	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214166 EXTENDED STAY AMERICA #303
 License Type: Hotel 3089 EXECUTIVE DR, CLEARWATER 33762

Inspection Date: 01/27/2020 Inspection Number: 1150813 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 133822, expired 09/12/2018 - From follow-up inspection 2020-01-27: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201261 EITEL-SYNDER APARTMENTS
 License Type: Apartment 301 NIMBUS AVE S, CLEARWATER 33765

Inspection Date: 01/31/2020 Inspection Number: 1475976 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apartment 7	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6205273 BLUFF'S PLACE APARTMENTS
 License Type: Apartment 551- 563 MEHLENBACHER RD, BELLEAIR BLUFFS 33770

Inspection Date: 01/31/2020 Inspection Number: 1476085 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215776 INNISBROOK RESORT & GOLF CLUB
 License Type: Hotel 36750 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 01/30/2020 Inspection Number: 1152654 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-03-4	High Priority - The front desk clerk/person responsible for registering guests is unaware of the location of the hearing-impaired smoke detector(s).	61C-1.004(8) FAC High Priority: Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in transient public lodging establishments without charge. Failure of the operator to inform any employee charged with registering guests of the location of such detector constitutes failure to make such detectors available.

Polk County

License Number: 6309165		HILTON GARDEN INN LAKELAND	
License Type: Hotel		3839 DON EMERSON DR, LAKELAND 33811	
Inspection Date: 01/28/2020	Inspection Number: 1152402	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-01-4	High Priority - Build-up of lint in the laundry room. Observed under dryer on left side.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.	
License Number: 6308649		LAKE LENA MOTEL	
License Type: Motel		1802 US HWY 92 W, AUBURNDALE 33823	
Inspection Date: 01/27/2020	Inspection Number: 1209066	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-01-4	High Priority - No hearing-impaired smoke detector(s) available. **Warning**	509.215(6) FS and 61C-1.004(8) FAC High Priority: 509.215(6) Specialized smoke detectors for the deaf and hearing-impaired shall be made available upon request by guests in public lodging establishments at a rate of at least one such smoke detector per 50 dwelling units or portion thereof, not to exceed five such smoke detectors per public lodging facility. 61C-1.004(8) Failure of the operator to inform any employee charged with registering guests of the location of such detector constitutes failure to make such detectors available.	
License Number: 6301066		STAY INN & SUITES	
License Type: Motel		1035 N BROADWAY AVE, BARTOW 33830	
Inspection Date: 01/28/2020	Inspection Number: 1210034	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-01-4	High Priority - Build-up of lint in the laundry room. Behind dryers	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.	
License Number: 6301059		QUALITY INN	
License Type: Motel		44199 HIGHWAY 27, DAVENPORT 33897	
Inspection Date: 01/28/2020	Inspection Number: 1209764	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-01-4	High Priority - Build-up of lint in the laundry room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.	

Polk County

License Number: 6309189

WOODSPRING SUITES DAVENPORT

License Type: Hotel

141 BELLA CITTA BLVD, DAVENPORT 33897

Inspection Date: 01/31/2020

Inspection Number: 1151958

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name:

Violation Code Observation

Violation Citation

02-01-4 High Priority - Build-up of lint in the laundry room. ****Warning****

61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

Sarasota County

License Number: 6804704 HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75
 License Type: Hotel 5730 GANTT RD, SARASOTA 34233

Inspection Date: 01/29/2020 Inspection Number: 1150538 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-05-4	High Priority - Build-up of dirt/dust throughout boiler room.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.

License Number: 6800740 CADILLAC MOTEL
 License Type: Motel 4021 N TAMIAMI TRL, SARASOTA 34234

Inspection Date: 01/31/2020 Inspection Number: 1210705 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguisher from case between rooms 105 & 106 - From follo	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed missing fire extinguisher from case between rooms 105 & 106	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903310

TOWN CENTRE HARMONY HOUSING LLC

License Type: Apartment

100 WILLNER CIR, SANFORD 32771

Inspection Date: 01/27/2020

Inspection Number: 1488457

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name:

Violation Code Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 2, 9, and club house. Notified Mark James, Sanford Fire Inspector. 407-562-2786. - From follow-up inspection 2019-12-26

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4 - From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Club house. - From follow-up inspection 2019-12-26: - From follow-up inspection 2020-01-27:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602014

COLLEGE PARK APARTMENTS

License Type: Apartment

2703 VIRGINIA AVE, FORT PIERCE 34981

Inspection Date: 01/28/2020

Inspection Number: 1480362

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Middle building by apartment 10 and across from apartment 6

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405788 EXTENDED STAY AMERICA #1564
 License Type: Hotel 255 BILL FRANCE BLVD, DAYTONA BEACH 32114

Inspection Date: 01/28/2020 Inspection Number: 1152286 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Light on 4 zone communicator. Manager states light is on do to phone line and has called tech.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400051 DAYS INN SPEEDWAY
 License Type: Motel 2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 01/29/2020 Inspection Number: 1207167 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-06-4	High Priority - Flammable material stored in the meter room/attic/basement. Maintenance room next to room 130. Paint and boxes stored by electrical panels.	61C-1.004(6) FAC High Priority: Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables.