

Alachua County

License Number: 1102961 DRURY INN & SUITES- GAINESVILLE
 License Type: Hotel 4000 SW 40 BLVD, GAINESVILLE 32608

Inspection Date: 02/07/2020 Inspection Number: 1152266 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-06-4	Combustibles stored in boiler room. For reporting purposes only. Observed multiple pressurized tanks stored in the boiler room, behind the water storage tank. The maintenance staff is working on moving them to another location. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1101682 BOARDWALK APTS (THE)
 License Type: Apartment 2701 SW 13 ST, GAINESVILLE 326082084

Inspection Date: 02/04/2020 Inspection Number: 1470032 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed the office fire extinguisher indicator in the recharge zone. It was replaced. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1603263 VICTORIA VILLAGE LLC
 License Type: Apartment 921 NE 17 AVE, FORT LAUDERDALE 33304

Inspection Date: 02/05/2020 Inspection Number: 1488879 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 925 between Apts 3 and 4.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600892 SKY ISLANDS
 License Type: Motel 4117 N OCEAN BLVD, FORT LAUDERDALE 33308

Inspection Date: 02/07/2020 Inspection Number: 1207911 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DEJONG, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. Strobe / flash not working. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621452 OXFORD MEADOWS LLC
 License Type: Apartment 1351 SE 3RD ST, DEERFIELD BEACH 33441

Inspection Date: 02/03/2020 Inspection Number: 1486298 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PINEROS, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near apartment #1 first floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000955

INTOWN SUITES

License Type: Hotel

442 BLANDING BLVD, ORANGE PARK 32065

Inspection Date: 02/04/2020

Inspection Number: 1149957

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. One in guest laundry

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302246 JORGE AMIN AYAD
 License Type: Apartment 60 WEST 11 STREET, HIALEAH 33010

Inspection Date: 02/03/2020 Inspection Number: 1476160 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By unit 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330122 VISTA GARDENS LLC
 License Type: Apartment 4740 NW 7 AVE, MIAMI 33127

Inspection Date: 02/06/2020 Inspection Number: 1484180 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to unit one.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307062 PROSPERIDAD RENTALS LLC
 License Type: Apartment 945 NW 1 ST, MIAMI 33128

Inspection Date: 02/04/2020 Inspection Number: 1487138 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device on fire extinguisher box located at west wing of building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320752 CITY VIEW APARTMENTS MGMT LLC
 License Type: Apartment 933 NW 4 ST, MIAMI 33128

Inspection Date: 02/06/2020 Inspection Number: 1479222 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing from designated area located next to apartment 505.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device next to unit 101.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329295 LH FERNANDO LLC
 License Type: Apartment 901 SW 5 ST, MIAMI 33130

Inspection Date: 02/06/2020 Inspection Number: 1488933 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed all fire extinguishers in building locked with no means of access.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301681 ORANGE APTS
 License Type: Apartment 820 SW 11 AVE, MIAMI 331303600

Inspection Date: 02/05/2020 Inspection Number: 1468340 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire panel next to unit two, trouble light illuminated. **Repeat Violation** **Warning**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301243 LOVERA ENTERPRISE
 License Type: Apartment 1449 SW 4 ST, MIAMI 33135

Inspection Date: 02/04/2020 Inspection Number: 1485180 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Mattress on hallway 1 st floor.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329143 5475 MIAMI LLC
 License Type: Apartment 5475 NE 1 AVE, MIAMI 33137

Inspection Date: 02/06/2020 Inspection Number: 1480365 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By units 1 & 3	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329480 NORTH BEACH UNITED LLC
 License Type: Apartment 1995 BAY DR, MIAMI BEACH 33141

Inspection Date: 02/03/2020 Inspection Number: 1484686 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher located in laundry room in need of recharging.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300055 BP HARBOR SOUTH LLC
 License Type: Apartment 1075 101 ST, BAY HARBOR ISLANDS 33154

Inspection Date: 02/04/2020 Inspection Number: 1480774 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed fire alarm emitting audible alarm (fire alarm located in a contiguous room to the laundry) building located on the north side (last building)	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2302556 HARVARD HOUSE LLC
 License Type: Apartment 2020 NE 169 ST, NORTH MIAMI BEACH 33162

Inspection Date: 02/03/2020 Inspection Number: 1478440 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on 1st floor FE with no glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312162 PARK PLAZA
 License Type: Apartment 17600 NW 5TH AVE, MIAMI 33169

Inspection Date: 02/04/2020 Inspection Number: 1488888 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed in apartment unit #615, the electrical breaker boxes is tripping. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2309718 SANS SOUCI APTS
 License Type: Apartment 1745 SAN SOUCI BLVD, NORTH MIAMI 331813258

Inspection Date: 01/31/2020 Inspection Number: 1468219 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located in front of apt 207, next to apt 107 and 101.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613256

HOMEWOOD SUITES BY HILTON JACKSONVILLE DOWNTOWN SOUTHBANK

License Type: Hotel

1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 02/04/2020

Inspection Number: 1151496

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: ARMSTRONG, RICO

Violation Code ObservationViolation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2020-02-04: Boiler certificates available.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2020-02-04: Boiler certificates available inside boiler room.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2601080

CHELSEA COURTYARDS APARTMENTS

License Type: Apartment

2260 UNIVERSITY BLVD N, JACKSONVILLE 32211

Inspection Date: 02/03/2020

Inspection Number: 1480248

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code ObservationViolation Citation

01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Missing fire extinguishers at unit 39, 55, and C93.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

Duval County

License Number: 2600178 CASTILLE COURT APARTMENTS
 License Type: Apartment 1811 ROGERO RD #207 OFFIC, JACKSONVILLE 322114150

Inspection Date: 02/03/2020 Inspection Number: 1473225 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Propane tank stored under the stairway on building 7 near apt 701	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608439 GOLD RUSH MOTEL
 License Type: Motel 10885 HARTS RD, JACKSONVILLE 32218

Inspection Date: 02/04/2020 Inspection Number: 1208083 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. No smoke detector located in room 114	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2610725 HAWTHORN SUITES
 License Type: Hotel 8737 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 02/05/2020 Inspection Number: 1151306 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Two LP gas tank more then 2.7 pounds stored inside housekeeping area in building. Manager stated they will be removed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912546

CLIPPER COVE APARTMENTS

License Type: Apartment

7009 INTERBAY BLVD, TAMPA 33616

Inspection Date: 02/03/2020

Inspection Number: 1473721

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4702533

RESIDENCE INN TALLAHASSEE

License Type: Hotel

1880 RAYMOND DIEHL RD, TALLAHASSEE 32308

Inspection Date: 01/30/2020

Inspection Number: 1153652

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: TRUESDALE, CHRIS

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 02/03/2020

Inspection Number: 1153652

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Complied

Inspector Name: TRUESDALE, CHRIS

Violation Code Observation

Violation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2020-02-03: Boiler certificate or insurance inspector's boiler report expired. Per the manager, appointment has been set with boiler inspector **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5103072

HOLIDAY INN EXPRESS & SUITES BRADENTON WEST

License Type: Hotel

4450 47 ST W, BRADENTON 34210

Inspection Date: 02/07/2020

Inspection Number: 1152653

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200088

SILVER SPRINGS BUDGET MOTEL

License Type: Motel

4121 E SILVER SPGS BLVD, OCALA 344705003

Inspection Date: 02/04/2020

Inspection Number: 1209305

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Light flashing. No sounds.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809180

HILTON GARDEN INN ORLANDO AIRP

License Type: Hotel

7300 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 02/07/2020

Inspection Number: 1151429

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation Code

Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available, for FI 124222,. For reporting purposes only. **Corrected On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5901202

QUALITY INN MAINGATE

License Type: Motel

2945 ENTRY POINT BLVD, KISSIMMEE 34747

Inspection Date: 02/06/2020

Inspection Number: 1208448

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ system trouble **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6008599

LAQUINTA INN

License Type: Motel

34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 02/04/2020

Inspection Number: 1210750

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation

04-03-4 Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.#116, #201.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4 Electrical outlet damaged to indicate a malfunction. For reporting purposes only.2nd floor/hallway.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009310

BELL BOCA TOWN CENTER

License Type: Apartment

5881 TOWN BAY DR, BOCA RATON 33486

Inspection Date: 02/06/2020

Inspection Number: 1482355

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: TORRES, LARRY

Violation Code ObservationViolation Citation

01-03-4 - From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By apt 10-17 in building 5880. - From follow-up inspection 2020-02-06:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209700

QUALITY INN & SUITES

License Type: Motel

3655 HOSPITALITY LN, CLEARWATER 33762

Inspection Date: 02/06/2020

Inspection Number: 1210766

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WAGNER, MARGARET

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Repair scheduled to install hi limit manual reset valve, follow up inspection to be conducted by fire marshal **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204939

BELLEAIR BLUFFS APTS

License Type: Apartment

2889 LOS ALTOS BLVD, BELLEAIR BLUFFS 337701359

Inspection Date: 02/01/2020

Inspection Number: 1472335

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.
Could not located fire extinguishers.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6309210

LAKELAND MANOR

License Type: Apartment

929 GILMORE AVE, LAKELAND 33801

Inspection Date: 02/05/2020

Inspection Number: 1486560

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BEAULIEU, STEPHANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit 197 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By unit 102, 142, 146, 43,	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 02/03/2020

Inspection Number: 1150588

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: VITKUN, RONALD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed boiler certificate expired 3/16/2019

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501417

HOLIDAY INN ST AUGUSTINE-WORLD GOLF VILLAGE

License Type: Hotel

475 COMMERCE LAKE DR, SAINT AUGUSTINE 32095

Inspection Date: 02/05/2020

Inspection Number: 1153670

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Expired boiler certificate : 1/16/19

Per person in charge : boiler inspection last week. Waiting for Paperwork.

Priority: Reporting **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602547 652 HERNANDO STREET APARTMENTS
License Type: Apartment 652 HERNANDO ST, FORT PIERCE 34949

Inspection Date: 02/05/2020 Inspection Number: 1477813 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
Inspector Name: HARROD, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6600732 COURTYARD MARRIOTT
License Type: Hotel 10978 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 02/04/2020 Inspection Number: 1151877 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. 3 lp tanks in downstairs hallway.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406564 ZAPPIS ITALIAN GARDEN
 License Type: Apartment 128 S BEACH ST, DAYTONA BEACH 32114

Inspection Date: 02/06/2020 Inspection Number: 1479555 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System trouble ,system silence - From follow-up inspection 2020-01-06: Manager states tech has come out to look at panel and coming back to look at strobe horn. - From follow-up inspection 2020-02-06: Trouble and silenced light. Manager states it a short in a flasher. Viewed invoice 1/13/20 for replacement of fire alarm panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405509 GRANDVIEW MANOR
 License Type: Apartment 919 N GRANDVIEW AVE, DAYTONA BEACH 32118

Inspection Date: 02/06/2020 Inspection Number: 1478566 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. By apartment 2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-01-4	Stairs blocked by garden furniture by apartment 5. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Spot light by apartment 4 in disrepair.For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.