

Brevard County

License Number: 1505666

RESIDENCE INN CAPE CANAVERAL

License Type: Hotel

8959 ASTRONAUT BLVD, CAPE CANAVERAL 32920

Inspection Date: 02/12/2020

Inspection Number: 1151518

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. For 121980 and 121981 missing.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1612710 ATLANTIC INN MOTEL
 License Type: Motel 151 NW 17 AVE, POMPANO BEACH 33069-2813

Inspection Date: 02/10/2020 Inspection Number: 1206966 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BURGGRABE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to room 115 and 109.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1604893 SOUTH BANK APTS
 License Type: Apartment 601 N RIO VISTA BLVD, FORT LAUDERDALE 33301-2923

Inspection Date: 02/12/2020 Inspection Number: 1470255 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. First floor stairs by Apt 116. Inspector will email this inspection report to Fire Marshall Jeff Lucas. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Panel by mailboxes. Inspector will email this inspection report to Fire Marshall Jeff Lucas. **Corrective Action Taken**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621228 OCEANSIDE MIST LLC
 License Type: Apartment 4209 - 4215 SEAGRAPE DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 02/14/2020 Inspection Number: 1481037 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: DEJONG, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. Propane BBQ grill in covered area by pool. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619308 SOMERSET III
 License Type: Apartment 2790 SOMERSET DR #100, LAUDERDALE LAKES 33311

Inspection Date: 02/10/2020 Inspection Number: 1468070 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. FE at building 2820 1st floor by trash room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. FE missing from box located in building 2820 apt 108	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612833 SOMERSET PHASE V
 License Type: Apartment 2725 SOMERSET DR, LAUDERDALE LAKES 33311-2748

Inspection Date: 02/10/2020 Inspection Number: 1474402 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At fire extinguisher on the 2nd floor at building 2720 by elevator.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Exit sign at building 2720 apt 200 - missing	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603518 LENOX APT 9
 License Type: Apartment 2312 NW 9 ST, FORT LAUDERDALE 33311-6876

Inspection Date: 02/14/2020 Inspection Number: 1470221 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Building 2304 (16) by apt 2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620877

CHATEAU MAR GOLF RESORT

License Type: Hotel

3501 INVERRARY BLVD, LAUDERHILL 33319

Inspection Date: 02/07/2020

Inspection Number: 1151368

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEWIS, LYNDEN

Violation Code Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000920 STAY SUITES OF AMERICA
 License Type: Hotel 1656 WELLS RD, ORANGE PARK 32073

Inspection Date: 02/11/2020 Inspection Number: 1150090 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 9/16/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001053 LISA DAWN APARTMENTS
 License Type: Apartment 1425 SMITH ST, ORANGE PARK 32073

Inspection Date: 02/11/2020 Inspection Number: 1484821 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BIAVA, GRANT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. At building 1436	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308279 JOHNSON APTS
 License Type: Apartment 5000 NW 2 AVE, MIAMI 331272176

Inspection Date: 02/11/2020 Inspection Number: 1471490 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed no fire extinguisher at designated location/box located at the 1st and 2nd floors of apartment complex. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2308516 FRANCISCO APTS
 License Type: Apartment 2751 NW 7 AVE, MIAMI 331274000

Inspection Date: 02/13/2020 Inspection Number: 1471134 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, RAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at all fire extinguisher stations no device present to break glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312900 AUROSA BLDG
 License Type: Apartment 1144 NW 5 ST, MIAMI 331281049

Inspection Date: 02/10/2020 Inspection Number: 1470912 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located at the first floor next to laundry and meter room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313598 PEREZ APT
 License Type: Apartment 980 NW 2 ST, MIAMI 331281250

Inspection Date: 02/11/2020 Inspection Number: 1468882 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device on fire extinguisher located 1st and 2nd floors.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311712		TRIPOLI APTS	
License Type: Apartment		842 NW 3 ST, MIAMI 331281329	
Inspection Date: 02/12/2020	Inspection Number: 1468714	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2319491		851 NW 1 ST	
License Type: Apartment		851 NW 1 ST, MIAMI 331281340	
Inspection Date: 02/12/2020	Inspection Number: 1470977	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device on fire extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305847		BEACHFRONT HOLDINGS GROUP INC	
License Type: Apartment		835 SW 3 ST, MIAMI 33130	
Inspection Date: 02/10/2020	Inspection Number: 1486923	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to unit #2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308798		SUNSHINE INN OF MIAMI LLC	
License Type: Motel		4871 W FLAGLER ST, CORAL GABLES 33134	
Inspection Date: 02/12/2020	Inspection Number: 1207483	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. By unit 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329286		VINTRO HOTEL	
License Type: Hotel		2216 PARK AVE, MIAMI BEACH 33139	
Inspection Date: 02/12/2020	Inspection Number: 1151360	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2020-02-12: Observed alarm/trouble light illuminated. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329303		1 HOTEL SOUTH BEACH	
License Type: Hotel		2341 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 02/13/2020	Inspection Number: 1152361	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PRIETO, VICENTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328846		FRANIL MORALES	
License Type: Apartment		7332 BYRON AVE, NORTH BAY VILLAGE 33141	
Inspection Date: 02/10/2020	Inspection Number: 1475538	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between units 2 and 3/4/5. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329180		RITZ CARLTON BAL HARBOUR	
License Type: Hotel		10295 COLLINS AVE, BAL HARBOUR 33154	
Inspection Date: 02/12/2020	Inspection Number: 1151813	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2324615 SOUTH POINTE APTS
 License Type: Apartment 17842 SW 107 AVENUE, MIAMI 33157

Inspection Date: 02/11/2020 Inspection Number: 1474359 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 3 located in front of the laundry on building 17820. By unit 2 located on building 17810.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328335 GOLDEN ASSOCIATES LTD HIDDEN C
 License Type: Apartment 1030 NW 155 LN, MIAMI 33169

Inspection Date: 02/13/2020 Inspection Number: 1473203 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed fire panel glass missing, next to apartments #206, and 205.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313331 REBECCA'S VILLAGE
 License Type: Apartment 10953 SW 4 ST, SWEETWATER 331741356

Inspection Date: 02/11/2020 Inspection Number: 1470965 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher between units 2 and 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324350 SUN POINT RENTALS
 License Type: Apartment 11180 SW 107 ST, MIAMI 331768269

Inspection Date: 02/11/2020 Inspection Number: 1473749 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 102, 112, 305, 307, 107,	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328934

RESIDENCE INN AT AVENTURA MALL

License Type: Hotel

19900 W COUNTRY CLUB DR, AVENTURA 33180

Inspection Date: 02/11/2020

Inspection Number: 1152395

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Due to maintenance.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603661		TRAVELODGE INN & SUITES	
License Type: Motel		1153 AIRPORT RD, JACKSONVILLE 32218	
Inspection Date: 02/11/2020	Inspection Number: 1210802	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 412	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2609105		PALMS AT BEACON POINT	
License Type: Apartment		1251 BEACON DR, JACKSONVILLE 32246	
Inspection Date: 02/12/2020	Inspection Number: 1488931	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2612691		INTOWN SUITES	
License Type: Motel		11451 BEACH BLVD, JACKSONVILLE 32246	
Inspection Date: 02/13/2020	Inspection Number: 1206890	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. No certificate available for boiler jurisdiction number 133181. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2612297		EXTENDED STAY AMERICA	
License Type: Hotel		8300 WESTERN WAY, JACKSONVILLE 32256	
Inspection Date: 02/11/2020	Inspection Number: 1151080	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: VILBRUN, JOSUE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. No boiler certificate during inspection. Maintenance advise building is possibly switching to water heater instead and waiting for process. Boiler sticker on unit states last inspection was conducted in 2010	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Hillsborough County

License Number: 3901297

ALASKA MOTEL

License Type: Motel

1307 E HILLSBOROUGH AVE, TAMPA 336047209

Inspection Date: 02/12/2020

Inspection Number: 1210793

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARQUETTI, JESSICA

Violation Code Observation

Violation Citation

04-02-4 No smoke detector provided in guest room/unit. For reporting purposes only.
Unit 5

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200088

SILVER SPRINGS BUDGET MOTEL

License Type: Motel

4121 E SILVER SPGS BLVD, OCALA 344705003

Inspection Date: 02/13/2020

Inspection Number: 1209305

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Light flashing. No sounds. - From follow-up inspection 2020-02-13: No change. **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401622 THE REACH KEY WEST CURIO COLLECTION BY HILTON
 License Type: Hotel 1435 SIMONTON ST, KEY WEST 33040

Inspection Date: 02/12/2020 Inspection Number: 1153316 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MECK, PAMELA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Observed Boiler Jurisdiction #134286 Expiration 2/2/2020.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inpector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5402819 HYATT WINDWARD POINTE
 License Type: Hotel 3675 S ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 02/11/2020 Inspection Number: 1152800 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MECK, PAMELA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Fire Alarm panel trouble light for Building 5/6.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801847		QUALITY INN AND SUITES	
License Type: Hotel		626 LEE RD, ORLANDO 32810	
Inspection Date: 02/11/2020	Inspection Number: 1150465	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809318		STAYBRIDGE SUITES ORLANDO AIRPORT	
License Type: Hotel		7450 AUGUSTA NATIONAL DR, ORLANDO 32822	
Inspection Date: 02/13/2020	Inspection Number: 1151691	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809011		HOMETOWNE STUDIOS ORLANDO UCF AREA 3513	
License Type: Hotel		12350 E COLONIAL DR, ORLANDO 32826	
Inspection Date: 02/11/2020	Inspection Number: 1150604	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System is in trouble - From follow-up inspection 2020-02-11: System is in trouble **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5800360		BEST WESTERN LAKE BUENA VISTA RESORT HOTEL	
License Type: Hotel		2000 HOTEL PLAZA BLVD, LAKE BUENA VISTA 32830	
Inspection Date: 02/10/2020	Inspection Number: 1152530	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certification expired 12/4/2019 General Manager notify corporate office. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5900021 FLAMINGO WATERPARK RESORT
 License Type: Motel 2261 E IRLO BRONSON HWY, KISSIMMEE 34744

Inspection Date: 02/13/2020 Inspection Number: 1207236 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./system trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5900523 LAKESIDE TERRACE INN AND SUITES
 License Type: Motel 4880 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 01/08/2020 Inspection Number: 1210824 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Observed: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Priority: Reporting	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4	Observed: Fire alarm control panel emitting an audible alarm. For reporting purposes only. Priority: Reporting	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-07-4	Observed: Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Priority: Reporting	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900286

RED LION HOTELS - KISSIMMEE MAINGATE

License Type: Motel

7300 W IRLO BRONSON HWY, KISSIMMEE 34747

Inspection Date: 02/11/2020

Inspection Number: 1208963

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6000238

EL CID APARTMENT

License Type: Apartment

315 ALMERIA RD, WEST PALM BEACH 33405

Inspection Date: 02/12/2020

Inspection Number: 1475787

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SINGH, GAJENDRA

Violation Code Observation

Violation Citation

08-03-4 - From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2020-02-12: Same **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201864		SOUTHERN OAKS LLC	
License Type: Apartment		1200 NE BEACH DR, ST PETERSBURG 337011458	
Inspection Date: 02/10/2020	Inspection Number: 1469658	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WAGNER, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. - ground floor: under stairwell outside unit 7	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6201014		MADEIRA APARTMENTS	
License Type: Apartment		7533 38 AVE N, ST. PETERSBURG 33710	
Inspection Date: 02/10/2020	Inspection Number: 1488770	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No striker hammer on fire extinguisher case building 3935 upstairs. - From follow-up inspection 2020-01-13: **Time Extended** - From follow-up inspection 2020-02-10: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6201348		LEBCAR PROPERTIES LLC	
License Type: Apartment		1270 SANTA ROSA ST, CLEARWATER 33756	
Inspection Date: 02/14/2020	Inspection Number: 1479055	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PEARCE, LAURA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.near apartment 3	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6201831		MAGNUSON HOTEL CLEARWATER BEACH	
License Type: Motel		421 S GULFVIEW BLVD, CLEARWATER BEACH 33767	
Inspection Date: 02/14/2020	Inspection Number: 1210425	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 117.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Sarasota County

License Number: 6800278

SANDCASTLE RESORT AT LIDO BEACH

License Type: Hotel

1540 BEN FRANKLIN DR, SARASOTA 34236

Inspection Date: 02/14/2020

Inspection Number: 1150240

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VITKUN, RONALD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed boiler certificate expired 05/13/2018.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.