

Brevard County

License Number: 1500863

AMERICA'S BEST VALUE INN

License Type: Motel

3220 N COCOA BLVD, COCOA 329266699

Inspection Date: 03/03/2020

Inspection Number: 1210857

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In hall outside guest laundry 2nd floor. Maintenance states they have extinguisher but new box on order ****Corrective Action Taken**** - From follow-up inspection 2020-03-03: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In hall outside guest laundry 2nd floor. Maintenance states they have extinguisher but new box on order ****Corrective Action Taken**** - From follow-up inspection 2020-03-03: ****Time Extended**** - From follow-up inspection 2020-03-05: ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620747

EXTENDED STAY AMERICA #869

License Type: Hotel

5851 N ANDREWS AVE EXT, FORT LAUDERDALE 33309

Inspection Date: 03/02/2020

Inspection Number: 1152728

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617319

COURTYARD MARRIOTT

License Type: Hotel

440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 03/05/2020

Inspection Number: 1151576

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620877

CHATEAU MAR GOLF RESORT

License Type: Hotel

3501 INVERRARY BLVD, LAUDERHILL 33319

Inspection Date: 02/28/2020

Inspection Number: 1153784

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEWIS, LYNDEN

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Repeat Violation61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618409

EXTENDED STAY AMERICA #328

License Type: Hotel

1200 FAU RESEARCH PARK BLVD, DEERFIELD BEACH 33441

Inspection Date: 03/04/2020

Inspection Number: 1153020

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRABE, BROCK

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000955

INTOWN SUITES

License Type: Hotel

442 BLANDING BLVD, ORANGE PARK 32065

Inspection Date: 03/05/2020

Inspection Number: 1149957

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. One in guest laundry - From follow-up inspection 2020-03-05: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305839		MAYTIN APARTMENTS	
License Type: Apartment		39 W 27 ST, HIALEAH 330101740	
Inspection Date: 03/05/2020	Inspection Number: 1473376	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 3. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310944		REBECA APARTMENTS	
License Type: Apartment		718 SE 8 ST, HIALEAH 330105654	
Inspection Date: 03/03/2020	Inspection Number: 1470920	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking device located between units 2 and 3, between units 4 and 5, between units 11 and 12, and between units 14 and 15. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2318025		SOLON APARTMENTS	
License Type: Apartment		1045 SE 9 AVE, HIALEAH 330105841	
Inspection Date: 03/03/2020	Inspection Number: 1468912	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed extinguisher in front of unit 2, by meter room in back yard.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304761		NEXX MOTEL	
License Type: Motel		841 N KROME AVE, HOMESTEAD 33030	
Inspection Date: 03/03/2020	Inspection Number: 1209171	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Observed alarm panel silenced. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329433 1360 SHARAZAD BLVD
 License Type: Apartment 1360 SHARAZAD BLV, OPA LOCKA 33054

Inspection Date: 03/05/2020 Inspection Number: 1485130 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILCHEZ, NABEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher located on building B second floor. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301814 KILZI BROS & SONS LLC
 License Type: Apartment 2345 Nw FLAGLER TERR, MIAMI 33125

Inspection Date: 03/03/2020 Inspection Number: 1485062 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apartment #5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313496 RIVERLAND APTS
 License Type: Apartment 2138 NW FLAGLER TERR, MIAMI 331255343

Inspection Date: 03/03/2020 Inspection Number: 1468879 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTIN, RAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment number 5	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309730		CORALVITA APTS	
License Type: Apartment		3051 SW 3 AVE, MIAMI 331292700	
Inspection Date: 03/02/2020	Inspection Number: 1471504	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301735		1818 APTS	
License Type: Apartment		1818 SW 9 ST, MIAMI 33135	
Inspection Date: 03/02/2020	Inspection Number: 1479380	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328257		BAHIA APARTMENTS LLC	
License Type: Apartment		1201 NW 2 AVE, MIAMI 33136	
Inspection Date: 02/29/2020	Inspection Number: 1479936	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By units 1 and 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2307487		1311 APARTMENTS	
License Type: Apartment		1311 NW 2 AVE, MIAMI 331362667	
Inspection Date: 02/29/2020	Inspection Number: 1468528	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By unit 1.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301027		MORGAN APTS	
License Type: Apartment		1155 NW 2 AVE, MIAMI 331362751	
Inspection Date: 02/29/2020	Inspection Number: 1468258	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Both fire extinguishers, first and second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2310222		DESIGN PLACE	
License Type: Apartment		5135 NE 2 AVE, MIAMI 331372832	
Inspection Date: 03/03/2020	Inspection Number: 1473030	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on in 5140.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328390		SAGAMORE MIAMI BEACH	
License Type: Hotel		1671 COLLINS AVE, MIAMI BEACH 33139	
Inspection Date: 03/06/2020	Inspection Number: 1151669	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329247

GALE SOUTH BEACH/ REGENT HOTEL

License Type: Hotel

1690 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/05/2020

Inspection Number: 1151571

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329251

PESTANA SOUTH BEACH HOTEL

License Type: Hotel

1817 JAMES AVE, MIAMI BEACH 33139

Inspection Date: 03/05/2020

Inspection Number: 1152074

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329306

HYATT CENTRIC SOUTH BEACH

License Type: Hotel

1600 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 03/02/2020

Inspection Number: 1151537

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329378

TRYP BY WYNDHAM MIAMI BAY HARBOR

License Type: Hotel

9540 W BAY HARBOR DR, BAY HARBOR ISLANDS 33154

Inspection Date: 03/05/2020

Inspection Number: 1151456

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed 2 boilers on premises without boiler certificate. - From follow-up inspection 2020-03-05: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613249

TOWNEPLACE SUITES

License Type: Hotel

4801 LENOIR AVE, JACKSONVILLE 32216

Inspection Date: 03/04/2020

Inspection Number: 1152804

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ARMSTRONG, RICO

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
099964 10/23/19
099966 10/23/19 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702477

OAK RIDGE APARTMENTS

License Type: Apartment

7201 BRUNER ST, PENSACOLA 32526

Inspection Date: 03/05/2020

Inspection Number: 1489167

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUSSELL, SARAH

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Multiple extinguishers missing around property.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901979

QUALITY INN

License Type: Hotel

2701 E FOWLER AVE, TAMPA 33612

Inspection Date: 03/02/2020

Inspection Number: 1150229

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.
Operator placed in boiler room. **Corrected On-Site**61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913624

HOLIDAY INN EXPRESS AND SUITES BUSCH GARDENS AND USF

License Type: Hotel

2807 BUSCH BLVD, TAMPA 33612

Inspection Date: 03/05/2020

Inspection Number: 1151293

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 03/05/2020

Inspection Number: 1152849

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MAIO, BRENNNA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 10/24/2019, boiler inspection has been scheduled **Corrective Action Taken**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604656

LAGO DEL SOL APARTMENTS

License Type: Apartment

10770 CLEAR LAKE LOOP, FORT MYERS 33908

Inspection Date: 03/05/2020

Inspection Number: 1489150

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguishers present on the premises. For reporting purposes only. Building 15061, 15081, 15101.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

Damaged electrical wire(s). Observed emergency lights detached middle stairway 2nd/3rd floor, Building 15061. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200211

STEVENS MOTEL

License Type: Motel

3231 S PINE AVE, OCALA 344716617

Inspection Date: 03/02/2020

Inspection Number: 1206378

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.
 Inside laundry. Removed. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402225

COCONUT COVE RESORT & MARINA

License Type: Motel

84801 OLD HWY, ISLAMORADA 330363417

Inspection Date: 03/05/2020

Inspection Number: 1210909

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
No Smoke detector in unit 1509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5401502

OCEAN KEY RESORT

License Type: Hotel

ZERO DUVAL ST, KEY WEST 33040

Inspection Date: 03/06/2020

Inspection Number: 1152640

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403189

WICKER GUESTHOUSE

License Type: Hotel

913 DUVAL ST, KEY WEST 33040

Inspection Date: 03/03/2020

Inspection Number: 1153013

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Laundry room area face plate missing on outlet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811128 KATERINA HOTEL ORLANDO
 License Type: Hotel 830 LEE RD, ORLANDO 32810

Inspection Date: 03/04/2020 Inspection Number: 1153771 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2020-03-04: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2020-03-04: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807918 THE ROSEN CENTRE HOTEL
 License Type: Hotel 9840 INTERNATIONAL DR, ORLANDO 328198122

Inspection Date: 03/03/2020 Inspection Number: 1153820 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900879 THE GRAND ORLANDO RESORT AT CELEBRATION
 License Type: Hotel 2900 PKWY BLVD, KISSIMMEE 34747

Inspection Date: 03/06/2020 Inspection Number: 1153811 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ observed trouble at main fire panel	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5912071 MARGARITAVILLE RESORT ORLANDO
 License Type: Hotel 8000 FINS UP CIR, KISSIMMEE 34747

Inspection Date: 03/05/2020 Inspection Number: 1152487 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LORENZO, ANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ SYSTEM TROUBLE	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014065

WEST PALM BEACH INVESTMENT GROUP INC

License Type: Hotel

923 8 ST, WEST PALM BEACH 33401

Inspection Date: 03/02/2020

Inspection Number: 1152664

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.
Operator called for service.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6011587

HAMPTON INN BOCA RATON

License Type: Hotel

1455 YAMATO RD, BOCA RATON 33431

Inspection Date: 03/02/2020

Inspection Number: 1153320

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KHATOON, BEGUM

Violation CodeObservationViolation Citation

04-02-4

Red light smoke detector provided in guest room/unit at room 402. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215802

WOODSPRING SUITES CLEARWATER

License Type: Hotel

15672 US HWY 19 N, CLEARWATER 33764

Inspection Date: 03/04/2020

Inspection Number: 1151247

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. 001 Supervisory Smoke Detector Guest Rm 322. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6308644

LAKEVIEW MOTEL

License Type: Motel

1539 E MEMORIAL BLVD, LAKELAND 33801

Inspection Date: 03/03/2020

Inspection Number: 1209267

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 33 smoke alarm removed.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.