

Alachua County

License Number: 1103016

LYNCOURT SQUARE APTS

License Type: Apartment

1218 SW 3 AVE, GAINESVILLE 32601

Inspection Date: 04/20/2020

Inspection Number: 1481676

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Outlet in scooter parking area partially detached with visible wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103047

THE NINE AT GAINESVILLE

License Type: Apartment

1245 SW 11 AVE, GAINESVILLE 32601

Inspection Date: 04/22/2020

Inspection Number: 1489337

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Extinguisher across from 222 is missing handle for case.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Trouble light on the alarm panel. Per Manager alarm company is trying to locate malfunctioning strobe. **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1615411		SHERIDAN OCEAN CLUB	
License Type: Apartment		1155 SE 7 AVE, DANIA BEACH 33004	
Inspection Date: 04/22/2020	Inspection Number: 1485082	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	- From initial inspection : Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. North side of balcony facing tennis court. Building #13. - From follow-up inspection 2020-04-22: Observed same **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1603577		HARRIS MOTELS	
License Type: Motel		5724 PEMBROKE RD, WEST PARK 33023-2338	
Inspection Date: 04/23/2020	Inspection Number: 1209586	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 11.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1620854		SOLANO AT MIRAMAR	
License Type: Apartment		11700 SW 26 ST, MIRAMAR 33025	
Inspection Date: 04/23/2020	Inspection Number: 1484711	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SMITH, CORETTA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. Observed on balcony at apartment 11851. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1607675

INVERRARY GARDENS

License Type: Apartment

4200 INVERRARY BLVD, LAUDERHILL 33319

Inspection Date: 04/21/2020

Inspection Number: 1474692

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
At building 4222 apt 4715

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
FE at building 4212 at apt 86 is detached from the wall. Stored on the floor by the mailbox.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200234

SUNDIAL APARTMENTS

License Type: Apartment

200 SE SUNDIAL PL, LAKE CITY 32055

Inspection Date: 04/21/2020

Inspection Number: 1470472

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front of room 223.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312153

DELGADO & PEREZ INVESTMENT LLC

License Type: Apartment

65 NW 8 ST, HOMESTEAD 33030

Inspection Date: 04/24/2020

Inspection Number: 1478597

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher second floor with broken glass.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304734

NOELA APARTMENTS LLC

License Type: Apartment

3633 NW 9 ST, MIAMI 33125

Inspection Date: 04/20/2020

Inspection Number: 1481086

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by apartments #6, and #10 (1st floor), and #21 (2nd floor). **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301202

BEACHFRONT HOLDINGS GROUP INC

License Type: Apartment

120 NW 7 AVE, MIAMI 33130

Inspection Date: 04/22/2020

Inspection Number: 1489441

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. By drive way and a/c unit next to apartment 6 **Repeat Violation** **Admin Complaint**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

06-02-4

Door marked as an exit is blocked. For reporting purposes only. **Repeat Violation** **Admin Complaint**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324737

APARTMENTS

License Type: Apartment

2120 SW 4 ST, MIAMI 331351859

Inspection Date: 04/23/2020

Inspection Number: 1468891

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ALEJANDRO

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. For apartment 1-2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310961

SUNSET MANOR APTS

License Type: Apartment

7500 SW 59 PLACE, MIAMI 33143

Inspection Date: 04/24/2020

Inspection Number: 1474967

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed no glass breaker at the fire extinguisher box next to apartment 215

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324330

FOUNTAINBLEAU MILTON

License Type: Apartment

9501 FOUNTAINBLEAU BLVD, MIAMI 331726805

Inspection Date: 04/20/2020

Inspection Number: 1489423

Inspection Type: Complaint Partial

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device for fire extinguisher on building 9591 across from unit 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609033

GRASSY POND APARTMENTS

License Type: Apartment

5641 CALIFORNIA AVE, JACKSONVILLE 32244

Inspection Date: 04/21/2020

Inspection Number: 1480606

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Two extinguishers missing on courtyard side on building 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900375

UPTOWN AMBRUS INVESTMENTS LLC

License Type: Apartment

13142 N 22 ST, TAMPA 33612

Inspection Date: 04/23/2020

Inspection Number: 1487248

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Exterior casing in disrepair and no method to break panel.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600554

BRENTWOOD APARTMENTS

License Type: Apartment

107 A BRENTWOOD AVE, CRESTVIEW 325398958

Inspection Date: 04/20/2020

Inspection Number: 1473598

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
- apartment 106C: backside wires are hanging low (below 6 feet).

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003033		J6 HOLDINGS LLC	
License Type: Apartment		301 OLD DIXIE HWY, RIVIERA BEACH 33404	
Inspection Date: 04/24/2020	Inspection Number: 1478716	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only.unable to see gauge (blocked by tags).	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6013861		BOCA PLAZA HOTEL	
License Type: Hotel		2901 N FEDERAL HWY, BOCA RATON 33431	
Inspection Date: 04/23/2020	Inspection Number: 1153088	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6012655		FAIRFIELD INN & SUITES JUPITER	
License Type: Hotel		6748 INDIANTOWN RD, JUPITER 33458	
Inspection Date: 04/24/2020	Inspection Number: 2979070	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121021 exp 03/15/2019, 121022 exp 03/15/2019, 095111 exp 03/15/2019	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pasco County

License Number: 6102841

DELCHARLES ARMS

License Type: Apartment

37216 CLINTON AVENUE, DADE CITY 33525

Inspection Date: 04/22/2020

Inspection Number: 1474351

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on building 37216. For reporting purposes only.
Fire extinguishers present on exterior of building 37232 and 37222.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205429

NAUTICA APTS

License Type: Apartment

12275 3 ST E, TREASURE ISLAND 33706

Inspection Date: 04/24/2020

Inspection Number: 1477220

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Bicycle and coolers in walkway 2nd floor near unit 7 unable to exit unit 6 to right stair well.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200241

DAYS INN

License Type: Motel

5005 34TH ST N, ST. PETERSBURG 33714

Inspection Date: 04/22/2020

Inspection Number: 1209562

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6200806

EL CAMINO APARTMENTS

License Type: Apartment

1255 JEFFORDS STREET, CLEARWATER 33756

Inspection Date: 04/21/2020

Inspection Number: 1485746

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: VILLEGAS, TATTYANA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
Alarm pull station non operable in front of Building B unit 121.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405884

KRISHNA OF DAYTONA INC

License Type: Motel

315 BELLEVUE AVE, DAYTONA BEACH 32114

Inspection Date: 04/21/2020

Inspection Number: 1208848

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 107 .
Do rent or occupy room 107 until a fully operating smoke detector is installed.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406483

DAYTONA BEACH RESIDENCE INN

License Type: Hotel

1725 RICHARD PETTY BLVD, DAYTONA BEACH 32114

Inspection Date: 04/20/2020

Inspection Number: 1153252

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Signals silenced light on

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401047

FLAMINGO MOTEL

License Type: Motel

1915 N. ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 04/22/2020

Inspection Number: 1210474

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher between 7/8 missing breaking device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406509

BEACH HOUSE INN

License Type: Motel

1601 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 04/24/2020

Inspection Number: 1210028

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
No breaker device between room 201-202

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Above unit 201, several visual indicators of a potentially hazardous damaged wire, located close to a stairwell and door to guest room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.