

Alachua County

License Number: 1102671

THE PADDOCK CLUB GAINESVILLE

License Type: Apartment

1105 FT CLARKE BLVD, GAINESVILLE 32606

Inspection Date: 04/30/2020

Inspection Number: 1482773

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

07-04-4

Electrical device damaged to indicate a malfunction. For reporting purposes only.
Exit sign above door to unit 1310 hanging from wires.
Light in stair by 1412 partially detached.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502506 HILTON MELBOURNE BEACH OCEANFRONT
 License Type: Hotel 3003 N HWY A1A, MELBOURNE 32903

Inspection Date: 04/30/2020 Inspection Number: 1153967 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near front lobby outside dining room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Sticker on units were certified 4-29-20	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-06-4	Combustibles stored in boiler room. For reporting purposes only. Propane tanks, wood chairs, portable bar Operator states boilers are not in use during COVID 19	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618324		SFM PROPERTIES LLC	
License Type: Apartment		618 SW 4 AVE, HALLANDALE 33009	
Inspection Date: 04/27/2020	Inspection Number: 1489276	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-02-4	Rear windows is blocked by Hurricane shutters on building 618 and 622. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621081		YD MADISSON LLC	
License Type: Apartment		1652 MADISON ST, HOLLYWOOD 33020	
Inspection Date: 04/29/2020	Inspection Number: 1478868	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Two Portable fire extinguishers pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1614666		BELA SERA AT FORREST HILLS	
License Type: Apartment		2733 FORREST HILLS BLVD, CORAL SPRINGS 33065	
Inspection Date: 04/27/2020	Inspection Number: 1474532	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRADY, OSSIAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed fire extinguisher by Units 11 and 12 of building 2845, gauge appears to be in overcharge zone; Observed fire extinguisher by Units 7 and 8 of building 2867, gauge appears to be in overcharge zone;	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1603810		800 NE 14TH PL LLC	
License Type: Apartment		800 NE 14 PL, FORT LAUDERDALE 33304	
Inspection Date: 04/30/2020	Inspection Number: 1481107	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. BBQ grill with attached propane tank stored under staircase by Apt 5. Inspector will email inspection report to Fire Marshall Jeff Lucas for review.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Collier County

License Number: 2102315

THE POINT AT NAPLES

License Type: Apartment

2155 GREAT BLUE DR, NAPLES 34112

Inspection Date: 04/30/2020

Inspection Number: 1483369

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Building 14. Observed first floor rear fire extinguisher missing device to break glass. Observed fire extinguisher in front of apartment 201 missing device to break glass. Building 13. Observed fire extinguisher in front of apartment 202 missing device to break glass. Observed fire extinguisher in front of apartment 101 missing device to break glass. Building 12. Observed fire extinguisher in front of apartment 101 and 102 missing device to break glass.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2102383

COLLEGE PARK APTS HOME

License Type: Apartment

6450 COLLEGE PK CIR, NAPLES 34113

Inspection Date: 04/29/2020

Inspection Number: 1468221

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building five. Observed second floor fire extinguisher in front of apartment 207 in need of recharge. Building five. Observed third floor fire extinguisher in front of apartment 303 in need of recharge. Building six. Observed third floor fire extinguisher in front of apartment 307 in need of recharge. Building seven. Observed second floor fire extinguisher in front of apartment 203 in need of recharge. Building seven. Observed first floor fire extinguisher in front of apartment 105 in need of recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Building seven. Observed fire extinguisher in front of apartment 303 in locked box with no implement to break glass. Building seven. Observed fire extinguisher in front of apartment 102 in locked box with no implement to break glass. Building eight. Observed fire extinguisher in front of apartment 102 in locked box with no implement to break glass.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200048

PALM VILLAS APARTMENTS

License Type: Apartment

4826 US HWY 441 S, LAKE CITY 32025

Inspection Date: 04/27/2020

Inspection Number: 1474549

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher in front of room 107.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200607

THE GROVE APT

License Type: Apartment

384 SW DEXTER CIR, LAKE CITY 32025

Inspection Date: 04/27/2020

Inspection Number: 1482868

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.
Two tanks in storage building at the end of building of building 403.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200233

PLEASANT POINTE

License Type: Apartment

153 NW CR 25A, LAKE CITY 32055

Inspection Date: 04/27/2020

Inspection Number: 1475587

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in front of apartment 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303564		LE BO APTS	
License Type: Apartment		75 W 11 ST, HIALEAH 330103976	
Inspection Date: 04/29/2020	Inspection Number: 1468114	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: VILCHEZ, NABEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher without breaking device next to unit 8,6,21. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2304549		HIALEAH 19 UNITS LLC	
License Type: Apartment		421 E 29 ST, HIALEAH 33013	
Inspection Date: 04/29/2020	Inspection Number: 1486913	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near apartment #8 and #9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2308513		FLORIDIAN HOTEL OF HOMESTEAD	
License Type: Motel		990 N HOMESTEAD BLVD, HOMESTEAD 33030	
Inspection Date: 04/29/2020	Inspection Number: 1206494	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box with no means of access located between room 323 and water heating room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2311097		L & M APARTMENTS	
License Type: Apartment		1000 NW 27 ST, MIAMI 331274069	
Inspection Date: 04/30/2020	Inspection Number: 1468800	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Located by apt 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2328377		WEST BRICKELL APARTMENTS	
License Type: Apartment		955 SW 2 AVE, MIAMI 33130	
Inspection Date: 04/27/2020	Inspection Number: 1469005	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed extinguisher on 15th floor by unit 1509. Observed extinguisher on 6th floor by unit 601.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2300875		VALENCIA 520-524 LLC	
License Type: Apartment		101 ANTIQUERA AVE, CORAL GABLES 33134	
Inspection Date: 04/29/2020	Inspection Number: 1481250	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only extinguisher in box by apartment 5.missing glass breaker hammer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2305809		1943 - 71 ST APTS	
License Type: Apartment		1943 71 ST, MIAMI BEACH 331416907	
Inspection Date: 04/28/2020	Inspection Number: 1470680	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 3 and 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330427		NORTHSIDE PROPERTY IV LTD	
License Type: Apartment		3160 NW 79 ST, LEASING OFFICE, MIAMI 33147	
Inspection Date: 04/27/2020	Inspection Number: 1489445	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2310667

NOELA APARTMENTS LLC

License Type: Apartment

2240 SW 67 AVE, MIAMI 33155

Inspection Date: 04/27/2020

Inspection Number: 1489467

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: URIBE, GUISELLA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher by apt 25.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600619

GOLDEN SHORES JACKSONVILLE (JASPER)

License Type: Apartment

7703 HARE AVE, JACKSONVILLE 32211

Inspection Date: 04/28/2020

Inspection Number: 1489459

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Fire extinguisher missing next to unit 176, 230, and 227.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906225

FOUR POINTS SHERATON TAMPA AIRPORT WESTSHORE

License Type: Hotel

4400 W CYPRESS ST, TAMPA 33607

Inspection Date: 04/30/2020

Inspection Number: 1152951

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. "Room 521 smoke detectors z095." Establishment currently under renovations. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. 120542;120543 expire 11/08/2019. Boilers inspected 01/25/2020, certificate not generated due to unpaid fees operated paid fees during inspection. For reporting purposes only.
Corrective Action Taken

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913628

THE CASS FLATS

License Type: Apartment

3710 & 3712 W CASS ST, TAMPA 33609

Inspection Date: 04/30/2020

Inspection Number: 1483688

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Hammer missing from box. Next to Apt 14

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3901995

SEVILLA APTS

License Type: Apartment

4507 MCELROY, TAMPA 336113373

Inspection Date: 04/28/2020

Inspection Number: 1469090

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near apt 6 **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800717

HOST INN MOTEL

License Type: Motel

919 W COLONIAL DRIVE, ORLANDO 32804

Inspection Date: 05/01/2020

Inspection Number: 1209158

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. -room 103, operator removed to prevent theft. **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5800269

ROCK LAKE COTTAGES

License Type: Apartment

1301 GIVENS STREET, ORLANDO 32805-1301

Inspection Date: 04/28/2020

Inspection Number: 1479248

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801635

VACATION LODGE

License Type: Motel

720 S ORANGE BLOSSOM TRL, ORLANDO 32805-3144

Inspection Date: 04/30/2020

Inspection Number: 1209336

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near laundry facility next to room 129, hammer is missing.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811131

DRURY INN & SUITES ORLANDO

License Type: Hotel

7301 W SAND LAKE RD, ORLANDO 32819

Inspection Date: 04/28/2020

Inspection Number: 1153344

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6004110		1031 SOUTH WOOSTER LTD	
License Type: Motel		1901 PALM BEACH LAKES BLVD., WEST PALM BEACH 33409	
Inspection Date: 04/27/2020	Inspection Number: 1209519	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: DE JESUS, ARLENNY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Provided Boiler certificates B00061710 & B00061709 expired on 05/02/2019. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6007233		DOUBLETREE WEST PALM BEACH AIRPORT	
License Type: Hotel		1808 S AUSTRALIAN AVE, WEST PALM BEACH 33409	
Inspection Date: 04/27/2020	Inspection Number: 1152740	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE JESUS, ARLENNY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6014042		HILTON GARDEN INN WEST PALM BEACH AIRPORT	
License Type: Hotel		1611 WORTHINGTON RD, WEST PALM BEACH 33409	
Inspection Date: 04/27/2020	Inspection Number: 1152742	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DE JESUS, ARLENNY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. One Gentex- Hearing smoke detector not functioning when tested.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6010102		COURTYARD BY MARRIOTT	
License Type: Hotel		2000 NW EXECUTIVE CT, BOCA RATON 33431	
Inspection Date: 04/29/2020	Inspection Number: 1153074	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired door bell on room 302 not working	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pasco County

License Number: 6101249

WORTHINGTON COURT APARTMENTS

License Type: Apartment

7541 HIGHWATER DR, NEW PORT RICHEY 34655

Inspection Date: 04/28/2020

Inspection Number: 1482357

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Building k.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6100006

HOLIDAY HOTEL AND RESORT

License Type: Motel

2337 US HWY 19, HOLIDAY 34691

Inspection Date: 04/29/2020

Inspection Number: 1209392

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher in front of room 144 and next to room 155.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215184 BAYWALK APARTMENTS
 License Type: Apartment 301 11TH AVE NE, ST. PETERSBURG 33701

Inspection Date: 04/30/2020 Inspection Number: 1478700 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILLEGAS, TATTYANA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Behind building.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213899 BEACH HOUSE SUITES BY DON CESAR
 License Type: Hotel 3860 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 04/28/2020 Inspection Number: 1152095 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher on floor 4 near stairwell and unit 4410 in over charge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215539 SANDS OF TREASURE ISLAND
 License Type: Motel 11800 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 04/30/2020 Inspection Number: 1209872 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 2018. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215783

SWASHBUCKLER MOTEL

License Type: Motel

11875 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 04/30/2020

Inspection Number: 1209255

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in recharge zone near unit 1. - From follow-up inspection 2020-04-30: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in recharge zone near unit 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203376

GROVE ST APARTMENTS

License Type: Apartment

1143 GROVE ST, CLEARWATER 33755

Inspection Date: 04/27/2020

Inspection Number: 1476644

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Wire on ground behind building still connected to the power pole, resident stated it is a cable wire and he has made many attempts to get it taken care of but cable company has not been out yet to fix.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201091

BETTY LANE APARTMENTS

License Type: Apartment

311 S BETTY LANE, CLEARWATER 33756

Inspection Date: 04/28/2020

Inspection Number: 1486399

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to unit 34.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301176

A-P-T SUITES

License Type: Motel

4645 N SOCRUM LOOP RD, LAKELAND 33809

Inspection Date: 04/28/2020

Inspection Number: 1208104

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: GARCIA, GUADALUPE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 118-119. - From follow-up inspection 2020-04-28: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 118-119. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700027

EMERALD SANDS INN

License Type: Motel

6436 W HWY 90, MILTON 325704527

Inspection Date: 04/29/2020

Inspection Number: 1205894

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MCGEE, MONACO

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 106, and room 201.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6902421

REGATTA SHORES APTS

License Type: Apartment

2335 W SEMINOLE BLVD, SANFORD 327717930

Inspection Date: 04/27/2020

Inspection Number: 1472602

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Notified Mark James, Sanford Fire Inspector. 407-562-2786. - From follow-up inspection 2020-04-27:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501417

HOLIDAY INN ST AUGUSTINE-WORLD GOLF VILLAGE

License Type: Hotel

475 COMMERCE LAKE DR, SAINT AUGUSTINE 32095

Inspection Date: 04/27/2020

Inspection Number: 1153498

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2020-04-27: At callback : establishment still waiting for report. ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Establishment still needs boiler certification.
Inspection completed per person in charge

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405788

EXTENDED STAY AMERICA #1564

License Type: Hotel

255 BILL FRANCE BLVD, DAYTONA BEACH 32114

Inspection Date: 04/29/2020

Inspection Number: 1153963

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Silenced light on silent knight box about FACP box.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406503

RESIDENCE INN DAYTONA OCEANFRONT

License Type: Hotel

3209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 04/27/2020

Inspection Number: 1152478

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 2 of the 3 units in the boiler room exceed the 120 Gallon water capacity threshold at a level of 130 Gallons which requires a certificate of boiler inspection.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400673

BEST WESTERN DAYTONA INN SEABREEZE

License Type: Motel

730 N ATLANTIC AVE, DAYTONA BCH 321183805

Inspection Date: 04/27/2020

Inspection Number: 1209307

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble, silenced, memory lights yellow during time of inspection.
Repeat Violation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.