

Brevard County

License Number: 1500633 MONTEREY BAY APARTMENTS
 License Type: Apartment 1615 MITCHELL ST, MELBOURNE 32901

Inspection Date: 06/23/2020 Inspection Number: 1479690 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside of apartment 2b	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505783 DI PALERMO LLC
 License Type: Apartment 520 MONROE AVE, CAPE CANAVERAL 32920

Inspection Date: 06/23/2020 Inspection Number: 1484769 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500651 CIRCLE AVENUE APARTMENTS
 License Type: Apartment 35 E CIRCLE AVE, MELBOURNE 329356729

Inspection Date: 06/22/2020 Inspection Number: 1470125 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By unit 7. Amir states someone has already been called.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602458 BEACH ROOMS - HOLLYWOOD BEACH
 License Type: Apartment 315 ARTHUR ST, HOLLYWOOD 33019

Inspection Date: 06/25/2020 Inspection Number: 1482960 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

Violation Code Observation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to room 22 and 30.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600794 SEA WIND APARTMENTS
 License Type: Apartment 2210 N SURF RD, HOLLYWOOD 33019-3517

Inspection Date: 06/22/2020 Inspection Number: 1472807 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

Violation Code Observation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621368 FILLMORE APATTMENTS INC
 License Type: Apartment 6219 SW 30 ST, MIRAMAR 33023

Inspection Date: 06/25/2020 Inspection Number: 1484867 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GANPAT, INDAR

Violation Code Observation

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1602463 THE VICTORIA PARK HOTEL LLC
 License Type: Hotel 855 NE 20 AVE, FORT LAUDERDALE 33304

Inspection Date: 06/26/2020 Inspection Number: 1152391 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

Violation Code Observation

01-01-4 Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By Apt 110 and 203.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621076 BEACH HOUSE VILLAS
 License Type: Apartment 2901 RIO MAR STREET, FORT LAUDERDALE 33304

Inspection Date: 06/22/2020 Inspection Number: 1478751 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. BBQ grill with attached tank and 2 extra tanks under catwalk by pool that attaches to stairs. Inspector will email Inspection Report to Fire Marshall for review.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621092 BEACH HOUSE VILLAS
 License Type: Apartment 2901 RIO MAR ST, UNITS #: 102,103,104,105, 204 & 205, FORT LAUDERDALE 33304

Inspection Date: 06/22/2020 Inspection Number: 1486433 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. BBQ grill with attached tank and 2 extra tanks under catwalk by pool that attaches to stairs. Inspector will email Inspection Report to Fire Marshall for review.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1601745 4605 N OCEAN DR LLC
 License Type: Motel 4605 N OCEAN DR, LAUDERDALE BY THE SE 33308

Inspection Date: 06/26/2020 Inspection Number: 1210741 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DEJONG, STEVEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). By unit #16. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1603330 BEACHSIDE VILLAGE RESORT
 License Type: Motel 4553 EL MAR DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 06/26/2020 Inspection Number: 1210737 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: EVANS, EUGENE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By shower by back pool. Manager called for service **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602446

CYPRESS GROVE APARTMENTS

License Type: Apartment

4200 NW 19TH STREET, LAUDERHILL 33313

Inspection Date: 06/24/2020

Inspection Number: 1489342

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Observed Fire Extinguisher in laundry room in recharge zone. Serial F86641158

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102368

PALMDALE APTS

License Type: Apartment

2884 PINE ST, NAPLES 34112

Inspection Date: 06/25/2020

Inspection Number: 1468220

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed no fire extinguisher available at building 2881, 2883/ 2887, 2884, 2842, 2844, 2841, 2843.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306048 110 E 10 ST APTS
 License Type: Apartment 110 E 10 ST, HIALEAH 330104081

Inspection Date: 06/23/2020 Inspection Number: 1473462 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310301 SALCINES INVESTMENTS INC
 License Type: Apartment 974 NE 5 AVE, HOMESTEAD 33030

Inspection Date: 06/26/2020 Inspection Number: 1476344 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322076 QUALITY INN FLORIDA CITY-HOMESTEAD
 License Type: Motel 333 SE 1ST AVE, FLORIDA CITY 33034

Inspection Date: 06/24/2020 Inspection Number: 1209049 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330269 CRYSTAL LAKE APARTMENTS
 License Type: Apartment 2601 NW 207 ST, MIAMI GARDENS 33056

Inspection Date: 06/23/2020 Inspection Number: 1490012 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. On newly constructed building, no fire extinguishers located upstairs between apartments #258-#268	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed a broken hammer at Fire Extinguisher #172 & #173, and apartment #162 & #163.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300393 859 BUILDING
 License Type: Apartment 859 NW 1 ST, MIAMI 331281303

Inspection Date: 06/26/2020 Inspection Number: 1468357 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed the fire extinguisher with hose in disrepair condition next to apartment 1.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312471 NEVETTE CONST APTS
 License Type: Apartment 721 NW 2 ST, MIAMI 331281422

Inspection Date: 06/25/2020 Inspection Number: 1473519 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located at first floor next to #2 apartment, missing breaking device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329244 EXTENDED STAY AMERICA #1760
 License Type: Hotel 298 SW 15 RD, MIAMI 33129

Inspection Date: 06/25/2020 Inspection Number: 1154114 Inspection Type: Complaint Full Inspection Disposition: Call Back -
 Extension given, pending
 Inspector Name: WILLIAMS, ALFREDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 097115 exp 6/12/20, 097116 exp 6/12/20 - From follow-up inspection 2020-06-25: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 097115 exp 6/12/20, 097116 exp 6/12/20	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329254 STAY ALFRED
 License Type: Hotel 1701 SW 2 AVE, MIAMI 33129

Inspection Date: 06/24/2020 Inspection Number: 1152834 Inspection Type: Routine - Lodging Inspection Disposition: Warning
 Issued
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Supervisory indicator light on, as per operator technicians have been notified.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312540 555 SW 4 ST
 License Type: Apartment 555 SW 4 ST, MIAMI 33130

Inspection Date: 06/23/2020 Inspection Number: 1481735 Inspection Type: Routine - Lodging Inspection Disposition: Warning
 Issued
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By Unit 101.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330237 THE LUXE MIAMI
 License Type: Apartment 971 W FLAGLER ST, MIAMI 33130

Inspection Date: 06/23/2020 Inspection Number: 1486555 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 9	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304335 BRICKELL WEST APARTMENTS
 License Type: Apartment 244 SW 9 ST, MIAMI 331303572

Inspection Date: 06/22/2020 Inspection Number: 1470616 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: URIBE, GUISELLA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguishers: First floor Apartment 8 Second floor apartments 8, 10, 12, 15 Third floor apartments 18, 25, 28	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305567 LEAMINGTON HOTEL
 License Type: Hotel 307 NE 1 ST, MIAMI 33132

Inspection Date: 06/25/2020 Inspection Number: 1154126 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Gentex portable hearing impaired equipment strobe light no working at the time of inspection.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304530 HIGGS APARTMENTS
 License Type: Apartment 130 ANTIQUERA AVE, CORAL GABLES 331343051

Inspection Date: 06/05/2020 Inspection Number: 1470656 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only, observed no lights on the panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329717 711 BEACOM APARTMENTS
 License Type: Apartment 711 BEACOM BLVD, MIAMI 33135

Inspection Date: 06/22/2020 Inspection Number: 1480932 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2312614 MUJICA APARTMENTS
 License Type: Apartment 1028 NW 6 ST, MIAMI 331363731

Inspection Date: 06/25/2020 Inspection Number: 1468790 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By door 5. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329267 JOHNSON'S APARTMENTS
 License Type: Apartment 1506 NW 70 ST, MIAMI 33142

Inspection Date: 06/23/2020 Inspection Number: 1476686 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only,located at first floor unit.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329416 VILLAGE ALLAPATTAH PII LLC
 License Type: Apartment 2378 NW 17 AVE, MIAMI 33142

Inspection Date: 06/26/2020 Inspection Number: 1477966 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600639 ALMIRA GARDEN APARTMENTS
 License Type: Apartment 1616 ALMIRA ST, JACKSONVILLE 322115302

Inspection Date: 06/22/2020 Inspection Number: 1473244 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguishers missing from all fire boxes including the following areas: outside unit 5, unit 20, unit 24, unit 29, and unit 12	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611854 OAK HAMMOCK LTD
 License Type: Apartment 500 ACME ST, JACKSONVILLE 322117444

Inspection Date: 06/22/2020 Inspection Number: 1469161 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
03-04-4	Fire sprinkler head obstructed/covered. For reporting purposes only. Sprinkler head outside unit 608 obstructed by ceiling debris where a hole has been cut.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613311 UNIVERSITY PLACE APARTMENTS
 License Type: Apartment 3285 UNIVERSITY BLVD. NORTH, JACKSONVILLE 32277

Inspection Date: 06/22/2020 Inspection Number: 1479651 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. No fire extinguisher between units 144 and 145, no extinguisher between units 146 and 147 in designated holders **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900203

REGENCY INN

License Type: Motel

720 E FOWLER AVE, TAMPA 33612

Inspection Date: 06/22/2020

Inspection Number: 1211336

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCINTYRE, REGIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
One of the two hearing impaired smoke detectors was not functioning.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4100011

ROYAL VIKING APARTMENTS

License Type: Apartment

706 ROYAL PALM BLVD, VERO BEACH 32960

Inspection Date: 06/23/2020

Inspection Number: 1483938

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FRANZ, LISA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.- extinguisher on 1st floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602408

HOLIDAY INN EXPRESS

License Type: Hotel

1538 CAPE CORAL PKWY, CAPE CORAL 339049610

Inspection Date: 06/24/2020

Inspection Number: 1154111

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-06-4	Combustibles stored in boiler room. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403186

NYAH KEY WEST

License Type: Hotel

823 FLEMING ST, KEY WEST 33040

Inspection Date: 06/22/2020

Inspection Number: 1154122

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403191

CASA MARINA A WALDORF ASTORIA RESORT

License Type: Hotel

1500 REYNOLDS ST, KEY WEST 33040

Inspection Date: 06/22/2020

Inspection Number: 1154119

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MECK, PAMELA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811239 CHRISTIANNE SANTANA
 License Type: Apartment 7900 S ORANGE TRAIL #1054, ORLANDO 32809

Inspection Date: 01/29/2020 Inspection Number: 1490044 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	Observed: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per manager of the hotel license number 5810954 two new boilers have been installed waiting to be inspected, Priority: Reporting	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Inspection Date: 03/19/2020 Inspection Number: 1490044 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	Observed: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per manager of the hotel license number 5810954 two new boilers have been installed waiting to be inspected, Priority: Reporting	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808862 EXTENDED STAY AMERICA #1577
 License Type: Hotel 5610 VINELAND RD, ORLANDO 32819

Inspection Date: 06/22/2020 Inspection Number: 1153901 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble smoke hallway 3rd floor by room 324	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5801664 PENDELTON PARK VILLAS
 License Type: Apartment 5953 CURRY FORD RD, ORLANDO 32822

Inspection Date: 06/23/2020 Inspection Number: 1483309 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge, laundry room. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801665

CARLYLE COURT APARTMENTS

License Type: Apartment

5900 CURRY FORD RD, ORLANDO 32822

Inspection Date: 06/23/2020

Inspection Number: 1483308

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked, trash bags in hallway, by apt 39. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804817

GRAND FLORIDIAN BCH RESORT

License Type: Hotel

4401 FLORIDIAN WAY, BAY LAKE 32830

Inspection Date: 06/25/2020

Inspection Number: 1153309

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212564 THE VINOY RENAISSANCE ST PETERSBURG RESORT & GC
 License Type: Hotel 501 FIFTH AVE NE, ST. PETERSBURG 33701

Inspection Date: 06/26/2020 Inspection Number: 1152944 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Repairs in progress. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203064 TRADEWINDS SANDPIPER BEACH RESORT
 License Type: Motel 6000 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 06/23/2020 Inspection Number: 1209563 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAY-WALKER, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow system trouble light illuminating on lobby fire panel. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6204199 BET LIN APARTMENTS
 License Type: Apartment 117 127 AVE, TREASURE ISLAND 33706

Inspection Date: 06/25/2020 Inspection Number: 1481223 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: DAHL, MICHELE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.by garage door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215951 GATEWAY NORTH
 License Type: Apartment 2681 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 06/24/2020 Inspection Number: 1486940 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Next to 9101, 9209,	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202636

SANDS POINT MOTEL

License Type: Motel

433 CORONADO DR, CLEARWATER BEACH 33767

Inspection Date: 06/24/2020

Inspection Number: 1209182

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Timer outlet missing cover, located under steps. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6210194

CLEARWATER BEACH HOTEL

License Type: Motel

504 S GULF VIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 06/22/2020

Inspection Number: 1207112

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of
recharge. For reporting purposes only.
Next to 412.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301099

STAY PLUS INN

License Type: Motel

33224 HWY 27 S, HAINES CITY 33844

Inspection Date: 06/26/2020

Inspection Number: 1211373

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 108, 158.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 06/26/2020

Inspection Number: 1153676

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406506 ATLANTIC ECONOMY INN
 License Type: Motel 808 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 06/25/2020 Inspection Number: 1209552 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By room 122. - From follow-up inspection 2020-06-25: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400673 BEST WESTERN DAYTONA INN SEABREEZE
 License Type: Motel 730 N ATLANTIC AVE, DAYTONA BCH 321183805

Inspection Date: 06/26/2020 Inspection Number: 1209307 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble, silenced, memory lights yellow during time of inspection. **Repeat Violation** - From follow-up inspection 2020-05-27: **Time Extended** - From follow-up inspection 2020-06-26: Operator currently installing new panel **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.